

Branch Panel: CLDB

Location: SERVER ROOM 399

Supply From: RDB

Mounting: Recessed

Enclosure: Type 1

Notes:

Voltage: 230/400 Vye

Phases: 3

Wires: 4

A.L.C. Rating:

Maina Type:

Maina Rating: 100 A

MCB Rating: 100 A

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT	
1	Lighting	20 A	1	1296 ... 972 VA				1	20 A Lighting	2	
3	Lighting	20 A	1		20 VA 40 VA			1	20 A Lighting	4	
5	Lighting	20 A	1			1080 ... 1296 ...		1	20 A Lighting	6	
7	Lighting	20 A	1	20 VA 972 VA				1	20 A Lighting	8	
9	Lighting	20 A	1		40 VA 1080 ...			1	20 A Lighting	10	
11	Lighting	20 A	1			320 VA 720 VA		1	20 A Lighting	12	
13	Lighting	20 A	1	640 VA 720 VA				1	20 A Lighting	14	
15	Lighting	20 A	1		720 VA 720 VA			1	20 A Lighting	16	
17										18	
19										20	
21										22	
23										24	
25										26	
27										28	
29										30	
31										32	
33										34	
35										36	
37										38	
39										40	
41										42	
Total Load:		4519 VA		2617 VA		3416 VA					
Total Amps:		20 A		11 A		15 A					

Legend:

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals
Lighting - Dwelling Unit	48 VA	100.00%	48 VA	Total Conn. Load: 10552 VA
Lighting	10504 VA	100.00%	10504 VA	Total Est. Demand: 10552 VA
				Total Conn.: 15 A
				Total Est. Demand: 15 A

Branch Panel: CSDB1

Location: SERVER ROOM 399

Supply From: MDB

Mounting: Recessed

Enclosure: Type 1

Notes:

Volt: 230/400 V/50

Phases: 3

Wires: 4

A.I.C. Rating:

Main Type:

Main Rating: 100 A

MCB Rating: 400 A

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT	
1	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	2	
3	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	4	
5	Power	20 A	1			2200 VA 2200 VA		1	20 A Power	6	
7	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	8	
9	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	10	
11	Power	20 A	1			2200 VA 2200 VA		1	20 A Power	12	
13	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	14	
15	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	16	
17	Power	20 A	1			2200 VA 2200 VA		1	20 A Power	18	
19	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	20	
21	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	22	
23	Power	20 A	1			2200 VA 2200 VA		1	20 A Power	24	
25	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	26	
27	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	28	
29	Power	20 A	1			2200 VA 2200 VA		1	20 A Power	30	
31	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	32	
33	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	34	
35	Power	20 A	1			2200 VA 2200 VA		1	20 A Power	36	
37	Power	20 A	1	2200 VA 2200 VA				1	20 A Power	38	
39	Power	20 A	1		2200 VA 2200 VA			1	20 A Power	40	
41										42	
Total Load:				30600 VA		30600 VA		29400 VA			
Total Amps:				137 A		137 A		116 A			

Legend:

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals
Power	88000 VA	100.00%	88000 VA	Total Conn. Load: 88000 VA
				Total Est. Demand: 88000 VA
				Total Conn.: 127 A
				Total Est. Demand: 127 A

Branch Panel: CSDB3

Location: SERVER ROOM 399

Supply From: MDB

Mounting: Recessed

Enclosure: Type 1

Notes:

Branch Panel: CSDB3										Branch Panel: ESDB1											
Location: SERVER ROOM 399					Location: SERVER ROOM 399					Location: SERVER ROOM 399					Location: SERVER ROOM 399						
Supply From: MDB					Supply From: MDB					Supply From: MDB					Supply From: MDB						
Mounting: Recessed					Mounting: Recessed					Mounting: Recessed					Mounting: Recessed						
Enclosure: Type 1					Enclosure: Type 1					Enclosure: Type 1					Enclosure: Type 1						
Notes:					Notes:					Notes:					Notes:						
CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT	CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT
1	Socket	20 A	1	1000 VA 1000 VA				1	20 A Socket	2	1	Socket	20 A	1	500 VA 1800 VA				1	20 A Socket	2
3	Socket	20 A	1		1000 VA 1500 VA			1	20 A Socket	4	3	Socket	20 A	1		1800 VA 250 VA			1	20 A Socket	4
5	Socket	20 A	1					1	20 A Socket	6	5	Socket	20 A	1					1	20 A Socket	6
7	Socket	20 A	1	5000 VA 1000 VA				1	20 A Socket	8	7	Socket	20 A	1	500 VA 1000 VA				1	20 A Socket	8
9	Socket	20 A	1		1000 VA 5000 VA			1	20 A Socket	10	9	Socket	20 A	1					1	20 A Socket	10
11	Socket	20 A	1				1	1000 VA 1000 VA	1	20 A Socket	12	11	Socket	20 A	1				1	20 A Socket	12
13	Socket	20 A	1	1500 VA 1000 VA				1	20 A Socket	14	13	Socket	20 A	1					1	20 A Socket	14
15	Socket	20 A	1		1000 VA 1000 VA			1	20 A Socket	16	15	Socket	20 A	1					1	20 A Socket	16
17	Socket	20 A	1				1	1000 VA 1000 VA	1	20 A Socket	18	17	Socket	20 A	1				1	20 A Socket	18
19	Socket	20 A	1	1000 VA 1500 VA				1	20 A Socket	20	19	Socket	20 A	1					1	20 A Socket	20
21	Socket	20 A	1		1500 VA 1000 VA			1	20 A Socket	22	21	Socket	20 A	1					1	20 A Socket	22
23	Socket	20 A	1				1	5000 VA 1000 VA	1	20 A Socket	24	23	Socket	20 A	1				1	20 A Socket	24
25	Socket	20 A	1	1000 VA 5000 VA				1	20 A Socket	26	25	Socket	20 A	1					1	20 A Socket	26
27	Socket	20 A	1		1500 VA 1000 VA			1	20 A Socket	28	27	Socket	20 A	1					1	20 A Socket	28
29	Socket	20 A	1				1	1000 VA 1000 VA	1	20 A Socket	30	29	Socket	20 A	1				1	20 A Socket	30
31	Socket	20 A	1	1000 VA 1000 VA				1	20 A Socket	32	31	Socket	20 A	1					1	20 A Socket	32
33										33											33
36										36											36
37										37											37
39										39											39
41										41											41
		Total Load:		21000 VA		15500 VA						Total Load:		21000 VA		15500 VA					
		Total Amps:		91 A		67 A		67 A				Total Amps:		91 A		67 A		67 A			

Legend:

1000 VA

1500 VA

5000 VA