





1. Panel standart must be folowing IP65/66, Powder coating, and covered wit acrylic glass inside panel as protection.

2. Double door in front of panel

3. Please put label name of the panel outside and attach wiring digram drawing inside.

4. DImension of panel 600x800x250 mm

5. MCB distribution @ 63A 20 PCs

6. Hole at Bus bar + must be have thread of screw (dlulir)

KETERANGAN / REMARKS

MENYETUJUI / APPROVED

PT. TELKOMSEL

NAME : DATE :

MENGETAHUI / ACKNOWLEDGED

MAIN CONTRACTOR

PT. HUAWEI

NAME : NGFRIZAL NISJA DATE :

SUBCONTRACTOR

DIGAMBAR DIPERIKSA DIKETAHUI

Tulis M

PROJECT

TELKOMSEL GBSS & UTRAN

NAMA GAMBAR / DRAWING TITLE

Panel Layout

SITE ID

SITE NAME

TTC Gayungan

SKALA / SCALE

REVISI / REVISION

NO. TANGGAL / DATE

PAPAF / SIGN

1.

2.

3.

4.

NO. REGISTER

3





