4.4 Design of Roof Slab:

The imposed loads on flat roofs, sloping roofs and curved roofs, due to use or occupancy of the building and the geometry of the types of roofs are given in Table -2 of IS:875(Part 2)-1987.

In our case, the imposed load on the roof slab is taken as **2 KN/m²** because the access is provided to the roofs. [It is given in page. 14, table – 2, clauses 4.1 of IS 875(part -2) – 1987]

For designation point of view, the roof slabs are named S1, S2, S3, and S4. Since each slab panel in our layout has unique dimensions (**2.8m x 3.4m**, **3.1m x 3.4m**, **2.8m x 3.28m**, and **3.1m x 3.28m**), there are no symmetrical groups, and each will be designed individually as shown in the figure below. The slab thickness is taken as **100mm**.




Figure 4.1: Slab.

DESIGN OF SLAB [S3]:

As per Ratio,

L_X = 2800 mm

L_Y = 3280 mm

$$\frac{Ly}{Lx} = \frac{3280}{2800} = 1.17 < 2$$

So the slab should be design as two way slab

Assuming the Depth:

Overall depth of the slab = d_o = 100 mm

Diameter of the bar in Shorter Span directions = 8 mm

Diameter of the bar in Longer directions = 8 mm

Clear cover = 15 mm

Code limits:

As per IS 456-2000 Overall depth of the slab should be greater of the following

1) d_o > 100 mm

   So it is satisfied.

Diameter of the bar:

The diameter of reinforcing bar shall not exceed one eight of the total thickness of the slab witch is given in page No.48 of IS - 456-2000 in article 26.5.2.2.

Maximum diameter of the bar = $\frac{1}{8}$ d_o

= $\frac{1}{8}$ x 100

= 12.5 mm > 8 mm

Maximum Dia of the bar > selected Dia bar

*So let us adopt **8mm** dia bar

Effective depth:

$d_{(short)} = 100 - 15 - \frac{8}{2} = 81$ mm

$d_{(longer)} = 100 - 15 - 8 - \frac{8}{2} = 73$ mm

EFFECTIVE LENGTH:

Shorter span:

[Given in page No.34 of IS - 456-2000 in article 22.2(a).]

It should be least of the following

(Clear Span= 2800-230= 2570mm)

1) Clear span + Half of the bearing on either side of the slab

[Bearing = 230mm]

$$= \frac{230}{2} + 2570 + \frac{230}{2}$$

$$= 2800 \text{ mm}$$

2) Clear span + Effective Depth

$$= 2570 + 81$$

$$= 2651 \text{ mm}$$

*So take Effective length = **2651mm**

Longer span:

[Given in page No.34 of IS - 456-2000 in article 22.2(a).]

It should be least of the following

(Clear Span= 3280-230= 3050mm)

1) Clear span + Half of the bearing on either side of the slab

[Bearing = 230 mm]

$$= \frac{230}{2} + 3050 + \frac{230}{2}$$

$$= 3280 \text{ mm}$$

2) Clear span + Effective Depth

$$= 3050 + 73$$

$$= 3123 \text{ mm}$$

*So take Effective length = **3123 mm**

LOADS ON THE SLAB:

As per IS – 875 (Part – 2) – 1987, the imposed loads on the roof slab is taken as 2 KN /m^2 where the access is provided to the roofs.

[It is given in page. 14, table – 2, cause 1(a) of IS 875(part -2) – 1987]

Self weight of the slab	= 1 x 1 x 0.100 x 25
	= 2.5 KN/m^2
Weight of weathering course	= 1 KN/m^2
Imposed load	= 2 KN/m^2
Total Load	= 5.5 KN/m^2

Now,

Factored load = 1.5 x 5.5 = 8.25 KN/m^2

FACTORED BENDING MOMENTS:

$$M_x = \propto_x \ W \ l_x^2$$

$$M_y = \propto_y \ W \ l_x^2$$

The value of $\propto_x$ and $\propto_y$ are given in table -26 of the IS 456- 2000 in page.no.91. This values are depends on type of panel and moment consideration.

$$\frac{Ly}{Lx} = \frac{3123}{2651} = 1.1780 \cong 1.18$$

Because Ly/Lx = 1.18, we interpolate between 1.1 and 1.2:

$\propto_x$= (-ve) 0.047 & (+ve) 0.0351

$\propto_y$= (-ve) 0.037 & (+ve) 0.028

M_{ux} (+ve) = 0.0351 x 8.25 x $(2.65)^2$ = 2.03 KN-m

M_{ux} (-ve) = 0.047 x 8.25 x $(2.65)^2$ = 2.72 KN-m

M_{uy} (+ve) = 0.028 x 8.25 x $(2.65)^2$ = 1.62 KN-m

M_{uy} (-ve) = 0.037 x 8.25 x $(2.65)^2$ = 2.14 KN-m

CHECK FOR DEPTH:

$$M_u = M_{u'lim}$$

$$M_u = 0.36 \frac{x_{u\,max}}{d} (1 - 0.42 \frac{x_{u\,max}}{d}) bd^2 f_{ck}$$

For 500 grade steel, $x_{u\,max}$ = 0.46d which is given in page No.70 of IS - 456-2000 in article38.1.] Here maximum bending moment is considered to check the thickness.

$$2.72 \times 10^6 = 0.36 \frac{0.46d}{d} (1 - 0.42 \frac{0.46d}{d}) 1000 \times d^2 \times 20$$

$$d_{(required)} = 31.90 \text{ mm}$$

$$d_{(required)} < d_{(provided)}$$

So the section is safe in bending.

AREA OF REINFORCEMENT IN SLAB (A_{st}):

$+ve$ Reinforcement for shorter span:

$$M_{ux}(+ve) = 0.87 f_y A_{st} d (1 - \frac{f_y A_{st}}{bd f_{ck}})$$

$$2.03 \times 10^6 = 0.87 \times 500 \times A_{st} \times 81 (1 - \frac{500 \times A_{st}}{1000 \times 81 \times 20})$$

$$A_{st} = 58.67\ mm^2$$

Minimum Reinforcement:

Code limits:

As per IS 456-2000, the minimum area of steel in slab should be provided 0.12% of gross area for HYSD bars. [It is given in page No.48 of IS - 456-2000 in article 26.5.2.1.]

$$A_{st\ (minimum)} = 0.12\%\ gross\ area$$

$$A_{st\ (minimum)} = \frac{0.12}{100} \times 1000 \times 100 = 120\ mm^2$$

$$A_{st(required)} < A_{st\ (minimum)}$$

So provide A_{st} minimum…,

Spacing:

It should be lesser of the following

1) $S = \frac{a_{st}}{A_{st}} \times 1000 \ = \frac{50.26}{120} \times 1000 = 418.83\ mm,$ where $(a_{st} = \frac{\pi}{4} \times 8^2 = 50.26)$
2) $S = 3d = 3 \times 81 = 243$
3) $S = 300mm$

Let us provide 8mm diameter HYSD bars at 240mm c/c. $[A_{st(provided)} = 209.41\ mm^2]$

$-ve$ Reinforcement for shorter span:

$$M_{ux}(-\boldsymbol{ve}) \ = \ 0.87\ f_y\ A_{st}\ \ d\ (1 - \frac{f_y A_{st}}{bd\ f_{ck}})$$

$$2.72 \times 10^6 \ = \ 0.87\ \times\ 500 \times\ A_{st} \times 81\ (1 - \frac{500 \times A_{st}}{1000 \times 81 \times\ 20})$$

$$A_{st} = 79.12\ mm^2$$

$$A_{st(required)} < A_{st\ (minimum)}$$

So provide A_{st} minimum…,

Spacing:

It should be lesser of the following

1) $S = \frac{a_{st}}{A_{st}} \times 1000 \ = \frac{50.26}{120} \times 1000 = 418.83\ mm,$ where $(a_{st} = \frac{\pi}{4} \times 8^2 = 50.26)$
2) $S = 3d = 3 \times 81 = 243$
3) $S = 300mm$

Let us provide 8mm diameter HYSD bars at 240mm c/c.

$+ve$ Reinforcement for longer span:

$$M_{uy}(+\boldsymbol{ve}) \ = \ 0.87\ f_y\ A_{st}\ \ d\ (1 - \frac{f_y A_{st}}{bd\ f_{ck}})$$

$$1.62 \times 10^6 \ = \ 0.87\ \times\ 500 \times\ A_{st} \times 73\ (1 - \frac{500 \times A_{st}}{1000 \times 73 \times\ 20})$$

$$A_{st} = 51.93\ mm^2$$

Code limits:

As per IS 456-2000, the minimum area of steel in slab should be provided 0.12% of gross area for HYSD bars. [It is given in page No.48 of IS - 456-2000 in article 26.5.2.1.]

$$A_{st\ (minimum)} = 0.12\%\ gross\ area$$

$$A_{st\ (minimum)} = \frac{0.12}{100} \times 1000 \times 100 = 120\ mm^2$$

$$A_{st(required)} < A_{st\ (minimum)}$$

So provide A_{st} minimum…,

Spacing:

It should be least of the following

1) $S = \frac{a_{st}}{A_{st}} \times 1000 \ = \frac{50.26}{120} \times 1000 = 418.83\ mm,$ where $(a_{st} = \frac{\pi}{4} \times 8^2 = 50.26)$
2) $S = 3d = 3 \times 73 = 219\ mm$
3) $S = 300mm$

Let us provide 8mm diameter HYSD bars at 210 mm c/c. $[A_{st(provided)} = 239.33\ mm^2]$

$-ve$ Reinforcement for longer span:

$$M_{uy}(-\boldsymbol{ve}) \ = \ 0.87 \ f_y \ A_{st} \ d \ (1 - \frac{f_y A_{st}}{bd \ f_{ck}})$$

$$2.1452 \times 10^6 \ = \ 0.87 \ \times \ 500 \times \ A_{st} \times 73 \ (1 - \frac{500 \times A_{st}}{1000 \times 73 \times \ 20})$$

$$A_{st} = 69.02\ mm^2$$

$$A_{st(required)} < A_{st\ (minimum)}$$

So provide A_{st} minimum…,

Spacing:

It should be least of the following

1) $S = \frac{a_{st}}{A_{st}} \times 1000 \ = \frac{50.26}{120} \times 1000 = 418.83\ mm,$ where $(a_{st} = \frac{\pi}{4} \times 8^2 = 50.26)$
2) $S = 3d = 3 \times 73 = 219\ mm$
3) $S = 300mm$

Let us provide 8mm diameter HYSD bars at 210 mm c/c.

CHECK FOR DEFLECTION:

Basic value for two-way slab is given in page.39, article 24.1 of IS 456-2000.

Basic value (BV) = 40

% of Steel = Pt = $\frac{A_{st}}{bd} \times 100 = \frac{209.41}{1000 \times 81} \times 100 = 0.26\%$

Based on Pt value take modification factor (MF) from code IS 456-2000 in page. 38(fig-4)

$$f_s \ = 0.58 \times 500 \times \frac{120}{209.41} \ = 166.18$$

MF = 2

$$d_{(required)} = \frac{leff}{BV \times MF} = \frac{2651}{40 \times 2} = 33.13mm$$

$$d_{(required)} < d_{(provided)}$$

So the section is safe in deflection.