SLAB DESIGN SUMMARY

Project Name	:	G+2 RB SLAB DESIGN @FLOOR 2
Client Name	:	Unassigned
Engineer Name	:	Unassigned
Design File	:	E:\MY PROJECT 4-1\STAAD\RCDC FILES\G+2 Project Plan-Slab-1-8.077 m.rcdx
Analysis File	:	E:\MY PROJECT 4-1\STAAD\G+2 Project Plan.std
Analysis Last Modified	:	06-10-2026 03:00:45

Panel Types:

One Way Slab:
1. Simply Supported
2. End Span
3. Span Next to End Span
4. Interior Span

Two Way Slab:
1. Interior Panel
2. One Short Edge Discontinuous
3. One Long Edge Discontinuous
4. Two Adjacent Edges Discontinuous
5. Two Short Edges Discontinuous
6. Two Long Edges Discontinuous
7. Three Edges Discontinuous (One Long Edge Continuous)
8. Three Edges Discontinuous (One Short Edge Continuous)
9. Four Edges Discontinuous
10. Simply Supported On Four Sides

Level: 8.077 m

Slab No. : **S1**

Ly = 4.99 m	Lx = 3.92 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 4
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S2**

Ly = 4.99 m	Lx = 3.92 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 2
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S3**

Ly = 4.99 m	Lx = 1.37 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 1-Way	Panel Type = 2
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	--	T8 @ 300	--	T8 @ 300

Slab No. : **S4**

Ly = 5.07 m	Lx = 3.92 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 3
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S5**

Ly = 5.07 m	Lx = 3.92 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 1
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution

T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S6**

Ly = 5.07 m	Lx = 1.37 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 1-Way	Panel Type = 2
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	--	T8 @ 300	--	T8 @ 300

Slab No. : **S7**

Ly = 4.5 m	Lx = 3.92 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 3
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S8**

Ly = 4.5 m	Lx = 3.92 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 1
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S9**

Ly = 4.5 m	Lx = 1.37 m
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm

Thickness = 150 mm	Span Type = 1-Way	Panel Type = 2
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	--	T8 @ 300	--	T8 @ 300

Slab No. : **S10**

Ly = 3.92 m	Lx = 2.13 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 4
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S11**

Ly = 3.92 m	Lx = 2.13 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 3
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300

Slab No. : **S12**

Ly = 2.13 m	Lx = 1.37 m	
Live Load = 2 kN/sqm	Imposed Load = 1.5 kN/sqm	
Thickness = 150 mm	Span Type = 2-Way	Panel Type = 4
Design Code = IS 456 : 2000 + IS 13920 : 2016	Grade of Concrete = M25	Grade of Steel = Fe550

Bottom SS	Bottom LS	Top SS	Top LS	Distribution
T8 @ 275	T8 @ 275	T8 @ 300	T8 @ 300	T8 @ 300