

<p><u>CORESO Engineers</u></p> <p><u>North :</u> SANTOS Eduardo</p> <p><u>South :</u> BOYER Jonathan</p>	<p>Day Ahead report for</p> <p>10 January 2018</p>
<p>Security Levels:</p> <p>CWE: No critical constraint detected.</p> <p>CEE: No critical constraint detected.</p> <p>CSE: No critical constraint detected.</p>	

Key overall conditions

Outages table

Exchange program forecasts

ELIA expected flows & PSTs tap position

CEE Renewable Power Generation & Forecast

CWE, CSE & SWE Renewable Power Forecast (D-1 and D-2)

RTE flows on cross-border lines

N state flows at 10:30 and 19:30

Special topologies at 10:30 and 19:30

North analyses results

Constraints on Elia, RTE (North) and 50HzT 400kV grids and tie-lines

Constraints greater than 100% on NL + Amprion 400kV grids and greater than 120% on DE, CZ, PL and SK 400kV grids

Constraints on ELIA 220/150kV grid at 10:30

50HzT DC loopflows sensitivity

South analyses results

N state flows Off-Peak & Peak

Special topologies

Sensitivity coefficients for the Pentalateral instruction

Constraints on APG, Eles, RTE (South), Swissgrid and Terna 400kV grids and tie-lines

Final PSTs settings

Conclusion

Key overall conditions

Load & Generation margin forecast			Main generating units connected to the grid in DACF					
ELIA			Elia	Doel	Pmax (MW)	1000	1	1900
						450	2	
Peak load [MW]	11 500	18:00		Tihange		1000	2	2900
						450	2	
Generation Margin	Sufficient			Coo		230	3	1170
						160	3	
			50HzT	Rostock	Pmax (MW)	530	1	530
				Janschwalde		500	5	2500
				Boxberg		500	2	2800
						900	2	
				Schw. Pumpe		800	2	1600
				Lippendorf		920	2	1840
RTE			RTE	Gravelines	Pmax (MW)	900	6	5400
Peak load [MW]	75 600	19:00		Chooz		1500	2	3000
				Cattenom		1300	4	5200
Generation Margin	Sufficient			Fessenheim		900	1	900
				Penly		1300	2	2600
NATIONAL GRID (UK time)				Paluel		1300	3	3900
Peak load [MW]	48 200	17:30		Nogent s/ Seine		1300	2	2600
				Generation Margin		Sufficient		Bugey
				St Alban		1300	2	2600
TERNA				Cruas		900	3	2700
Peak load [MW]	48 000	18:30		Tricastin		900	4	3600
			Generation Margin	Sufficient				

Generation margin legend:

Green: Sufficient margin available. No risk for need of inter-TSO solicitation due to margin issues.

Orange: Tight margin available. Low risk for need of inter-TSO solicitation due to margin issues.

Red: Insufficient margin available. High risk for need of inter-TSO solicitation due to margin issues.

Comments:

CWE / CEE



CSE


ELES: The PST of Divaca will be at tap -26 all day long due to technical issue.

Outages table

OUTAGES						
Owner	Type of element	Line name	start	end	Comments	
50HzT	Hydro.Gen	MARKERSBACH _ Unit D 400 kV	28/09/2017	27/04/2018	160 MW	
50HzT	Line	CROSSEN _ RÖHRSDORF 211 220 kV	08/01/2018	12/01/2018	Alternating	
50HzT	Line	CROSSEN _ RÖHRSDORF 212 220 kV	08/01/2018	12/01/2018	Alternating	
50HzT	Line	EULA _ Wolframhausen 357 220 kV	06/10/2017	16/03/2018		
50HzT	Line	GORRIES _ KRUMMEL 419 400 kV	09/01/2018	09/01/2018		
50HzT	Line	HAMBURG Nord _ HAMBURG Ost 961 400 kV	08/01/2018	12/01/2018		
50HzT	Line	LUBMIN _ LUDERSHAGEN 317-27 225 kV	08/01/2018	10/01/2018		
50HzT	Line	LUBMIN _ WIKINGER 281 220 kV	26/09/2017	31/01/2018		
50HzT	Line	RAGOW _ Förderstedt 531 400 kV	02/01/2018	14/01/2018		
50HzT	Line	RAGOW _ FORDERSTEDT 532 380 kV	02/01/2018	14/01/2018		
50HzT	Line	WOLMIRSTEDT _ WUSTERMARK 494 400 kV	09/01/2018	09/01/2018		
50HzT / PSE	Line	KRAJNIK _ VIERRADEN 507 225 kV	22/06/2016	31/05/2018	Long term outage	
50HzT / PSE	Line	KRAJNIK _ VIERRADEN 508 225 kV	22/06/2017	31/05/2018	Long term outage	
AMP / TEN DE	Line	NEHDEN _ TWISTETAL W 400 kV	08/01/2018	23/02/2018		
APG	Line	TAUERN _ PST 220 kV	14/12/2017	15/01/2018		
CEPS	Line	DASNY _ KOCIN 473 400 kV	08/01/2018	26/01/2018		
CREOS	Line	BERTRANGE _ SCHIFFFLANGE West 220 kV	08/01/2018	02/03/2018		
ELIA	Line	GEZELLE _ STEVIN 111 400 kV	19/09/2017	02/03/2018		
ELIA	Line	GEZELLE _ STEVIN 112 400 kV	19/09/2017	02/03/2018		
ELIA	Nuc.Gen	DOEL _ Unit 3 (1000MW) 400 kV	23/09/2017	16/04/2018	Forced outage	
PSE	Fossil.Gen	TUROW _ Unit 2 225 kV	01/03/2017	12/01/2018		
PSE	Line	POLANIEC _ TARNOW 400 kV	08/01/2018	12/01/2018		
PSE	Line	TUCZNAWA _ RZESZOW 400 kV	08/01/2018	12/01/2018		
RTE	Nuc.Gen	CRUAS _ Unit 2 (900MW) 400 kV	02/12/2017	30/03/2018		
RTE	Nuc.Gen	FESSENHEIM _ Unit 2 (900MW) 400 kV	01/01/2017	15/03/2018		
RTE	Nuc.Gen	PALUEL _ Unit 2 (1300MW) 400 kV	01/08/2015	15/04/2018		
S.GRID	Line	LIMMERN _ TIERFEHD 1 400 kV	28/01/2017	31/07/2018		
S.GRID	Nuc.Gen	BEZNAU _ BEZNAU G11 220 kV	13/03/2015	28/02/2018	182 MW	
S.GRID	Nuc.Gen	BEZNAU _ BEZNAU G12 220 kV	13/03/2015	28/02/2018	182 MW	
TENNET DE	Line	BORKEN _ BERGHAUSEN 1 400 kV	09/01/2018	09/01/2018		
TENNET DE	Line	TWISTETAL _ BORKEN 3 400 kV	16/05/2017	11/10/2018		
TENNET DE	Line	WURGASSEN _ GROHNDE 2 400 kV	08/01/2018	12/01/2018		
TENNET NL	Line	HENGEL _ ZWOLLE WT 400 kV	08/01/2018	12/01/2018		
TERNA	Line	PIAN CAMUNO _ S.FIORANO 358 400 kV	05/01/2018	31/01/2018	Forced outage	
TransnetBW	Line	DAXLANDEN _ PHILIPPSBURG GE 400 kV	08/01/2018	12/01/2018		
TransnetBW	Line	DAXLANDEN _ PHILIPPSBURG RT 400 kV	09/01/2018	12/01/2018		
TransnetBW	Line	GOLDSHOFE _ KUPFERZELL GN 400 kV	03/01/2018	10/01/2018		

Exchange program forecasts





ELIA expected flows & PSTs tap position

		Node 1	Node 2	Order	00:30	03:30	07:30	10:30	12:30	14:30	16:30	17:30	19:30	21:30	22:30	23:30
BE	FR	ACHENE	LONNY	380.19	173	-395	80	222	114	-123	-280	-140	387	156	158	283
BE	FR	AUBANGE	MONT ST MARTIN	220.51	13	-151	-70	-39	-75	-154	-172	-119	-2	-49	-32	-4
BE	FR	AUBANGE	MOULAIN	220.51	1	-155	-75	-50	-88	-159	-178	-130	-20	-57	-43	-13
BE	FR	AVELGEM	AVELIN	380.80	-85	-769	-58	166	76	-352	-614	-554	387	-45	-110	-24
BE	FR	AVELGEM	MASTAING	380.79	-191	-458	-263	-185	-234	-406	-522	-509	-99	-262	-295	-234
BE	FR	MONCEAU	CHOOZ	220.48	-119	-205	-99	-52	-64	-108	-144	-148	-34	-187	-191	-162
BE	NL	VAN EYCK 1	MAASBRACHT	380.27	-514	-135	-328	-345	-344	-205	-84	-157	-510	-545	-583	-631
BE	NL	VAN EYCK 2	MAASBRACHT	380.28	-186	304	100	147	97	338	558	596	-136	-191	-234	-343
BE	NL	ZANDVLIET	BORSSELE	380.29	-472	-128	-752	-731	-742	-640	-527	-570	-974	-746	-733	-758
BE	NL	ZANDVLIET	GEERTRUIDENBERG	380.30	-362	303	-175	-140	-149	62	237	159	-514	-501	-500	-564
BE	LU	BELVAL	SCHIFFLANGE	220.511	-105	38	10	-26	-30	52	91	58	-68	-89	-105	-160

BE	FR	TOTAL		-208	-2133	-485	62	-271	-1302	-1910	-1600	619	-444	-513	-154	
BE	NL	TOTAL		-1534	344	-1155	-1069	-1138	-445	184	28	-2134	-1983	-2050	-2296	
BE	LU	TOTAL		-105	38	10	-26	-30	52	91	58	-68	-89	-105	-160	
TOTAL BELGIAN IMPORT/EXPORT					-1847	-1751	-1630	-1033	-1439	-1695	-1635	-1514	-1583	-2516	-2668	-2610



PST taps in DACF	Zandvliet 1	12	12	12	12	12	12	12	12	12	12	12	12	12	12
	Zandvliet 2	12	12	12	12	12	12	12	12	12	12	12	12	12	12
	Van Eyck 1	12	12	12	12	12	12	12	12	12	12	12	12	12	12
	Van Eyck 2	12	12	12	12	12	12	12	12	12	12	12	12	12	12
	Average	12	12	12	12	12	12	12	12	12	12	12	12	12	12

CREOS PST in DACF	Schiffange	17	17	17	17	17	17	17	17	17	17	17	17	17	17
-------------------	------------	----	----	----	----	----	----	----	----	----	----	----	----	----	----

Proposal for real time after D-1 studies


Timestamps	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
PSTs																								
Zandvliet PST 1	[1;35]	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
Zandvliet PST 2	[1;35]	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
Van Eyck PST 1	[1;35]	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
Van Eyck PST 2	[1;35]	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12	12
Schiffange PST 1	[1;35]	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17

CEE Renewable Power Generation & Forecast







The charts above show the wind and solar generation forecasts for the TSOs in CEE (most significant) from D+1 until D-2 and the realised generation in Germany in real time. Source: Meteologica and 50HzT (RT)

50HzT Preventive Redispatch



CWE, CSE & SWE Renewable Power Forecast (D-1 and D-2)



The charts above show the latest wind and solar generation forecasts for D-1 and D-2 for all the European TSOs in CWE, CSE and SWE with a significant installed capacity. Source: Meteologica

RTE flows on cross-border lines

With last provided tap position on Belgian PSTs:

				03:30			07:30			10:30			12:30		
		Node 1	Node 2	DACF	Merge	Delta	DACF	Merge	Delta	DACF	Merge	Delta	DACF	Merge	Delta
FR	BE	LONNY	ACHENE	448	395	-53	22	-80	-102	-163	-222	-59	-60	-114	-54
FR	BE	MONT ST MARTIN	AUBANGE	97	151	54	49	70	21	38	39	1	44	75	31
FR	BE	MOULAIN	AUBANGE	104	155	51	55	75	20	49	50	1	58	88	30
FR	BE	AVELIN	AVELGEM	924	769	-155	307	58	-249	13	-166	-179	186	-76	-262
FR	BE	MASTAING	AVELGEM	577	458	-119	432	263	-169	301	185	-116	408	234	-174
FR	BE	CHOOZ	MONCEAU	206	205	-1	191	99	-92	146	52	-94	190	64	-126
FR	DE	MUHLBACH	EICHSTETTEN	483	558	75	361	514	153	256	426	170	225	429	204
FR	DE	VOGELGRUN	EICHSTETTEN	7	61	54	-31	52	83	-28	26	54	-2	27	29
FR	DE	ST AVOLD	ENSDORF	0	0	0	0	0	0	0	0	0	0	0	0
FR	DE	VIGY	ENSDORF 1	412	480	68	142	306	164	204	223	19	265	253	-12
FR	DE	VIGY	ENSDORF 2	197	284	87	202	397	195	299	335	36	370	386	16

				17:30			19:30			23:30		
		Node 1	Node 2	DACF	Merge	Delta	DACF	Merge	Delta	DACF	Merge	Delta
FR	BE	LONNY	ACHENE	357	140	-217	-195	-387	-192	-205	-283	-78
FR	BE	MONT ST MARTIN	AUBANGE	143	119	-24	34	2	-32	42	4	-38
FR	BE	MOULAIN	AUBANGE	153	130	-23	50	20	-30	48	13	-35
FR	BE	AVELIN	AVELGEM	663	554	-109	-322	-387	-65	205	24	-181
FR	BE	MASTAING	AVELGEM	584	509	-75	137	99	-38	361	234	-127
FR	BE	CHOOZ	MONCEAU	227	148	-79	134	34	-100	181	162	-19
FR	DE	MUHLBACH	EICHSTETTEN	393	547	154	-29	173	202	-168	27	195
FR	DE	VOGELGRUN	EICHSTETTEN	54	80	26	-76	1	77	-72	2	74
FR	DE	ST AVOLD	ENSDORF	0	0	0	0	0	0	0	0	0
FR	DE	VIGY	ENSDORF 1	646	610	-36	-53	24	77	-237	-99	138
FR	DE	VIGY	ENSDORF 2	790	785	-5	-30	88	118	-343	-175	168


				03:30			07:30			10:30			12:30		
		Node 1	Node 2	DACF	Merge	Delta	DACF	Merge	Delta	DACF	Merge	Delta	DACF	Merge	Delta
FR	CH	SIERENTZ	ASPHARD	452	454	2	335	355	20	253	310	57	206	326	120
FR	CH	MAMBELIN	BASSEECOURT	3	45	42	-153	-127	26	-212	-161	51	-186	-112	74
FR	CH	SIERENTZ	BASSEECOURT	344	369	25	426	415	-11	388	429	41	402	419	17
FR	CH	BOIS TOLLOT	ROMANEL	250	308	58	146	205	59	97	172	75	150	217	67
FR	CH	SIERENTZ	LAUFENBURG	416	385	-31	248	201	-47	227	170	-57	138	211	73
FR	CH	CORNIER	RIDDES	21	75	54	5	62	57	-29	34	63	-9	55	64
FR	CH	CORNIER	ST TRIPHON	6	73	67	-13	60	73	-72	36	108	-52	56	108
FR	CH	PRESSY	VALLORCINES	-69	16	85	-62	18	80	-135	-30	105	-108	-5	103
FR	CH	BOIS TOLLOT	VERBOIS	158	134	-24	192	229	37	156	239	83	210	257	47
FR	CH	GENISSIAT	VERBOIS	168	162	-6	144	175	31	121	180	59	146	184	38
FR	CH	GENISSIAT	VERBOIS	168	162	-6	144	175	31	121	180	59	146	184	38
FR	IT	ALBERTVILLE	RONDISSONE	1125	938	-187	1119	900	-219	1175	866	-309	1133	879	-254
FR	IT	ALBERTVILLE	RONDISSONE	1125	895	-230	1119	858	-261	1175	823	-352	1134	851	-283
FR	IT	MENTON	CAMPOROSSO	253	601	348	149	493	344	141	666	525	148	590	442
FR	IT	VILLARODIN	VENAUS	342	242	-100	480	406	-74	580	376	-204	540	344	-196

				17:30			19:30			23:30		
		Node 1	Node 2	DACF	Merge	Delta	DACF	Merge	Delta	DACF	Merge	Delta
FR	CH	SIERENTZ	ASPHARD	190	376	186	70	197	127	48	116	68
FR	CH	MAMBELIN	BASSEECOURT	-126	-23	103	-328	-263	65	-304	-254	50
FR	CH	SIERENTZ	BASSEECOURT	286	324	38	426	389	-37	434	411	-23
FR	CH	BOIS TOLLOT	ROMANEL	163	167	4	33	20	-13	49	24	-25
FR	CH	SIERENTZ	LAUFENBURG	56	173	117	-11	66	77	75	79	4
FR	CH	CORNIER	RIDDES	-8	38	46	-65	-14	51	-68	-35	33
FR	CH	CORNIER	ST TRIPHON	-37	31	68	-98	-31	67	-98	-37	61
FR	CH	PRESSY	VALLORCINES	-91	-47	44	-155	-92	63	-181	-124	57
FR	CH	BOIS TOLLOT	VERBOIS	214	217	3	168	199	31	153	215	62
FR	CH	GENISSIAT	VERBOIS	158	158	0	126	135	9	86	112	26
FR	CH	GENISSIAT	VERBOIS	158	158	0	126	135	9	86	112	26
FR	IT	ALBERTVILLE	RONDISSONE	1177	991	-186	1017	758	-259	765	565	-200
FR	IT	ALBERTVILLE	RONDISSONE	1178	950	-228	1018	729	-289	766	533	-233
FR	IT	MENTON	CAMPOROSSO	157	529	372	145	488	343	156	375	219
FR	IT	VILLARODIN	VENAUS	563	492	-71	479	346	-133	80	20	-60

N state flows at 10:30 and 19:30

The I_{max} and load values in the table below are extracted from the merged TSOs' DACF.

TSO	Line (380 kV)	10:30		19:30	
		I _{max} (A)	% of I _{max}	I _{max} (A)	% of I _{max}
ELIA	Champion - Gramme (32)	2448	37	2448	38
	Doel - Mercator (51)	2239	36	2239	46
	Doel - Mercator (52)	2239	36	2239	46
	Doel - Mercator (54)	2448	36	2448	46
	Doel - Zandvliet (25)	2349	17	2349	35
	Mercator - Horta (73)	2569	28	2569	46
	Courcelles - Gramme (31)	2330	39	2349	40
	Mercator - Rodenhuize/Horta (74)	2342	31	2349	52
RTE	Attaques - Warande 2	3780	56	3780	57
	Avelin - Gavrelle	2622	40	2622	52
	Avelin - Warande	3458	10	3458	6
	Lonny - Seuil	4149	23	4149	26
	Mandarins - Warande 1	3780	53	3780	53
	Muhlbach - Scheer	2598	32	2598	25
	Revigny - Vigy	2596	40	2596	44
	Warande - Weppes	3458	16	3458	12



X < 50 % of I_{max}




50 ≤ X < 75 % of I_{max}



X ≥ 75 % of I_{max}

TSO	Voltage	Line (380 kV)	10:30		19:30	
			I _{max} (A)	% of I _{max}	I _{max} (A)	% of I _{max}
50 HzT	380 kV	Eisenach - Mecklar (450-2)	2520	13	2520	19
		Hagenwerder - Mikulowa (567)	2520	11	2520	9
		Hagenwerder - Mikulowa (568)	2520	11	2520	9
		Remptendorf - Redwitz (413)	3440	36	3485	39
		Remptendorf - Redwitz (414)	3440	36	3485	39
		Röhrsdorf - Hradec (445)	2520	19	2520	15
		Röhrsdorf - Hradec (446)	2520	19	2520	15
		Vieselbach - Mecklar (449-1)	2520	17	2520	23
		Wolmirstedt - Helmstedt (491-1)	2400	6	2400	6
		Wolmirstedt - Helmstedt (492-2)	2400	6	2400	6
	220 kV	Vierraden - Krajnik (507)	1361	0	1352	0
		Vierraden - Krajnik (508)	1361	0	1352	0



X < 50 % of I_{max}



50 ≤ X < 75 % of I_{max}



X ≥ 75 % of I_{max}

Special topologies at 10:30 and 19:30

Nodes in North area				
			10:30	19:30
380 kV	Elia	Doel	1	1
		Avelgem	1	1
	Rte	Warande	1	1
		Cergy	2	2
		Terrier	1	1
		Plessis Gassot	1	1
		Mery/Seine	2	2
		Muhlbach	1	1
		Vigy	2	2
	Transnet bw	Eichstetten	1	1
	Amprion	Uchtelfangen	1	1
	Tennet DE	Redwitz	1	1
	50 HzT	Remptendorf	1	1
		Wolmirstedt	1	1
	CEPS	Hradec Vychod	1	1
220 kV	50 HzT	Pasewalk	1	1

North analyses results

Security analyses have been performed for 24 timestamps.

All remedial actions have been agreed with concerned TSO during the day ahead process.

Constraints on Elia, RTE (North) and 50HzT 400kV grids and tie-lines

TSO	Validity	Contingency				Constraint					Timestamps of max
		U (kV)	Substation 1	Substation 2	Code	Overload	U (kV)	Substation 1	Substation 2	Code	

Constraints greater than 100% on NL + Amprion 400kV grids and greater than 120% on DE, CZ, PL and SK 400kV grids

TSO	Validity	Contingency				Constraint					Timestamps of max
		U (kV)	Substation 1	Substation 2	Code	Overload	U (kV)	Substation 1	Substation 2	Code	

Constraints on ELIA 220/150kV grid at 10:30

Contingency				Constraint					Comments
U (kV)	Substation 1	Substation 2	Code	Overload	U (kV)	Substation 1	Substation 2	Code	
400	Avelgem	Busbar	1	105%	150	Koksijde	Slykens		08:00 - 12:00
400	Avelgem	Busbar	2	130%	150	Langerbrugge	Nieuwvaart		07:00 - 15:00
400	Mercator	Busbar	2A	125%	150	Lillo	Zandvliet		06:00 - 24:00

50HzT DC loopflows sensitivity

Vierraden-Krajnik 220kV axis in long term outage till 2018.

South analyses results

Security analyses have been performed for these 2 timestamps:

- Off-peak period (23:00 – 07:00): **03:30**
- Peak period (07:00 – 23:00): **11:30**

Adaptations made on merged DACFs:

Off-peak:

- SI → IT physical flow adapted to the target flow : **1000 MW** , Divaca PST forced to tap -26
- Mendrisio-Cagno flow adapted to the schedule : **150 MW**
- PST of Lienz adapted to **150 MW**
- PST of Camporosso adapted to **150 MW**

Peak:

- SI → IT physical flow adapted to the target flow : **800 MW** , Divaca PST forced to tap -26
- Mendrisio-Cagno flow adapted to the schedule : **200 MW**
- PST of Lienz adapted to **150 MW**
- PST of Camporosso adapted to **150 MW**

Special topologies




Nodes in South area				
			Off Peak	Peak
380 kV	Swissgrid	Sils	1	1
		Robbia	2	2
	Rte	Génissiat	1	1
		Albertville	1	1
		Grande Ile	2	2
	Terna	Turbigo	1	1
		Baggio	1	1
		Bovisio	1	2
		Ostiglia	1	1

N state flows Off-Peak & Peak

The I_{max} and load values in the table below are extracted from the **adapted** merged TSOs' DACF.

TSO	Voltage	Line (380 kV)	Off Peak		Peak	
			I _{max} (A)	% of I _{max}	I _{max} (A)	% of I _{max}
Terna	380 kV	Albertville - Rondissone 1	2370	63	2370	62
		Albertville - Rondissone 2	2370	61	2370	60
		Bulciago - Soazza	2300	39	2300	58
		Cagno - Mendrisio	855	29	855	42
		Musignano - Lavorgo	2270	53	2270	71
		Redipuglia - Divaca	2700	41	2700	33
		Robbia - San Fiorano	2530	36	2530	61
		Robbia - Gorlago	2530	45	2530	69
		Venaus - Villarodin	2715	19	2715	27
	220 kV	Airolo - Ponte	900	6	900	14
		Lienz - Soverzene	750	52	750	51
		Menton - Campo Rosso	1165	29	1165	35
		Padriciano - Divaca	960	71	960	60
		Riddes - Avise	1010	32	1010	34
		Riddes - Valpelline	1010	36	1010	36
		Serra - Pallanzeno	900	30	900	40

For Terna:

	X < 50 % of I _{max}		50 ≤ X < 75 % of I _{max}		X ≥ 75 % of I _{max}
---	------------------------------	---	-----------------------------------	---	------------------------------

Sensitivity coefficients for the Pentalateral instruction

The amount of the control program curtailment on peak and off-peak can be calculated thanks to the sensitivities in the table below:

		FR → IT	CH → IT	AT → IT	SI → IT
Off Peak	Initial physical flows on adapted base case	2453	3530	153	1054
	Compensation ratio (calculated from NTC)	40%	49%	4%	8%
	Pentalateral impact on physical flows	-24%	-60%	-3%	-13%
Peak	Initial physical flows on adapted base case	2584	4963	152	838
	Compensation ratio (calculated from NTC)	37%	50%	4%	9%
	Pentalateral impact on physical flows	-26%	-56%	-4%	-15%

OFF PEAK

Off Peak constraints on APG, Eles, RTE (South), Swissgrid and Terna 400kV grids and tie-lines

	TSO	Contingency				Constraint				
		U (kV)	Substation 1	Substation 2	Code	Overload	U (kV)	Substation 1	Substation 2	Code
Off Peak	RTE	380	Albertville	Grande Ile	N-K	96% 1'	380	Albertville	Grande Ile	remaining
		Preventive action : 2 nodes in Albertville => 80% remaining.								
	RTE	380	Alberville	Busbar	1A	98% 1'	220	Alberville	Longefan	
		Preventive action : Increase 3 taps on La Praz PST => 105% 10' remaining. Curative action : open the 220kV line Saussaz - Vieux moulin => 85% remaining.								

PEAK

Peak constraints on APG, Eles, RTE (South), Swissgrid and Terna 400kV grids and tie-lines

	TSO	Contingency				Constraint				
		U (kV)	Substation 1	Substation 2	Code	Overload	U (kV)	Substation 1	Substation 2	Code
Peak	RTE	380	Albertville	Grande Ile	N-K	96% 10'	380	Albertville	Grande Ile	remaining
		Curative action : 2 nodes in Albertville => 77% remaining.								

Final PSTs settings

The tables below present the tap positions and the physical flows on different PSTs with the adaptations described at the top of the page (IT-SI target flow...) and preventive actions (before Pentalateral reduction).

PST	Off Peak	
	Tap position	Physical flow to Italy (MW)
La Praz (1/33)	17	339
Rondissone 1 (1/33)	29	958
Rondissone 2 (1/33)	32	998
Camporosso (-32/32)	5	137
Lienz (-32/32)	-7	155
Padriciano (1/33)	33	275
Divaca (-32/32 each)	-26	782

PST	Peak	
	Tap position	Physical flow to Italy (MW)
La Praz (1/33)	17	498
Rondissone 1 (1/33)	30	943
Rondissone 2 (1/33)	32	969
Camporosso (-32/32)	7	155
Lienz (-32/32)	-17	154
Padriciano (1/33)	33	229
Divaca (-32/32 each)	-26	610

Conclusion

CWE: No critical constraint detected.

CEE: No critical constraint detected.

CSE: No critical constraint detected.