

ROUTINE TEST RECORD FOR BELT SCALE

JOB No. : BS-ORIGINAL-TEMPLATE-FINAL
ABEL STEEL CORP
CAPACITY : 1000 TPH
BC-01

CUSTOMER NAME:

CONVEYOR NO:

BELT SCALE	LOAD CELL	SPEED SENSOR	JUNCTION BOX
Model No: BS-10000 Serial No: BS-SN-001 REMOTE: Model No: RM-100 Serial No: RM-SN-001	Model No: LC-500 Serial No: 1) LC-01 2) LC-02 3) LC-03 4) LC-04	Sensor: Model No: SS-100 Serial No: TS-SN-01	Model No: JB-101 Serial No: JB-SN-101 Model No: JB-102 Serial No: JB-SN-102

Resolution: L:

0.1 kg/m S: 0.01 m/s r: 1 tph t: 0.1 tonnes

Check for short between Line & Neutral, Neutral & Earth, Line & Earth : OK (100M Ohm)

SL. No.	Test Performed	Specified	Actual
1.	Input Supply Voltage (+/-10%)	230V	230V
2.	Derived DC Voltages (+/-5%)	24V	24V
3.	Display and Keypad Functionality	Display OK	Display OK
4.	Belt Load as specified in G.A. or MPL	27.78	27.78 Kg/m
5.	Belt Speed as specified in G.A. or MPL	2.50	2.50 m/s
6.	Number of PF Contacts	4	4
7.	Communication Output (Specify)	RS-485	RS-485
8.	Analog Output (Specify number)	4-20mA	4-20mA
9.	Wiring, TB and Component Layout	Wiring OK	Wiring OK

Resolution L: 0.1 S: 0.01 r: 1 t: 0.1

Load on Load cell Kg / mV	Belt load Kg/m	Speed in m/s	Rate in tph	Totalizer in Tones (6 min)	O/p current mA AO1	O/p current mA AO2
10	2.5	2.50	10	1.5	2.00	2.00
20	5.0	2.50	20	3.0	4.00	4.00
30	7.5	2.50	30	4.5	6.00	6.00
40	10.0	2.50	40	6.0	8.00	8.00
50	12.5	2.50	50	7.5	10.00	10.00
60	15.0	2.50	60	9.0	12.00	12.00
70	17.5	2.50	70	10.5	14.00	14.00
80	20.0	2.50	80	12.0	16.00	16.00
90	22.5	2.50	90	13.5	18.00	18.00
100	25.0	2.50	100	15.0	20.00	20.00
110	27.5	2.50	110	16.5	22.00	22.00

Instrument Used: Fluke 87V Multimeter
Tested by: System Admin
PDN
Date: 14-Sep-2026

Approved by: HOD-

(HOD - PDN)