

ROUTINE TEST RECORD FOR BELT SCALE

JOB No. : BS-RESTART-TEST-001
STEEL INC
CAPACITY : 1200 TPH
BC-05

CUSTOMER NAME: GLOBAL

CONVEYOR NO:

BELT SCALE	LOAD CELL	SPEED SENSOR	JUNCTION BOX
Model No: BS-1200 Serial No: BS-SN-999 S/W Version: 3.1.3 REMOTE: Model No: RM-200 Serial No: RM-SN-200	Model No: LC-750 Serial No: 1) LC-750-1 2) LC-750-2 3) LC-750-3 4) LC-750-4	Model No: SS-200 Serial No: SS-SN-200	Model No. : JB-A1 Serial No. : JB-SN-A1
		ANGLE SENSOR	Model No. : JB-A2 Serial No. : JB-SN-A2
		Model No: AS-500 Serial No: AS-SN-500	Model No. : JB-A3 Serial No. : JB-SN-A3

Check for short between Line & Neutral, Neutral & Earth, Line & Earth : OK (100M Ohm)

SL. No.	Test Performed	Specified	Actual
1.	Input Supply Voltage (+/-10%)	230V	230V
2.	Derived DC Voltages (+/-5%)	24V	24V
3.	Display and Keypad Functionality	Display OK	Display OK
4.	Belt Load as specified in G.A. or MPL	27.78	27.78 Kg/m
5.	Belt Speed as specified in G.A. or MPL	2.50	2.50 m/s
6.	Number of PF Contacts	4	4
7.	Communication Output (Specify)	RS-485	RS-485
8.	Analog Output (Specify number)	4-20mA	4-20mA
9.	Wiring, TB and Component Layout	Wiring OK	Wiring OK

Resolution: L: 0.1 kg/m S: 0.01 m/s r: 1 tph t: 0.1 tonnes

Measurement to be done from 0 to 110% of the Belt Scale capacity.

Load on Load cell Kg/Mv	Belt load Kg/m	Speed in m/s	Rate in tph	Totalizer in Tones (6 min)	O/p current mA
10	2.5	2.50	10	1.5	2.00
20	5.0	2.50	20	3.0	4.00
30	7.5	2.50	30	4.5	6.00
40	10.0	2.50	40	6.0	8.00
50	12.5	2.50	50	7.5	10.00
60	15.0	2.50	60	9.0	12.00
70	17.5	2.50	70	10.5	14.00
80	20.0	2.50	80	12.0	16.00
90	22.5	2.50	90	13.5	18.00
100	25.0	2.50	100	15.0	20.00
110	27.5	2.50	110	16.5	22.00

Instrument Used: Fluke Multimeter

