

ROUTINE TEST RECORD FOR BELT SCALE

JOB No. : JOB-2026-377

Thermal

CAPACITY : 1200

CUSTOMER NAME: Adani Power

CONVEYOR NO: CV-73B

BELT SCALE	LOAD CELL	SPEED SENSOR	JUNCTION BOX
Model No: BS-MODEL-377 Serial No: SN-BS-7377 REMOTE: Model No: RM-UNIT-01 Serial No: SN-RM-5377	Model No: LC-300KG Serial No: 1) LC1-007 2) LC2-007 3) LC3-007 4) LC4-007	Sensor: Proximity Model No: TACHO-SENS-PRO Serial No: TS-8377	Model No: JBOX-IP67 Serial No: JB-SN-477 Model No: JBOX-IP67 Serial No: JB-SN-577

Check for short between Line & Neutral, Neutral & Earth, Line & Earth : OK (Checked Line/Neutral, Neutral/Earth, Line/Earth)

SL. No.	Test Performed	Specified	Actual
1.	Input Supply Voltage (+/-10%)	230V	230V
2.	Derived DC Voltages (+/-5%)	24V	24V
3.	Display and Keypad Functionality	OK	OK
4.	Belt Load as specified in G.A. or MPL	117.8 kg/m	117.8 Kg/m
5.	Belt Speed as specified in G.A. or MPL	2.83	2.83 m/s
6.	Number of PF Contacts	4	4
7.	Communication Output (Specify)	RS-485	RS-485
8.	Analog Output (Specify number)	4-20mA	4-20mA
9.	Wiring, TB and Component Layout	OK	OK

Resolution

L: 0.1

S: 0.01

r: 1

t: 0.1

Load on Load cell Kg / mV	Belt load Kg/m	Speed in m/s	Rate in tph	Totalizer in Tones (6 min)	O/p current mA AO1	O/p current mA AO2
3	0.0	2.83	0	0.0	4.00	4.00
3	23.6	2.83	240	24.0	7.20	7.20
4	47.1	2.83	480	48.0	10.40	10.40
4	70.7	2.83	720	72.0	13.60	13.60
5	94.2	2.83	960	96.0	16.80	16.80
5	117.8	2.83	1200	120.0	20.00	20.00

Instrument Used: Fluke 87V Digital Multimeter & 50kg Calibrated Class F Weights

Tested by: A

Date: 14-Sep-2026

Approved by: HOD-PDN

(HOD - PDN)