

**ROUTINE TEST RECORD FOR LOAD INDICATOR / DIGITAL INDICATOR / TANK /
HOPPER / SILO WEIGHING SYSTEM/CRANE WEIGHING SYSTEM**

SYSTEM : DIGITAL INDICATOR

JOB No. : JOB-2026-259

CAPACITY: 1200 Kg

CUSTOMER NAME: Adani Power Thermal

TAG. NO: CV-92B

Load/Digital Indicator.	SENSOR	REMOTE (IF ANY)	JUNCTION BOX
Model No: DI-3000 Serial No: SN-DI-8821 S/W Version: v3.2.0	Model No: LC-CZ50T Serial No: 1) LC1-009 2) LC2-009 3) LC3-009 4) LC4-009	Model No: N/A Serial No: N/A	Model No: JB-8P Serial No: JB-SN-441

Check for short between Line & Neutral , Neutral & Earth , Line & Earth : Checked & found OK

SL No.	Test Performed	Specified Values	Actual Values
1.	Input Supply Voltage (+/-10%)	230V	230V
2.	Derived DC Voltages (+/-5%)	24V	24V
3.	Check for the power on display and the Keyboard function.	OK	OK
4.	Load on the Load cell as specified in G.A. or MPL	Full Capacity Span	Passed
5.	Tare weight as specified in G.A. or MPL	Zero Balance OK	Passed

Resolution: L: kg/T

Measurement to be done from 0 to 110% of the System capacity.

Load on Load cell Kg/T or mV	Measured Load kg/T (1 to 4 Load cell system)				Current output mA	Measured Load kg/T (5 to 8 Load cell system)			
	1	2	3	4		5	6	7	8
3.00	0.0	1.53	0	0.0	4.00				
3.40	43.6	1.53	240	24.0	7.20				
3.80	87.1	1.53	480	48.0	10.40				
4.20	130.7	1.53	720	72.0	13.60				
4.60	174.3	1.53	960	96.0	16.80				
5.00	217.9	1.53	1200	120.0	20.00				
60%	600	600	600	600	13.60				
70%	700	700	700	700	15.20				
80%	800	800	800	800	16.80				
90%	900	900	900	900	18.40				
100%	1000	1000	1000	1000	20.00				
110%	1100	1100	1100	1100	21.60				

**ROUTINE TEST RECORD FOR LOAD / DIGITAL INDICATOR / TANK / HOPPER / SILO
WEIGHING SYSTEM**

SL No	Test Performed	Checked: YES/NO
6.	PF/ Relay Contacts: Check for the relay change over for the set points.	Checked: YES
7.	Display Annunciation: (As per the software Details)	Checked: YES
8.	Communication: RS 232 / RS 485 / BCD / Other Communication Protocols (If any specify) The RS232 / RS485 to be checked with interfacing to PC	Checked: YES
9.	Any other parameters (If Any)	N/A
10.	Rating of the fuse used in the system:	2A Fast Blow

REMARKS (If ANY): - Calibration completed within acceptable industrial limits.

	LC 1	LC 2	LC 3	LC 4
SPAN	10.00	10.00	10.00	10.00
TARE	0.00	0.00	0.00	0.00
EXC V	10.0V	10.0V	10.0V	10.0V

Instrument Used: Fluke 87

Tested by: A

Date: 16-Sep-2026

Approved by: HOD-PDN

(HOD - PDN)