

Test Report for Miscellaneous items: Production Systems

Job No: JOB-2026-908

Model No: CCB-200

Customer: ADANI POWER

Sl. No: SN-CCB-88

Item Description: Custom Controller Board Qty: 1 Nos

Test Readings and Result:

Input Voltage : 24 VDC +/- 5%

Current Consumption : 150 mA

Relay Contact Output : Checked & Energized OK

RS485 Modbus RTU : Communicating at 9600 baud

Tested by: Tester E

Approved by: HOD-PDN

Date: 18-Sep-2026

(HOD-PDN)