

ROUTINE TEST RECORD FOR WEIGH FEEDER/SCREW FEEDER

JOB No. :
CAPACITY :

TPH

CUSTOMER:
MATERIAL :

WEIGH FEEDER	CONTROLLER	LOADCELL	TACHO / PROXIMITY	JUNCTION BOX
Model No. Serial No. <u>LOCAL PANEL/PUSH BUTTON STATION:</u> Model No. Serial No.	Model No. Serial No. SW version	Model No. Serial No. 1) 2) 3) 4)	AC / Pulse Model No. Serial No.	Model No. Serial No. Model No. Serial No. Model No. Serial No.

AC/DC DRIVE Details	Motor	Gearbox	RAL details
Make: Model: Serial No.: Capacity: kW	Make: Model No.: Serial No. : Rating: kW	Make: Ratio: Model No.: Serial No. :	Make: Model No. : Serial No. :
NOTE: Check for short between Line & Neutral, Neutral & Earth, Line & Earth before powering ON the system			

SL. No.	Test Performed	Specified Values	Actual Values
1.	Input Supply Voltage (+/-10%)		
2.	SMPS Output (+/-5%)		
3.	Check for the Display, Touchpad/Keypad functionality		
4.	Belt/Screw Load as specified in G.A. or MPL		kg/m
5.	Belt Speed as specified in G.A. or MPL		m/s

Resolution: Load: kg/m Speed: m/s Rate: tph totalizer: tonnes

I) Measurement to be done from 10 to 100% of the Feeder capacity unless specified in Design Document.

Belt Length /width	mm.
Actual speed (Measured with stop clock)	m/s

II). Speed calibration: Calibrate the speed by entering the actual belt speed when the Drive output is 100%.

Drive output in %	Calculated Speed m/s	Measured Speed m/s
10		
25		
50		
75		
100		

ROUTINE TEST RECORD FOR WEIGH FEEDER/SCREW FEEDER

III). Load Calibration: Weight of Calibration Chain: Kg/m

IV). VOLUMETRIC MODE:

V). GRAVIMETRIC MODE: Operating Range:

Set rate tph		Actual rate tph Min Max Avg			Load in Kg/m	Totalizer (6 min)		% Error	Current O/p mA
						Act.	Meas.		
10%									
25%									
50%									
75%									
100%									

Functionality Check a) Control Panel Mode b) Local Mode c) Remote Mode	
Check Digital Input functions	
Check the function for PF Contacts from/to Customer	
Check for the function Analog Input and outputs	
Check Communication Specify the Slave Address, Baud Rate and other Communication Parameters	

Remarks:

Instrument Used:

Tested by:
Date:

Approved by:
(HOD – PDN)