



KIRLOSKAR CHILLERS PRIVATE LIMITED
A Kirloskar Group Company

Enriching Lives

ENGINEERING BULLETIN

Subject :	Release of Cable Ratings				
Released By:	SSN	Bulletin No.:	EB/14-15/02	Date:	29 th April, 2014

We are releasing herewith Engg. Specification for Cable Ratings (ESP/14-15/01). Henceforth GA and selection software will not have the cable sizes, instead above ESP should be referred.

How to Use Cable Rating Table:

To determine the cable sizes required for particular selection, find out RLA from selection sheet and compare it with maximum allowable current given in the tables. If its lying in between two sizes, select the immediate higher size.

For example:

1. If RLA is 270 A – Copper Cable size should be 185 sq.mm X No of Runs 1
2. If RLS is 390A – Copper Cable size should be 150 sq.mm X No of Runs 2

Note that:

1. Even though Max allowable current is exactly matching with RLA, same size cable can be selected, refer above example 1.
2. One size higher option if needed can be selected but not more than that without Engg. Approval.
3. If customer is asking for cable size other than table indicates, consult engineering.