



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING BULLETIN

Subject :	Release of Rating Charts for Heat pump & Brine chillers.				
Released By:	SSN	Bulletin No.:	EB/14-15/03	Date:	05 rd May, 2014

We are releasing here with following Engg. Specifications:

1. Rating charts for Heat Pump_KWS_R134a – ESP/14-15/05
2. Rating charts for Heat Pump_KWS_R407C – ESP/14-15/06
3. Rating charts for Heat Pump_KWK_R134a – ESP/14-15/07
4. Rating Charts for Brine chiller with Economizer KWS_R134a – ESP/14-15/03
5. Rating Charts for Brine chiller with Economizer KWS_R407C – ESP/14-15/04
6. Rating Charts for Brine chiller KWS_R134a – ESP/13-14/102 – **R01**
7. Rating Charts for Brine chiller KWS_R407C – ESP/13-14/103 – **R01**

Please note following points:

1. Economizer for brine chiller is used to improve the efficiency, but there will be price adder for the same. If Economizer is not required, you can refer rating charts ESP/13-14/102 – R01 and ESP/13-14/103-R01.
2. While selecting Heat Pump and Brine chiller also refer Engg. Bulletin EB/13-14/10_Various Operating Modes of WC Chillers.
3. For Heat Pumps, Rating charts are prepared by considering condenser ΔT as 5^o C and not 4^o C.
4. AHRI Certification is not applicable for Heat Pump and Brine chiller below 0 deg C
5. As on date, we are not offering brine chiller below -10 deg C in KWK, KWI series.