



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING BULLETIN

Subject :	Minimum chilled water temperatures without brine.				
Released By:	SSN	Bulletin No.:	EB/15-16/06	Date:	20 th Oct, 15

We can now offer chillers with chilled water temperature (Evap. LWT) below 5 deg. C without considering brine solution. That means only water can be used up to following range:

For Flooded chillers : up to 3 deg. C.

For Dx-Chillers : up to 2 deg. C

For temperature requirements less than above mentioned limits, brine solution must be considered as per our existing practice.

While offering chillers with water below 5 deg. C as above, please note following points:

1. Considering water is optional, one should always offer chillers with brine for below 5 deg. C requirements as a standard practice. But if customer demands for water then we can offer up to above limits
2. Performance should be considered as same as with brine.
3. DP switch for evaporator is **MUST**.
4. The cost of the DP switch should be consider in pricing.