

ENGINEERING BULLETIN

Product Release

New software Version for
KWK-I chiller series.

Software Identification–
KWKI_XXX_1X_13.18.18
(for pCO 5+)
KWKI_XXX_2X_13.19.19
(for pCO 5+)

No: EB/20-21/001,
Date: 8th July-2020

Dear Colleague,

We hereby wish to inform you that the official release of new Software version of KWKI_XXX_1X_13.18.18 (for pCO 5+) & KWKI_XXX_2X_13.19.19 (for pCO 5+).

In this software version, we have made following changes:

- New password management like KSC software, with all functionality like KSC software.
- New IO's reading block are configured to ensure accurate reading of inputs.
- Facility to read Danfoss VFD parameters over Modbus RS-485 (Controller side J-26 fieldbus2 port is used).
- Controller will monitor VFD current and will take appropriate controlling action (load/unload/reload & hold on safety, same as our regular current safeties) to ensure VFD will not reach "current limit".
- Danfoss VFD alarms can be reset from the controller using same alarm "Reset" button in alarm view page.
- TR display functionality is added with the option to select it for display.

Software Release

New software Version for
KWK-I chiller series.

Software Identification–
KWKI_XXX_1X_13.18.18

KWKI_XXX_2X_13.19.19

- R-134aZE gas selection is provided, and all changes related to the gas has been incorporated.
- Call for service alarm reset option is provided on password page. This functionality is same as KSC chillers.