

ENGINEERING BULLETIN

Product Release

Special Brine Step
Chiller software
updates.

No: EB/22-23/02,
Date: 14th July 2022

Dear Colleague,

We hereby wish to inform you about the official release of Special Step Brine chiller series software with some up gradations.

- ✓ Pull Down Settings
- ✓ Delta-T Set points (For Dual circuit)

We have an observation that in starting condition if chiller supply temperature is too high then compressor goes to high amps and due to this compressor load-unload for few minutes,

For this we have introduced Pull down temperature set point at user level settings.



We have identified the bug and corrected this error.

Below are the program versions for modified programs.

- KWS XXX 1BE Br 13.14.14
- KWS XXX 2BE Br 13.11.11

We recommend updating the software at all existing sites where such issues are faced.