

ENGINEERING BULLETIN

Product Options

Modification in Oil Cooler Requirement for Special Brine Series with FVRL Compressor

No: EB/23-24/004,
17/01/2023

Dear Colleague,

We hereby wish to inform you about a modification in the design of our Special Brine Series with FVRL compressor.

Modification Details: Upon thorough evaluation, it has been observed that the oil cooler in the Special Brine Series with FVRL compressor is not necessary when the condenser leaving water temperature is up to 39°C.

Implications for Technical Considerations: Excluding an oil cooler in a chiller system within a specified temperature range offers several benefits. It simplifies the system design, making installation and maintenance easier while reducing the risk of component failures. Energy consumption is lowered, enhancing overall efficiency, and valuable space is saved within the system. Improved reliability and reduced downtime are additional advantages, along with environmental benefits such as lower energy usage and a smaller footprint

Conditional Requirement for Oil Cooler: It is essential to note that the oil cooler will become necessary only when the condenser leaving water temperature exceeds 39°C. In such cases, the oil cooler will play a crucial role in maintaining optimal system performance.

Implementation: This modification is effective immediately for all upcoming units in the Special Brine Series with FVRL compressor. Units already in production will be reviewed on a case-by-case basis.