



KIRLOSKAR CHILLERS PRIVATE LIMITED

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: Brine table (MEG & Propylene Glycol)		
Document No: ESP-13-14-105	Revision:R00	Date:28/09/2013

Brine Table:

ELWT in Deg C	% MEG	Flow Factor by volume, MEG	% Propylene glycol	Flow Factor by volume, PG
4 ~ 3	5	1.005	7	1.002
2 ~ 1	10	1.015	12	1.004
0 ~ (-)1	15	1.025	18	1.013
(-)2 ~ (-)5	20	1.04	25	1.03
(-)6 ~ (-)7	25	1.06	30	1.043
(-)8 ~ (-)10	30	1.08	35	1.06
(-)11 ~ (-)15	35	1.11	40	1.08
(-)16 ~ (-)20	40	1.135	45	1.103

Notes:

1. Above mentioned % in second & forth column are minimum brine % required for corresponding target leaving temperature mentioned in column one. One can use brine % greater than minimum required, but in that case corresponding flow factors should be used to calculate the evaporator flow.

SNM Prepared By	SSN Approved By
---------------------------	---------------------------