



KIRLOSKAR CHILLERS PRIVATE LIMITED

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: Fouling Correction Factor		
Document No: ESP-13-14-106	Revision:R00	Date:28/09/2013

Evaporator fouling correction factors:

Evaporator Fouling Factor		
Fouling factor ft ² hr °F/BTU	Cooling capacity correction factor	Power input correction factor
0.0001	1	1
0.00025	0.983	0.998
0.0005	0.974	0.989
0.00075	0.969	0.982
0.001	0.828	0.976
0.002	0.793	0.969

Condenser fouling correction factors:

Condenser Fouling Factor		
Fouling factor ft ² hr °F/BTU	Cooling capacity correction factor	Power input correction factor
0.00025	1	1
0.0005	0.987	1.011
0.00075	0.984	1.016
0.001	0.981	1.020
0.002	0.955	1.072

SNM Prepared By	SSN Approved By
---------------------------	---------------------------