



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: Brine Chiller Settings		
Document No: ESP-15-16-102	Revision: 01	Date: 04/01/17
Prepared By: AHW	Approved By: SSN	Sheet: 1 OF 1

Set points for Brine chiller

Ch.LWT Setpoint (Deg C)	Set points				
	Antifreeze set point (Deg C)	R-134a		R-22/R-407C	
		Low Suction Pressure (Bar)	Very Low Suction Pressure (Bar)	Low Suction Pressure (Bar)	Very Low Suction Pressure
Above 4 deg c	4.4	1.8	1.4	3.6	3.2
4	1	1.8	1.3	3.6	3.2
3	0	1.7		3.5	
2	-1	1.6		3.3	
1	-2	1.5		3.3	
0	-3	1.4		3	
-1	-4	1.3	2.8		
-2	-5	1.2	2.7		
-3	-6	1.2	2.6		
-4	-7	1.1	2.5		
-5	-8	1	0.5	2.4	1.8
-6	-9	0.9		2.3	
-7	-10	0.8		2.2	
-8	-11	0.8		2.1	
-9	-12	0.7		2	
-10	-13	0.6		1.9	
-11	-14	NOT APPLICABLE		1.7	
-12	-15			1.6	
-13	-16			1.5	
-14	-17			1.4	
-15	-18			1.3	
-16	-19			1.3	0.8
-17	-20			1.2	
-18	-21			1.1	
-19	-22			1	
-20	-23			0.9	