



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: VFD Set points for KAS/ KWS chiller		
Document No: ESP-16-17-101	Revision: R01	Date: 05/01/2018
Prepared By: RDT	Approved By: SSN	Sheet: 1 of 1

	CHILLER MODEL	KAS/KWS
ID	Name	Setup 1
0 30	Custom Readout Unit	RPM
0 31	Custom Readout Min Value	0
0 32	Custom Readout Max Value	3600
0 60	Main Menu password	2020
0 61	Access to main menu	LCP read only
0 40	[Hand on] Key on LCP	Disabled
1 03	Torque Characteristics	Compressor torque
1 20	Motor power (KW)	107
1 22	Motor Voltage	380
1 23	Motor Frequency	60
1 24	Motor Current	183 A
1 25	Motor Nominal Speed	3600
3 03	Maximum Reference	60
3 13	Reference Site	Remote
3 15	Reference 1 Source	Analog input 53
3 16	Reference 2 Source	No function
3 17	Reference 3 Source	No function
3 41	Ramp 1 Ramp Up Time	8
3 42	Ramp 1 Ramp Down Time	10
4 10	Motor Speed Direction	Clockwise
4 12	Motor Speed Low Limit [Hz]	30
4 14	Motor Speed High Limit [Hz]	60
4 16	Torque Limit Motor Mode	120
4 18	Current Limit	$\left[\frac{\text{RLA of Comp (as per SO)}}{\text{Motor Current (para. 1 24)}} \times 100 \right] + 10$



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

	CHILLER MODEL	KAS/KWS
ID	Name	Setup 1
4 19	Max Output Frequency	61
4 50	Warning Current Low	0
4 51	Warning Current High	Showing Auto
4 52	Warning Speed Low	0
4 53	Warning Speed High	3600
5 13	Terminal 29 Digital Input	No operation
5 40	Function Relay	Drive ready
5 40 1	Function Relay	Running
6 15	Terminal 53 High Ref./ Feedback Value	60
6 50	Terminal 42 Output	Motor cur. 0-I _{max}
14 25	Trip Delay at Torque Limit	25
14 26	Trip Delay at Inverter Fault	2
16 37	Inverter max current	Showing Auto
22 43	Wake-up Speed [Hz]	30

NOTE:

SET FLA IN CONTROLLER AS:-

0.87 X CURRENT (RLA of Compressor as per SO).

IF NEEDED CHANGE THE CURRENT SETPOINT IN CONTROLLER TO MATCH THE ACTUAL POWER WITH SHOP-ORDER POWER. (Not more than 3%).