



Instrument Set Point List

Sr.No.	SET POINT DESCRIPTION	UOM	SETPOINTS	AUTHORIZATION
CONTROL SETPOINTS				
1.	LWT SET POINT	°C	7.0	OPERATOR
2.	CONTROL BAND	°C	2.2	KCPL
3.	DEAD BAND	°C	0.2	
4.	COMP CUTOFF % DEMAND	%	10.0	
5.	COMP CUTOFF DELAY	Sec	60.0	
6.	NEXT COMP ON DELTA-T	°C	3.0	
CURRENT SETPOINTS				
7.	FULL LOAD CURRENT	Amp	AS PER SHOP ORDER	
8.	LOW CURRENT TRIP SETPOINT	%	0.0	
9.	INITIAL BYPASS TIME	Sec	30	
10.	ALARM DELAY WHILE RUNNING	Sec	10	
11.	HIGH CURRENT TRIP SETPOINT	%	115.0	
12.	INITIAL BYPASS TIME	Sec	300	
13.	ALARM DELAY WHILE RUNNING	Sec	15	
14.	HIGH CURRENT UNLOAD	%	101.0	
15.	HIGH CURRENT UNLOAD-HOLD	%	100.0	
16.	HIGH CURRENT LOAD-HOLD	%	99.0	
17.	HIGH CURRENT RELOAD	%	97.0	
TEMPERATURE SETPOINTS				
18.	ANTIFREEZE TRIP SETPOINT	°C	4.4	
19.	HIGH SUCT TEMP TRIP SETPOINT	°C	15.0	

KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company



Enriching Lives

Document Name : Instrument Set Point List For KCM_XXX_1X			
Document No : ESP-16-17-103		Revision : R00	Date : 20/09/2016
Prepared By : HPK	Verified By : RDT	Approved By : SSN	Sheet : 2

Instrument Set Point List

20.	INITIAL BYPASS TIME	Sec	300
21.	HIGH DISCHARGE TEMP TRIP SETPOINT	°C	75.0
22.	HIGH DISCHARGE TEMP UNLOAD	°C	5.0
23.	HIGH DISCHARGE TEMP HOLD	°C	7.0
24.	HIGH DISCHARGE TEMP RELOAD	°C	9.0
PRESSURE SETPOINTS			
25.	HIGH DISH PRESS TRIP SETPOINTS	Bar	9.0
26.	HIGH DISCH PRESS UNLOAD	Bar	1.0
27.	HIGH DISCH PRESS HOLD	Bar	1.2
28.	HIGH DISCH PRESS RELOAD	Bar	1.5
29.	LOW SUCTION PRESS TRIP SETPOINT	Bar	1.7
30.	INITIAL BYPASS TIME	Sec	30
31.	ALARM DELAY WHILE RUNNING	Sec	5
32.	LOW SUCTION PRESS UNLOAD	Bar	0.4
33.	LOW SUCTION PRESS HOLD	Bar	0.5
34.	LOW SUCTION PRESS RELOAD	Bar	0.6
35.	VERY LOW SUCTION PRESS TRIP SETPOINT	Bar	1.0
COMPRESSOR SETPOINTS			
36.	MINIMUM TIME BETWEEN STOP- START	Sec	600
37.	MINIMUM TIME BETWEEN START- START	Sec	300
38.	SAFETY HOLD TIME	Sec	30
39.	MAX PUMP DOWN TIME	Sec	60

KCPL
Authorized Personal only

KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company



Enriching Lives

Document Name : Instrument Set Point List For KCM_XXX_1X			
Document No : ESP-16-17-103		Revision : R00	Date : 20/09/2016
Prepared By : HPK	Verified By : RDT	Approved By : SSN	Sheet : 3

Instrument Set Point List

40.	STARTER DELAY	Sec		5	
TIMER SETPOINTS					
41.	POWER ON DELAY	Sec		10	
42.	TRANSITION ALARM	Sec		35	
VFD SETPOINTS					
43.	START-UP % DEMAND	%		35.0	
44.	MAX POWER DIFF_P	kW		2.0	
45.	MAX POWER DIFF_N	kW		-2.0	
46.	START-UP LOADING	PUL	PER	1.0	4
47.	NORMAL LOADING	PUL	PER	0.5	8
48.	SAFETY UNLOADING	PUL	PER	0.5	8
49.	FAST UNLOADING	PUL	PER	0.6	5
50.	DEL_IGV TO SPEED	Sec		60	
EXV SETPOINTS					
51.	DELAY COMP-EXV	Sec		5	
52.	DELAY EXV START ON SSH	Sec		60	
53.	DELAY EXV START ON DSH	Sec		900	
54.	EXV PULSE PERIOD SP	Sec		4	
55.	EXV PULSE PERIOD SSH	Sec		8	
56.	EXV PULSE PERIOD DSH	Sec		8	
57.	EXV START OPENING	%		25	
58.	EXV MIN OPENING	%		25	
59.	EXV MAX OPENING	%		70	
60.	TARGET SUCT PRESSURE SETPOINT	Bar		2.3	

KCPL
Authorized Personal only

KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company



Enriching Lives

Document Name : Instrument Set Point List For KCM_XXX_1X			
Document No : ESP-16-17-103		Revision : R00	Date : 20/09/2016
Prepared By : HPK	Verified By : RDT	Approved By : SSN	Sheet : 4

Instrument Set Point List

61.	BAND -VE	Bar	1.0
62.	PULSE MINIMUM	msec	20
63.	PULSE MAXIMUM	msec	40
64.	TARGET SUCT SUPERHEAT SETPOINT	°C	1.0
65.	BAND +VE	Bar	0.5
66.	BAND -VE	Bar	0.5
67.	PULSE MINIMUM	msec	3
68.	PULSE MAXIMUM	msec	3
69.	TARGET DISCH SUPERHEAT SETPOINT	°C	9.0
70.	BAND +VE	Bar	2.0
71.	BAND -VE	Bar	2.0
72.	PULSE MINIMUM	msec	3
73.	PULSE MAXIMUM	msec	3
74.	NEUTRAL BAND	msec	1
75.	COND REF LEVEL PULSE	Sec	10
76.	COND REF LEVEL PERIOD	Sec	6