



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: IO's list for K-W/A-K/F/3/4/S/I		
Document No: ESP-17-18-107	Revision: R00	Date: 22/12/2017
Prepared By: RDT	Approved By:	Sheet: 1 of 3

Analog Inputs	Main Board	B1	Suction Pressure Comp 1(4-20 mA)
		B2	Discharge Pressure Comp 1 (4-20 mA)
		B3	Suction Pressure Comp 2(4-20 mA)(FOR KCPL D,KW4 & KW3,Air-cooled)
		B4	Evaporator Water In Temperature
		B5	Evaporator Water Out Temperature
		B6	Discharge Pressure Comp 2 (4-20 mA)
		B7	Discharge Temperature Comp 1(HT)
		B8	Discharge Temperature Comp 2(HT)
	Exp.Board A	B1	Motor Current Comp 1(0-5 Vdc)
		B2	Motor Current Comp 2(0-5 Vdc)
		B3	Oil Pressure Comp 1 (4-20 mA)
		B4	Oil Pressure Comp 2 (4-20 mA)
	Exp.Board B	B1	Liquid Line Temperature Comp 1
		B2	Liquid Line Temperature Comp 2
		B3	Suction Temperature comp 1
		B4	Suction Temperature comp 2 (FOR KCPL D, KW4 & KW3)
	Exp.Board C	B1	Cond Water In Temperature 1/ Ambient Temp
		B2	Cond Water Out Temperature 1 (for water cooled)
		B3	Sump Oil Temperature Comp 1
		B4	Sump Oil Temperature Comp 2
	Exp.Board D	B1	Desup Water In Temperature 1
		B2	Desup Water Out Temperature 1
		B3	Cond Water In Temperature 2 (FOR WKCPL D, KW4 & KW3)
		B4	Cond Water Out Temperature 2 (FOR WKCPL D, KW4 & KW3)
	Exp.Board E	B1	Evaporator Flow
		B2	Condenser Flow 1
		B3	Condenser Flow 2
		B4	Spare



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: IO's list for K-W/A-K/F/3/4/S/I		
Document No: ESP-17-18-107	Revision: R00	Date: 22/12/2017
Prepared By: RDT	Approved By:	Sheet: 1 of 3

Digital Input	Main Board	ID1	Chiller ON/OFF Comp 1
		ID2	Voltage Protection Device1/ VFD1 Starter Fault
		ID3	Oil Level Switch Comp 1(FOR KCPL D, KWF)
		ID4	=====Spare=====
		ID5	Winding Protection Comp 1
		ID6	Transition OK Comp 1
		ID7	Chiller ON/OFF Comp 2
		ID8	Voltage Protection Device2/VFD2 Starter Fault
		ID9	Oil Level Switch Comp 2 (FOR KCPL D, KWF)
		ID10	=====Spare=====
		ID11	Winding Protection Comp 2
		ID12	Transition OK Comp 2
		ID13	Evap.Flow switch
		ID14	Condenser flow switch Comp 1 (for water cooled)
	Exp.Board A	ID1	Chiller run/stop sw
		ID2	Emergency Stop
		ID17	Condenser flow switch Comp 2 (for water cooled)
		ID18	=====Spare=====
	Exp.Board B	ID1	=====Spare=====
		ID2	=====Spare=====
		ID17	=====Spare=====
		ID18	=====Spare=====
	Exp.Board C	ID1	=====Spare=====
		ID2	=====Spare=====
		ID17	=====Spare=====
		ID18	=====Spare=====



KIRLOSKAR CHILLERS PRIVATE LIMITED

A Kirloskar Group Company

Enriching Lives

ENGINEERING SPECIFICATIONS

Document Name: IO's list for K-W/A-K/F/3/4/S/I		
Document No: ESP-17-18-107	Revision: R00	Date: 22/12/2017
Prepared By: RDT	Approved By:	Sheet: 1 of 3

Digital Output	Main Board	NO1	Loading solenoid Valve Comp 2
		NO2	Unloading solenoid Valve Comp 2
		NO3	Fast Unload Comp 2 (For 3 coil)
		NO4	Comp 1 Cond Bank 1(Fan 2&3)
		NO5	Comp 1 Cond Bank 2(Fan 4 or 4&5)
		NO6	Fast Unload Comp 1 (For 3 coil)
		NO7	Loading solenoid Valve Comp 1
		NO8	Compressor (Delta) Comp 1 /(SS)
		NO9	Compressor (Main) Comp 1
		NO10	Comp 1 Cond Bank 3(Fan 6 or 6&7)
		NO11	Compressor (Main) Comp 2
		NO12	Unloading solenoid Valve Comp 1
		NO13	Compressor (Delta) Comp 2 /(SS)
	Exp.Board A	NO1	Liquid Injection Valve Comp 1 (FOR KCPL D, KW4& KW3) (for air-cooled)
		NO2	Liquid Injection Valve Comp 2 (FOR KCPL D, KW4& KW3) (for air-cooled)
		NO3	Evap pump
		NO4	Cooling tower fan /Comp 1 Cond Bank 4(Fan 8)
	Exp.Board B	NO1	Comp 2 Cond Bank 1(Fan 6&7 or 7&8 or 8&9 or 10&11)
		NO2	Cond pump1 / Comp 2 Cond Bank 2(Fan 8&9 or 9&10 or 10&11 or 12&13)
		NO3	Cond pump2 / Comp 2 Cond Bank 3(Fan10 or 12 or 12&13 or14&15)
		NO4	Comp 2 Cond Bank 4(Fan 14 or 16)
	Exp.Board C	NO1	Economizer Sol 1 (selectable)
		NO2	Economizer Sol 2 (selectable)
		NO3	Alarm Comp 1
		NO4	Alarm Comp 2
	Exp.Board D	NO1	Fogger pump Comp 1
		NO2	Fogger pump Comp 2
		NO3	SOV Comp 1
		NO4	SOV Comp 2
Analog Outputs		Y1	EXV command Comp 1 (selectable)
		Y2	EXV command Comp 2 (selectable)
		Y3	VFD command Comp1 (selectable)
		Y4	VFD command Comp2 (selectable)