

ENGINEERING SPECIFICATIONS

Document Name: VFD Set Points- KWI With Schneider make VFD(ATV610)		Date: 20/10/2023
Document No:	ESP-20-21-003	Revision: R01 (MODBUS PARAMETERS ADDED)
Prepared By: ASP	Revised By: IGP	Approved By: SSN
		Sheet: 1 of 2
Menu	Motor Parameters	Value
7.0 My Preferences	Access Level	Expert
4.0 Complete Setting	4.1 Motor Parameters	
	Motor Standard	60 Hz NEMA
	Nominal Motor Power KW/HP	**
	Nom Motor Voltage	**
	Nom Motor Current (A)	**
	Nominal Motor Frequency (Hz)	**
	Nom Motor Speed (RPM)	**
	Motor Control Type	U/F VC Standard
	Current Limitation (A)	RLA of Comp (as per SO/Chiller nameplate) X 1.1
	Autotuning	Apply Auto Tuning
	Autotuning Status	Done
	4.2 Input/Output Menu	
	DI1 Assignment	
	DI1 High Assignment	Forward
	Ref. freq. template	Pedestal
	AI1 Config.	
	AI1 Assignment	Frequency
	AI1 Type	Vtg.
	AI1 Min Value	0
	AI1 Max Value	10
	R1 Config.	
	R1 Assignment	Operating State Fault
	R2 Config.	
	R2 Assignment	Drive Running
	4.3 Command & Ref.	
	Low Speed	22 Hz
	High Speed	50HZ
	4.4 Generic Function	
	Ramp	
	Acceleration	8 Sec
	Deceleration	7 Sec
	Auto DC injection	No
	Threshold reached	
	High Current Thd	RLA of Comp (as per SO/Chiller nameplate) X 1.05
	Low I Threshold	0.2
	Low Freq Threshold	22
	Mot Freq Thd	51
	4.6 Error/Warning	
	Out put phase loss	YES(Can Disable only for control test)
	Warn grp configuration	
	Grp. 1 def.	
	IGBT Thermal Warn	Yes
	Fan Counter Warning	Yes
	Fan Feedback Warn	Yes
	Undervoltage Warn	Yes
	Preventive UnderV	Yes
	Mot Freq High	Yes
	Mot Freq Low Thd	Yes
	Current Thd Reached	Yes
	Drv Therm reached	Yes
	Motor Therm Thd	Yes

ENGINEERING SPECIFICATIONS

Document Name: VFD Set Points- KWI With Schneider make VFD(ATV610)			Date: 20/10/2023
Document No:	ESP-20-21-003	Revision: R01 (MODBUS PARAMETERS ADDED)	
Prepared By: ASP	Revised By: IGP	Approved By: SSN	Sheet: 2 of 2
1.2 Simply Start	Nominal Motor Power KW/HP	**	
	Nom Motor Current (A)	**	
	Motor Th Current ITH	**	
	Acceleration	8 Sec	
	Deceleration	7 Sec	
	Low Speed	22 Hz	
	High Speed	50 Hz	
6.0 File Management	6.1 Transferconfig file	Copy to the Drive	
		Copy from the Drive	
7.0 My Preferences	7.2 Password		
	Password status		
	Password	202020	
	Upload Rights	Not Allowed	
	Download Rights	Not Allowed	
Modbus	Modbus address (Add)	1,2 (As per circuit number)	
	Modbus baud rate (tbr)	19K2	
	Modbus format (tFo)	8 n 1 (With Carel Controller)	
		8 e 1 (With Siemens Controller)	
NOTES			
1) FLA SETPOINT IN CONTROLLER - RLA(AS PER SO/ CHILER NAMEPLATE) X 0.87			
** 2) REFER ESP-20-21-014_MOTOR DATA FOR VFD SETPOINT			