



Document No: ESP/20-21/012				
Document Name: MCCB set points for Screw chiller				
Prep. By: DBM	Checked By: DBM	Appd. By: ASP	Date:13/11/2020	Total Pages: 01

Engineering Specification

Protection unit setting for Siemens and Schneider MCCB are as follows:

A) Siemens 3VT

Parameter	setting
Overload current (Ir)*	RLA X 1.1
Tripping delay (Tr)	M(8)
Restart function	T(t)
I(i)	a) delay = 50 ms
	b) current = refer table 1

Table 1:

Compressor motor	Setting (kA)
80	0.6
110	0.75
125	1.0
160	1.0
210	1.6
240	2.0

A) Schneider LV5

MCCB Rating (A)	Setting (A)
150	1350
220	1350
320	1920
500	3000

*Note: Set Ir to nearest matching value on trip unit