

ENGINEERING SPECIFICATIONS

Document Name: Setpoint list for KAC Scroll Chiller		
Document No: ESP-20-21-014	Revision: R00	Date: 25/12/2020
Prepared By: CGH	Approved By: RDT	Sheet: 1

Name	Proposed Setting (Engg.)	Factory Setting	Field Setting
			(Service Engg.)
Main Menu			
B. Setpoint			
Chiller Cooling Setpoint	7.0 °C		
Differential	0.4 °C		
Delta T SP	0.0 °C		
H. Manufacturer			
a. Configuration			
Initial Start Delay Compressor	10 Sec		
Refrigerant Type	R410A		
Reg. Type	PROPORTIONAL		
Cooling Mode – Differential	0.4 °C		
Cooling Mode – Dead Band	0.2 °C		
Setpoint Limit Min/Max	05/15 °C		
Time Delay COMP 1 & COMP 2 – Load Up	60 Sec		
Time Delay COMP 1 & COMP 2 – Load Down	30 Sec		
Comp 1 Low Pressure Alarm -- Setpoint	5.0 Bar		
Comp 1 Low Pressure Alarm -- Differential	1.0 Bar		
Comp 2 Low Pressure Alarm -- Setpoint	5.0 Bar		
Comp 2 Low Pressure Alarm -- Differential	1.0 Bar		
Comp 1 & Comp 2 Low Pressure Alarm Delay -- Startup	30 Sec		
Comp 1 & Comp 2 Low Pressure Alarm Delay -- Running	5 Sec		
Comp 1 High Pressure Alarm -- Setpoint	38 Bar		
Comp 1 High Pressure Alarm -- Differential	1.0 Bar		
Comp 2 High Pressure Alarm -- Setpoint	38 Bar		
Comp 2 High Pressure Alarm -- Differential	1.0 Bar		
Comp 1 Disch Temp Alarm -- Setpoint	100.0		
Comp 1 Disch Temp Alarm -- Delay	10 Sec		
Evap. Antifreeze Alarm -- Threshold	3.0 °C		
Evap. Antifreeze Alarm -- Differential	1.0 °C		
Comp 2 Disch Temp Alarm -- Setpoint	100.0		
Comp 2 Disch Temp Alarm -- Delay	10 Sec		
Comp 1 Low Diff. Press. Alarm -- Threshold	6.3 Bar		
Comp 1 Low Diff. Press. Alarm -- Differential	1.0 Bar		
Comp 1 Diff Pressure Alarm Delay -- Startup	120 Sec		
Comp 1 Diff Pressure Alarm Delay -- Running	5 Sec		
Comp 2 Low Diff. Press. Alarm -- Threshold	6.3 Bar		
Comp 2 Low Diff. Press. Alarm -- Differential	1.0 Bar		
Comp 2 Diff Pressure Alarm Delay -- Startup	120 Sec		
Comp 2 Diff Pressure Alarm Delay -- Running	5 Sec		
Evaporator Pumps – Number of Pumps	1		

ENGINEERING SPECIFICATIONS

Document Name: Setpoint list for KAC Scroll Chiller		
Document No: ESP-20-21-014	Revision: R00	Date: 25/12/2020
Prepared By: CGH	Approved By: RDT	Sheet: 2

Warning limit max for flow lack	2 Sec		
c. Factory Setting			
Compressor Min on Time	120 Sec		
Compressor Min off Time	450 Sec		
Minimum Time Between Same Comp Start	450 Sec		