

Document Name : Danfoss MCD600 soft starter parameter list

Document No:	ESP-21-22-005	Revision:	R01	Date:	09/06/2022
Prepared By:	SRS	Revised By:	IGP	Approved By:	ASP
				Sheet:	1 of 1

Parameter group number	Parameter group name	Setting	Parameter group number	Parameter group name	Setting
1	Motor Details		6	Protection Action	
1-1	Command Source	Digital Input	6-18	Motor Thermistor	Log Only
1-2	Motor FLC	As per Motor data	7	Inputs	
1-3	Motor kW	As per Motor data	7-1	Input A Function	Motor Set select
1-4	Locked Rotor Time	As per Motor data	7-2	Input A Trip	Always Active
1-5	Locked Rotor Current	As per Motor data	7-3	Input A Trip Dly	0 sec
1-6	Motor Service Factor	As per Motor data	7-4	Input A Initial Dly	0 sec
			7-9	Remote Reset Logic	Normally Closed
2	Motor Start/stop		7-10	Input A Name	Input Trip
2-1	Start Mode	Adaptive control			
2-2	Start Ramp Time	8	8	Relay Outputs	
2-3	Initial Current	350	8-1	Relay A Function	Trip
2-4	Current Limit	350	8-2	Relay A On Delay	10 sec
2-5	Adaptv Start Profile	Constant Acceleration	8-3	Relay A Off Delay	0 sec
2-6	Kickstart Time	0	8-5	Relay B On Delay	0 sec
2-7	Kickstart Level	500	8-6	Relay B Off Delay	0 sec
2-9	Stop Mode	Coast to stop	8-7	Low Current Flag	50%
2-10	Stop Time	0	8-8	High Current FLag	100%
2-11	Adaptv Stop Profile	Constant Deceleration	8-9	Motor Temp Flag	80%
2-12	Adaptv Control Gain	75%	8-10	Main Contactor Time	400 ms
2-14	Start Delay	0	9	Analog Outputs	
2-15	Brake Torque	20%	9-1	Analog Output A	Current (%FLC)
2-16	Brake Time	1 Sec	9-2	Analog A Scale	4-20 mA
2-17	Breake Current Limit	250%	9-3	Analog A Max Adj	100%
			9-4	Analog A Min Adj	0%
4	Auto Start /Stop				
4-1	Auto Start /Stop Mode	Disable			
5	Protection Level				
5-1	Current Imbalance	30%			
5-2	Current Imbal Dly	3 Set			
5-3	Undercurrent	20%			
5-4	Undercurrent Dly	5 sec			
5-5	Inst Overcurrent	400%			
5-6	Inst Overcurrent Dly	0 Sec			
5-7	Undervoltage	375V			
5-8	Undervoltage delay	1 Sec			
5-9	Overvoltage	456V			
5-10	Overvoltage delay	1 Sec			
5-15	Excess Start Time	15			
5-18	Phase Sequence	Positive Only			
5-16	Restart Delay	10 Sec			