

Kirloskar Chillers Private Limited

A Kirloskar Group Company

Document No : ESP-22-23-002				
Document Name : LHD Setpoints for KSC chiller				
Prep. By : DBM	Checked By : DBM	Appd. By :ASP	Date : 12/04/22	Total Pages : 03

Engineering Specification

	CHILLER MODELS	KSC SITE
ID	Name	Setup
0 30	Custom Readout Unit	RPM
0 31	Custom Readout Min Value	0
0 32	Custom Readout Max Value	As per motor details
0 60	Main Menu password	2020
0 61	Access to main menu	LCP read only
0 40	[Hand on] Key on LCP	Disabled
1 03	Torque Characteristics	Variable torque
1 20	Motor power (KW)	As per motor details
1 22	Motor Voltage	400
1 23	Motor Frequency	50
1 24	Motor Current	As per motor details
1 25	Motor Nominal Speed	As per motor details
3 03	Maximum Reference	52
3 13	Reference Site	Remote
3 14	Preset Relative Reference	0
3 15	Reference 1 Source	Analog input 53
3 16	Reference 2 Source	No function
3 17	Reference 3 Source	No function
3 41	Ramp 1 Ramp Up Time	8
3 42	Ramp 1 Ramp Down Time	10
4 10	Motor Speed Direction	Clockwise
4 12	Motor Speed Low Limit [Hz]	35
4 14	Motor Speed High Limit [Hz]	52
4 16	Torque Limit Motor Mode	110
4 18	Current Limit	$\left\{ \frac{\text{RLA of comp (as per SO)} \times 100}{\text{Motor current (Para. 1 24)}} \right\} + 10$

Kirloskar Chillers Private Limited

A Kirloskar Group Company

Document No : ESP-22-23-002				
Document Name : LHD Setpoints for KSC chiller				
Prep. By : DBM	Checked By : DBM	Appd. By :ASP	Date : 12/04/22	Total Pages : 03

	CHILLER MODELS	KSC SITE
ID	Name	Setup 2
4 19	Max Output Frequency	52
4 50	Warning Current Low	0
4 51	Warning Current High	Showing Auto
4 52	Warning Speed Low	0
4 53	Warning Speed High	As per motor details
5 13	Terminal 29 Digital Input	No operation
5 40	Function Relay	Drive ready
5 40 1	Function Relay	Running
6 15	Terminal 53 High Ref./ Feedb.Value	52
6 50	Terminal 42 Output	Motor cur. 0-lmax
14 25	Trip Delay at Torque Limit	25
14 26	Trip Delay at Inverter Fault	2
16 37	Inv max current	Showing Auto
22 43	Wake-up Speed [Hz]	35

NOTE:

**SET FLA IN CONTROLLER AS
0.87 X CURRENT [Current entered in (Para.1-24 Motor current)].**

Kirloskar Chillers Private Limited

A Kirloskar Group Company

Document No : ESP-22-23-002				
Document Name : LHD Setpoints for KSC chiller				
Prep. By : DBM	Checked By : DBM	Appd. By :ASP	Date : 12/04/22	Total Pages : 03

Parameter	Value	Function
0-20	Power Factor	Display
0-21	%THDi	Display
0-22	Mains current	Display
0-23	Output current	Display
0-24	Mains frequency	Display
510	Star	Run command to AHF
511	No operation	
512	No operation	
513	No operation	
530	No operation	
531	No operation	
30010	420	Measured input voltage
30020	1000	CT primary rating
30024	L1,L2,L3	CT sequence