

Kirloskar Chillers Private Limited

A Kirloskar Group Company

Document Name	DATA SHEET FOR EVD EVALUTION LAN PROTOCOL				
Document No.	ESP-22-23-005	Revision	00	No. of sheets	Page 1 of 1
Date	10-06-2022	Prepared By	IGP	Approved By	ASP

Name	EVD EVALUTION LAN PROTOCOL
Model	EVD0000E00
Index of protector	IP20
Power supply	24 Vac (+10/-15%) 50/60 Hz to be protected by an external 2 A type T fuse. Use a dedicated class 2 transformer (max 100 VA). Lmax=5 m
Motor connection	4-wire shielded cable AWG 18/22, Lmax 10 m
Assembly	DIN rail
Connectors	plug-in, cable size 0.5 to 2.5 mm ² (12 to 20 AWG)
Dimensions	LxHxW= 70x110x60
Operating conditions	-10T60°C; <90% rH non-condensing.
Storage conditions	-20T70°C, humidity 90% rH non-condensing
Environmental pollution	2 (normal)
Resistance to heat and fire	Category D
Immunity against voltage surges	Category 1