

ENGINEERING SPECIFICATIONS

Document Name: IO list for KWS Single Circuit		
Document No: - ESP-22-23-002	Revision: R01	Date: 31/09/2023
Prepared By: PJP/SNM		Approved By: CGH

Analog Input/Output	POL688	X1	Suction Pressure Comp (4-20 mA)
		X2	Discharge Pressure Comp-1 (4-20 mA)
		X3	Oil Feed Pressure (4-20 mA)
		X4	Evaporator Water In Temperature
		X5	Evaporator Water Out Temperature
		X6	Comp Current (0-5 Vdc)
		X7	Suction Temperature
		X8	Discharge Temperature
		X9	Liquid Line Temperature
		X10	Condenser Water In Temperature
		X11	Condenser Water Out Temperature
	POL965	X1	Feed Oil Temperature
		X2	EXV-A ,Board/S2
		X3	Desuperheater In Temperature
		X4	Desuperheater Out Temperature
		X5	Oil Cooler EXV Command
		X6	Evaporator Flow Meter
		X7	Condenser Flow Meter
		X8	External Emergency Stop / Economiser Out Pressure

ENGINEERING SPECIFICATIONS

Document Name: IO list for KWS Single Circuit		
Document No: - ESP-22-23-002	Revision: R01	Date: 31/09/2023
Prepared By: PJP/SNM		Approved By: CGH

Digital Input	POL688	D1	Evaporator Flow switch
		D2	Condenser Flow Switch
		DU1	Comp ON/OFF Switch (24V AC/DC)
		DU2	Voltage Protection Device/VFD Fault (24V AC/DC)
		DL1	Transition Feedback Comp
		DL2	ATCS Pump MPU FB
	POL965	D1	=====Spare=====
		D2	=====Spare=====
		D3	=====Spare=====
		DL1	Winding Protection Comp
		DL2	=====Spare=====

Digital Output	POL688	Q1	Comp Alarm Potential Free Contact
		Q2	Delta Contactor Coil
		Q3	Main contactor coil comp
		Q4	Oil Heater Relay
		Q5	Oil Feed Solenoid
		Q6	Coil Liquid Injection Solenoid Comp
		Q7	Fast Unloading Coil Comp
		Q8	ATCS Pump FWD
		D01	Loading Coil (V1) Potential Free (Triac Output-AC 24 V...230 V)
		D02	Unloading Coil (V2) Potential Free(Triac Output-AC 24 V...230 V)
	POL965	Q1	ATCS Pump Rev
		Q2	Cooling Tower Potential Free
		Q3	Condenser Pump On/Off Potential Free
		Q4	Evaporator Pump On/Off switch
		Q5	=====Spare=====
		Q6	=====Spare=====
		Q7	=====Spare=====
		Q8	=====Spare=====
		D01	=====Spare=====
		D02	=====Spare=====

ENGINEERING SPECIFICATIONS

Document Name: IO list for KWS Single Circuit		
Document No: - ESP-22-23-002	Revision: R01	Date: 31/09/2023
Prepared By: PJP/SNM		Approved By: CGH

Controller T-IP Ethernet	PVR 7 INCH Communication Port
POL688	Main Controller
POL965	Expansion Board
Controller T-HI Port	Keypad Display