

ENGINEERING SPECIFICATIONS

Document Name: IO list for KAS Single Circuit		
Document No: - ESP-23-24-005	Revision: R01	Date: 29/08/2023
Prepared By: PJP	Approved By: CGH	
Analog Input/Output	POL688	X1 Suction Pressure Comp (4-20 mA)
		X2 Discharge Pressure Comp-1 (4-20 mA)
		X3 Oil Feed Pressure (4-20 mA)
		X4 Evaporator Water In Temperature
		X5 Evaporator Water Out Temperature
		X6 =====Spare=====
		X7 Suction Temperature
		X8 Discharge Temperature
		X9 Liquid Line Temperature
		X10 Ambient Temp
		X11 =====Spare=====
	POL985	X1 VFD command (Analog Output 0-10 Vdc)
		X2 Economiser EXV (Analog Output 0-10 Vdc)
		X3 Desuperheater Out Temperature
		X4 EXV-A ,Board/S2 (EXV Command)
		X5 EXV Board Oil Cooler/S2 command
		X6 Evaporator Flow Meter
		X7 =====Spare=====
		X8 Economiser Out Pressure
		B1 Economiser Out Temperature
		B2 Sump Oil Temperature
		B3 Desuperheater In Temperature

ENGINEERING SPECIFICATIONS

Document Name: IO list for KAS Single Circuit		
Document No: - ESP-23-24-005	Revision: R01	Date: 29/08/2023
Prepared By: PJP		Approved By: CGH

Digital Input	POL688	D1	Evaporator Flow switch (Potential Free)
		D2	=====Spare=====
		DU1	Comp ON/OFF Switch (24V AC/DC)
		DU2	Voltage Protection Device/VFD Fault (24V AC/DC)
		DL1	Transition Feedback Comp
		DL2	Winding Protection Comp
	POL985	D1	=====Spare=====
		D2	External Emergency Stop Alarm
		D3	=====Spare=====
		DL1	LP Cutout
		DL2	HP Cutout

Digital Output	POL688	Q1	Comp Alarm Potential Free Contact
		Q2	Compressor (Delta) Comp/VFD Latch Contactor Coil
		Q3	Compressor (Main) Comp
		Q4	Oil Heater Relay
		Q5	Fan 1 Motor Contactor Coil (Cond bank 1)
		Q6	Coil Liquid Injection Solenoid Comp
		Q7	Fast Unloading Coil Comp
		Q8	Fan 2/3 Motor Contactor Coil (Cond bank 2)
		D01	Loading Coil (V1) Potential Free (Triac Output-AC 24 V...230 V)
		D02	Unloading Coil (V2) Potential Free(Triac Output-AC 24 V...230 V)
	POL985	Q1	=====Spare=====
		Q2	=====Spare=====
		Q3	=====Spare=====
		Q4	Evaporator Pump On/Off switch
		Q5	Fan 4/5 Motor Contactor Coil (Cond bank 3)
		Q6	Fan 6/7 Motor Contactor Coil (Cond bank 4)
		Q7	Fan 8/9 Motor Contactor Coil (Cond bank 5)
		Q8	Motor Contactor Coil (Cond bank 6)
		D01	=====Spare=====
		D02	=====Spare=====

ENGINEERING SPECIFICATIONS

Document Name: IO list for KAS Single Circuit		
Document No: - ESP-23-24-005	Revision: R01	Date: 29/08/2023
Prepared By: PJP		Approved By: CGH

Controller T-IP Ethernet	PVR 7 INCH Communication Port
POL688	Main Controller
POL985	Expansion Board
Controller T-HI Port	Keypad Display

ENGINEERING SPECIFICATIONS

Document Name: IO list for KAS Single Circuit		
Document No: - ESP-23-24-005	Revision: R01	Date: 29/08/2023
Prepared By: PJP		Approved By: CGH