

Document Name: Chiller Design and Test Pressures

Document No.: ESP/07-08/107

Revision No.: R16

Revision Date: 13th Mar 2026

Prepared By: RMY

Checked By: MNK

Approved By: SKP

Notes:

1. For Dx evaporator pass partition side refer tube side pneumatic test pressure.
2. Unit test pressure with Relief valve = $0.8 \times \text{Design Pressure}$ (Safety valve set pressure). For LP side consider evaporator safety valve set pressure and for HP side consider condenser safety valve set pressure.
3. For Oil separator pressures, Refer respective Condenser pressures and safety valve rating.
4. Design temperature for Standard & CE (except CE Centrifugal) Evaporator & Condenser is 65°C & 100°C Respectively. Design temperature for CE Marked Centrifugal Evaporator & Condenser is 65°C & 65°C Respectively.
5. All the pressures mentioned above are applicable for standard chillers. Don't refer these in case of Heat Pumps.
6. On Refrigerant side, hydrostatic test shall not be performed. According to ASME Sec VIII Div I, UG-100, for vessels where water traces are harmful, hydrotest can be avoided. Only pneumatic test is sufficient.