

Sr. No.			Description	UOM (Wherever Applicable)	Data (Common For All Models)
A			General Points		
	1		Cooling Capacity	ton _R	Refer KCPL Chiller Selection System Software
	2		Power Consumption	kW	Refer KCPL Chiller Selection System Software
	3		Specific Power Consumption	kW/ton _R	Refer KCPL Chiller Selection System Software
	4		Co-Efficient of Performance (COP)	kW/kW	Refer KCPL Chiller Selection System Software
	5		No. of Compressors	Nos.	Contact To Engineering Team
	6		No. of Individual Refrigerant Circuits	Nos.	Contact To Engineering Team
	7		Refrigerant		
		i	Name	-	R134a
		ii	Quantity	kg	Refer KCPL Chiller Selection System Software
		iii	Technical Specifications	-	Refer ESP-18-19-003
	8		Sound Pressure Level		
		i	Noise Level	dB	Refer ESP-18-19-001
		ii	Measuring Standard	-	ANSI/AHRI Standard 575-2008
	9		Insulation Details		
		i	Material	-	Closed Cell Nitrile Foam
		ii	Insulation Thickness on Various Parts	-	For Standard Temperature Range (LWT upto -10 °C)
			Evaporator Shell	mm	32
			Evaporator Tubesheet	mm	19
			Evaporator Pass Partition Assembly	mm	19
			Evaporator Head Cover	mm	32
			Evaporator Support Plate	mm	19
			Compressor Motor Body	mm	19
			Suction Line Assembly	mm	19
			Liquid Line Assembly	mm	9
		iii	Insulation Thickness on Various Parts	-	For Brine Temperature Range (LWT below -10 °C)
			Evaporator Shell	mm	51 (32+19)
			Evaporator Tubesheet	mm	32
			Evaporator Pass Partition Assembly	mm	32
			Evaporator Head Cover	mm	51 (32+19)
			Evaporator Support Plate	mm	32
			Compressor Motor Body	mm	28 (19+9)
			Suction Line Assembly	mm	28 (19+9)
			Liquid Line Assembly	mm	19
		iv	Density	kg/m ³	76.6
		v	Thermal Conductivity	W/m.K	0.035 (at 0 °C Mean Temperature)
		vi	Standard	-	IS 14164
		vii	Adhesive	-	Blend of Synthetic Polymers and Synthetic Resin
		viii	Insulation Specifications	-	Refer ESP-18-19-004
	10		Vibration		
		i	Vibration Level	mm/sec	Less than 1.5 mm/sec
		ii	Vibration control	-	Rubber Pads (Standard) / Spring Isolators (At an Additional Cost)
		iii	Standard	-	IS 12075
	11		Painting Specification		
		i	Paint Type	-	RAL 7035
		ii	Standard	-	Coating as per KCPL Standards
	12		Overall Dimensions		
		i	Approx. Length	mm	Refer KCPL Chiller Selection System Software
		ii	Approx. Width	mm	Refer KCPL Chiller Selection System Software
		iii	Approx. Height	mm	Refer KCPL Chiller Selection System Software
	13		Space Clearances Required		
		i	Plain End Side (For Tube Cleaning)	mm	Contact To Engineering Team
		ii	All Other Sides	mm	Contact To Engineering Team
		iii	Overhead	mm	Contact To Engineering Team
	14		Weight		
		i	Approx. Shipping Weight	kg	Refer KCPL Chiller Selection System Software
		ii	Approx. Operating Weight	kg	Refer KCPL Chiller Selection System Software
	15		Cable Sizes		
		i	Aluminum Cable	-	Refer ESP-14-15-01
		ii	Copper Cable	-	Refer ESP-14-15-01
B			Compressor Details		
	1		Make	-	Kirloskar Chillers Private Limited
	2		Type / Description	-	Semi-Hermetic Twin Screw Compressor
	3		Model	-	Refer KCPL Chiller Selection System Software
	4		Drive	-	Direct Driven by Rotor Shaft
	5		Capacity Control Percentage	%	
	6		Type of Capacity Control	-	Stepless
	7		Capacity Control Mechanism	-	Slide Valve Mechanism
	8		Volumetric Ratio	-	Fixed Ratio (3.2)
	9		Contact To Engineering Team		
		i	Design Pressure	bar	30
		ii	Test Pressure (Pneumatic)	bar	33
		iii	Design Temperature	°C	120
		iv	Max. Allowable Discharge Temperature	°C	120
	10		Bearings		
		i	Types of Bearings	-	Roller Bearings - For Radial Load Angular Contact Roller Bearing - For Axial Load
		ii	Material of Construction	-	Steel
		iii	Life of Bearing	Hours	50,000
		iv	Class of Bearing	-	Proprietary Data

Sr. No.			Description	UOM (Wherever Applicable)	Data (Common For All Models)	
	11		Lubrication			
		i	Type	-	Lubrication by Differential Pressure Mechanism	
		ii	Lubricating Oil	-	Synthetic Oil	
		iii	Grade of Lubricating Oil	-	Proprietary Data	
		iv	Quantity	Liter	Refer KCPL Chiller Selection System Software	
	12		Compressor Components MOC			
		i	Screw	-	Alloy Steel	
		ii	Casing	-	Cast Iron	
		iii	Shaft	-	Alloy Steel	
		iv	Rotor	-	Aluminum Alloy	
	13		Physical Data of Compressor			
		i	Screw Construction	-	Twin Screw	
		ii	No. of Lobes Male Rotor	Nos.	5	
		iii	No. of Lobes Female Rotor	Nos.	6	
		iv	Male Rotor Diameter (mm)	mm	Proprietary Data	
		v	Female Rotor Diameter (mm)	mm	Proprietary Data	
		vi	Driving Rotor	-	Male Rotor	
	14		Oil Filter			
		i	Micron Rating	Micron	10	
		ii	Material of Construction	-	Resin Impregnated Fibres	
		iii	Quantity	Nos.	1 No. per Compressor	
	15		Copressor Isolation Type			
		i	At Suction	-	Butterfly Valve	
		ii	At Discharge	-	Shut-off Valve	
C			Compressor Motor Details			
	1		Make	-	Kirloskar Approved Vendor	
	2		Motor Type	-	Semi-Hermetic Squirrel Cage Induction Motor	
	3		Type of Duty	-	Continuous	
	4		Motor Rating	kW	Refer KCPL Chiller Selection System Software	
	5		Motor Speed (Synchronous)	RPM	3000	
	6		Ingress Protection (IP)	-	NA, Being Semi-Hermetic Type	
	7		GD ² of Rotor	-	Proprietary Data	
	8		Whether SPDP or TEFC?	-	NA, Being Semi-Hermetic Type	
	9		Power Supply Details (Standard)			
		i	Supply Voltage	V	400	
		ii	Permissible Voltage Variation	%	±10%	
		iii	Frequency	Hz	50	
		iv	Permissible Frequency Variation	%	±3%	
		v	Phase	-	3	
	10		Performance Indicators			
		i	Motor Efficiency Class	-	NA	
		ii	Motor Power	kW	Refer KCPL Chiller Selection System Software	
		iii	Motor Efficiency	-	Consult with Engineering Department on Case to Case Basis	
		iv	Power Factor	-	Consult with Engineering Department on Case to Case Basis	
		v	Class of Insulation	-	Class F	
	11		Motor Cooling			
		i	Motor Cooling Type	-	Refrigerant Cooled	
		ii	Cooling Mechanism	-	Suction Gas	
		iii	Temperature at full load	°C	10 to 15 (At Normal Condtns)	
	12		Current Details			
		ii	Rated Load Current	A	Refer KCPL Chiller Selection System Software	
		iii	Full Load Current	A	Refer KCPL Chiller Selection System Software	
		iv	Inrush/Starting Current	A	Refer KCPL Chiller Selection System Software	
		v	Locked Rotor Current	A	Refer KCPL Chiller Selection System Software	
		vi	Starting Torque	N.m	Contact To Engineering Team	
		vii	No Load Current	A	Contact To Engineering Team	
		viii	Acceleration Time to Reach Rated Speed	Sec	2 to 3	
	13		Control Settings			
		i	No. of Starts per Hour	Nos.	4	
		ii	Time Between STOP to START	Sec	300	
		iii	Time Between START to START	Sec	900	
D			Power Supply (Standard-Chiller Icomer)			
	1		Supply Voltage	V	415	
	2		Permissible Voltage Variation	%	±10%	
	3		Frequency	Hz	50	
	4		Permissible Frequency Variation	%	±3%	
	5		Phase	-	3	
	6		Control Voltage	V	230 (Standard) 110 (Special-Optional)	
	7		Supply Wire System	-	3 Phase - 4 Wire System (Standard) 3 Phase - 3 Wire System (Special-Optional)	
	8		Fault Level at Busbar	kA	As per KCPL Standard Practice	
E			Oil Separator Details			
	1		Type	-	Dome Type (Built in Compressor)	
	2		Internal Structure	-	Demister Arrangement	
	3		Method of Oil Separation	-	Differential Mass Between Oil and Gas, Impact with Surfaces, Filtering of Oil-Gas Mixture	
	4		Oil Heater Details			
		i	Make	-	Kirloskar Approved Vendor	
		ii	Quantity	Nos.	Contact To Engineering Team	
		iii	Power Supply	V	230	
		iv	Rating	W	250	

Sr. No.			Description	UOM (Wherever Applicable)	Data (Common For All Models)
F			Oil Cooler	-	If Applicable
	1		Type	-	Plate Type
	2		Quantity	Nos.	One per Compressor
	3		Heat Duty	kW	Depends on Working Conditions
	4		Method of Cooling	-	Refrigerant Cooled
	5		Material of Construction	-	Brazzed PHE, Plate Material - SS
	6		Pressure Drop		
		i	Oil Side	bar	less than 0.5
		ii	Refrigerant Side	bar	Proprietary Data
G			Evaporator Details		
	1		Model	-	Refer KCPL Chiller Selection System Software
	2		Design Code	-	As per KCPL Standards
	3		Type	-	Shell and Tube DX Design
	4		Tube Side (Fluid)	-	Refrigerant
	5		Shell Side (Fluid)	-	Chilled Water
	6		Design Parameters		
		i	Design Temperature (Refrigerant Side)	⁰ C	65
		ii	Max. Operating Pressure (Refrigerant Side)	bar	Refer ESP-07-08-107
		iii	Design Pressure (Refrigerant Side)	bar	Refer ESP-07-08-107
		iv	Test pressure (Refrigerant Side)	bar	Refer ESP-07-08-107
		v	Testing method (Refrigerant Side)	-	Refer ESP-07-08-107
		vi	No. of Passes (Refrigerant Side)	Nos.	Contact To Engineering Team
		vii	Design Temperature (Water Side)	⁰ C	65
		viii	Max. Operating Pressure (Water Side)	bar	Refer ESP-07-08-107
		ix	Design Pressure (Water Side)	bar	Refer ESP-07-08-107
		x	Test pressure (Water Side)	bar	Refer ESP-07-08-107
		xi	Testing method (Water Side)	-	Refer ESP-07-08-107
		xii	No. of Passes (Water Side)	Nos.	Single Pass
		xiii	Water Velocity	m/s	Less than 3 m/s
		xiv	Inlet Pressure	bar	Depends on Site Piping Layout (Maximum Allowable - 9.4 bar)
		xv	Evaporating Temperature	⁰ C	Consult with Engineering Department on Case to Case Basis
	7		Physical Data of Evaporator		
		i	Overall Length of Evaporator	ft	Contact To Engineering Team
		ii	Shell Diameter	inch	Contact To Engineering Team
		iii	Shell Thickness	mm	Contact To Engineering Team
		iv	Approx. Shell Length	mm	Contact To Engineering Team
		v	Material of Construction of Shell	-	Mild Steel
		vi	Material Standard of Shell	-	Refer "MOC" Sheet
		vii	Tube Type/ Nature of Tube Surface	-	Integral Helical Fins on the Outside Surface and Integral Helical Ridges on the Inside Surface
		viii	Tube Length	mm	Refer "HX Details" Sheet
		ix	Tube Diameter	mm	Refer "HX Details" Sheet
		x	Tube Thickness	mm	Refer "HX Details" Sheet
		xi	Material of Construction of Tube	-	Cu
		xii	Material Standard of Tube	-	Refer "MOC" Sheet
		xiii	Water Volume in Evaporator	Liter	Refer KCPL Chiller Selection System Software
	8		Water Box Details		
		i	Type	-	Standard - On Shell Nozzle
		ii	Material	-	Mild Steel
		iii	Standard (Material)	-	Refer "MOC" Sheet
		iv	Nozzle size	NB	Refer KCPL Chiller Selection System Software
		v	End connection	-	Standard - Victaulic Conn. (Flanged Conn. - Optional)
		vi	MOC of Water Side Gasket	-	NAM AF 120
		vii	MOC of Refrigerant Side Gasket	-	NAM AF 159
	9		Accessories Provided		
		i	Pressure Relief Valve	-	Spring Loaded (For Safety Valve Set Pressure Refer ESP)
		ii	Drain/Vent Valves	Inch	Plugged Connection Provided (1" NPT)
H			Condenser Details		
	1		Model	-	Refer KCPL Chiller Selection System Software
	2		Design Code	-	As per KCPL Standards
	3		Type	-	Shell and Tube Flooded Design
	4		Tube Side (Fluid)	-	Chilled Water
	5		Shell Side (Fluid)	-	Refrigerant
	6		Design Parameters		
		i	Design Temperature (Refrigerant Side)	⁰ C	100
		ii	Max. Operating Pressure (Refrigerant Side)	bar	Refer ESP-07-08-107
		iii	Design Pressure (Refrigerant Side)	bar	Refer ESP-07-08-107
		iv	Test pressure (Refrigerant Side)	bar	Refer ESP-07-08-107
		v	Testing method (Refrigerant Side)	-	Refer ESP-07-08-107
		vi	No. of Passes (Refrigerant Side)	Nos.	Single Pass
		vii	Design Temperature (Water Side)	⁰ C	100
		viii	Max. Operating Pressure (Water Side)	bar	Refer ESP-07-08-107
		ix	Design Pressure (Water Side)	bar	Refer ESP-07-08-107
		x	Test pressure (Water Side)	bar	Refer ESP-07-08-107
		xi	Testing method (Water Side)	-	Refer ESP-07-08-107
		xii	No. of Passes (Water Side)	Nos.	Two Pass
		xiii	Water Velocity	m/s	Less than 3 m/s
		xiv	Inlet Pressure	bar	Depends on Site Piping Layout (Maximum Allowable - 9.4 bar)
		xv	Condensing Temperature	⁰ C	Consult with Engineering Department on Case to Case Basis
	7		Physical Data of Condenser		

Sr. No.			Description	UOM (Wherever Applicable)	Data (Common For All Models)
		i	Overall Length of Condenser	ft	Contact To Engineering Team
		ii	Shell Diameter	inch	Contact To Engineering Team
		iii	Shell Thickness	mm	Contact To Engineering Team
		iv	Shell Length	mm	Contact To Engineering Team
		v	Material of Construction of Shell	-	Mild Steel
		vi	Material Standard of Shell	-	Refer "MOC" Sheet
		vii	Tube Type/ Nature of Tube Surface	-	Integral Helical Fins on the Outside Surface and Integral Helical Ridges on the Inside Surface
		viii	Tube Length	mm	Refer "HX Details" Sheet
		ix	Tube Diameter	mm	Refer "HX Details" Sheet
		x	Tube Thickness	mm	Refer "HX Details" Sheet
		xi	Material of Construction of Tube	-	Cu
		xii	Material Standard of Tube	-	Refer "MOC" Sheet
		xiii	Water Volume in Condenser	Liter	Refer KCPL Chiller Selection System Software
	8		Water Box Details		
		i	Type	-	Standard - Dish Ends (M.W.Box - Optional)
		ii	Material	-	Mild Steel
		iii	Material Standard	-	Refer "MOC" Sheet
		iv	Nozzle size	NB	Refer KCPL Chiller Selection System Software
		v	End connection	-	Standard - Victaulic Conn. (Flanged Conn. - Optional)
		vi	MOC of Water Side Gasket	-	NAM AF 120
		vii	MOC of Refrigerant Side Gasket	-	NAM AF 159
	9		Accessories Provided		
		i	Pressure Relief Valve	-	Spring Loaded (For Safety Valve Set Pressure Refer ESP)
		ii	Drain/Vent Valves	Inch	Plugged Connection Provided (3/8" NPT)
I			Suction Line		
	1		Design Code	-	ASME B31.3
	2		Isolation Valve	-	Butterfly Valve
	3		Material of Construction	-	Carbon Steel
	4		Material Standard	-	Refer "MOC" Sheet
	5		Angle Valve	-	Provided on Suction Line For Service Purpose
J			Discharge Line		
	1		Design Code	-	ASME B31.3
	2		Isolation Valve	-	Shut-off Valve
	3		Material of Construction	-	Carbon Steel
	4		Material Standard	-	Refer "MOC" Sheet
	5		Skin Type Thermowell	-	Provided on Discharge Line For Discharge Temp. Sensor
K			Liquid Line		
	1		Design Code	-	ASME B31.3
	2		Expansion Valve		
		i	Type	-	Electronic Expansion Valve
		ii	Make	-	Kirloskar Approved Vendor
		iii	Quantity	Nos.	Contact To Engineering Team
		iv	Sight Glass	-	Inbuilt
		v	Moisture Indicator	-	NA
	3		Filter Drier	-	Provided
	4		Material of Construction	-	Copper
	5		Material Standard	-	Refer "MOC" Sheet
L			Desuperheater		
	1		Type	-	Plate Type
	2		Quantity	Nos.	One per Compressor
	3		Operating Conditions		
		i	Heat Duty	kW	Depends on Working Conditions
		ii	Hot Water Inlet Temperaure	°C	Depends on Site Conditions (Max. Possible - 45)
		iii	Hot Water Outlet Temperaure	°C	Max. Possible - 50
		iv	Hot Water Flow Rate	L/s	Depends on Working Conditions
	4		Material of Construction	-	Brazzed PHE, Plate Material - SS
	5		Water Side End connection Details		
			Water Inlet Connection	NB	Consult with Engineering Department on Case to Case Basis
			Water Outlet Connection	NB	Consult with Engineering Department on Case to Case Basis
	6		Pressure Drop		
		i	Water Side	bar	less than 0.5
		ii	Refrigerant Side	bar	Proprietary Data
M			Economizer		
	1		Type	-	Plate Type
	2		Quantity	Nos.	One per Compressor
	3		Heat Duty	kW	Proprietary Data
	4		Material of Construction	-	Brazzed PHE, Plate Material - SS
N			Starter and Control Panel		
	1		Panel Enclosure	-	Starter and Control Panel Integrated in Single Fabricated Box
	2		Make	-	Kirloskar Approved Vendor
	3		Material of Enclosure	-	Rittal Enclosure - Sheet Steel Fabricated Enclosure - CRCA Sheet
	4		Thickness of Enclosure	mm	Rittal Enclosure - (For Single Circuit Chillers) Enclosure - 1.5 mm Door - 2 mm Fabricated Enclosure - (For Dual Circuit Chillers) Load Bearing Member - 2 mm Non-Load Bearing Member - 1.6 mm
	5		Ingress Protection (IP)	-	IP54

Sr. No.			Description	UOM (Wherever Applicable)	Data (Common For All Models)
	6		Painting Specification		
		i	Paint Type	-	RAL 7035
		ii	Standard	-	Coating as per KCPL Standards
	7		Mounting Arrangement	-	Mounted on Chiller
	8		Type of Starter	-	Star-Delta Starter (Soft Starter - Optional)
	9		Type of Isolation	-	MCCB for Star-Delta Starter FSD for Soft Starter
	10		Type of Protection	-	MCCB for Star-Delta Starter FSD for Soft Starter
	11		Switchgear Make	-	Siemens
	12		Electrical and Control Cables	-	Power - PVC Insulated Single Core (Vtg. Grade 1.1 kV) Control- PVC Insulated Single Core, Multicore Cable (Vtg. Grade 1.1 kV) Signal- Shielded Cable
	13		Optional Features		
		i	Phase Indicating Lamps	-	Special-Optional
		ii	Hooter	-	Special-Optional
		iii	Energymeter	-	Special-Optional
		iv	Door Handle	-	Special-Optional
		v	LOTO Arrangement	-	Special-Optional
O			Controller		
	1		Make	-	Refer "Make List" Sheet
	2		Transmitters	-	NA
	3		Oil Level Switch	-	NA
	4		Oil Level Failure Trip	-	NA
	5		LP Switch and Gauge	-	No, Controller Program will Take Care of Low Pressure
	6		HP Switch and Gauge	-	No, Controller Program will Take Care of High Pressure
	7		Chilled Water Flow Failure	-	Yes
	8		Cooling Water Flow Failure	-	Yes
	9		Reverse Rotor Protection	-	No
	10		High/Low Voltage Trip	-	Yes
	11		Low Current Trip (Current Based-Analog)	-	Yes
	12		High Current Trip (Current Based-Analog)	-	Yes
	13		Phase Failure/Reverse Phasing Trip	-	Yes
	14		Earth Fault Trip	-	No
	15		Communication Through RS232/RS485	-	RS485
	16		Display of Microprocessor	-	Yes
	17		Type of Display	-	PGD0 Screen
	18		Remote Monitoring Facility	-	Yes
	19		Output to DCS	-	Applicable (Only if RS485 is Available)