

Detailed Action Plan

Establishing an Electrically Safe Work Environment

Job Planning Check List:

Employee Name(s) _____ Date: _____

- | | | |
|---|---|---|
| ☐ Safety Glasses | ☐ Roof / Fall Arrest Kit | ☐ PPE Cat4 40 Cal CM/CM2 |
| ☐ Hard Hat | ☐ Visibility Vest | ☐ PPE Cat2 Coveralls |
| ☐ Lock Out Tag | ☐ Safety Harness | ☐ Layered Arc 2 |
| ☐ Hearing Protection | ☐ Barricades | ☐ Other _____ |

Is the worker aware of the customer's safety policy and procedures?

- ☐ Yes ☐ No ☐ Request Customer Site Contact

Sketch / Description of work to be performed:

Identify Hazards:

When working on electrical equipment or parts, every attempt shall be made to de-energize electrical circuit conductors and circuit parts. This shall be considered the norm rather than the exception. The decision to work on or near live electrical circuit conductor or circuit parts shall be made after a careful risk assessment has been conducted and shall not be made on economic grounds.

Is live work required?

☐ Yes

☐ No

What voltage may be present?

☐ 120

☐ 347

☐ 480

☐ 600

☐ Other _____

Will you carry out the work herein described and do you acknowledge to follow and adhere to all PPE rules and Procedures set out by OHSA and New Electric TM?

☐ Yes ☐ Employee Initial Through Box

I understand and acknowledge the work presented to me by my Supervisor,

Employee's Signature(s): _____

Date Signed: _____