

Maharashtra State Electricity Distribution Co. Ltd.

Tender No. MSEDCL/2026/ELE/207 - Substation Ancillaries

1. GENERAL

1.1 Supply and installation of internal electrical wiring and distribution boards for the substation control room.

1.2 All PVC insulated cables shall conform to IS 694.

1.3 Electrical wiring installation practice shall follow IS 732:2019 in its entirety.

Page 1 of 2

Maharashtra State Electricity Distribution Co. Ltd.

Tender No. MSEDCL/2026/ELE/207 - Substation Ancillaries

2. PROTECTION AND EARTHING

2.1 Earthing of the installation shall be carried out as per IS 3043.

2.2 Miniature circuit breakers for final circuits shall comply with IS 8828.

2.3 Residual current operated circuit breakers shall be provided on all socket outlet circuits.

2.4 Three phase induction motors supplied under this contract shall be of energy efficiency class IE3 or better.

2.5 Self-ballasted LED lamps for area lighting shall carry a valid BIS registration.