

Orion DC-01 Client Technical Specification

1. Critical Power — UPS

UPS-01 shall provide a minimum rated output of 500 kVA.

Nominal supply voltage shall be 415 V, three phase, 50 Hz.

The UPS shall be configured to maintain N+1 modular redundancy.

Indoor UPS enclosure shall satisfy a minimum protection class of IP31.

The UPS supplier shall provide factory acceptance test evidence before site release.

2. Cooling — CRAH

CRAH-01 and CRAH-02 shall each provide 120 kW sensible cooling capacity.

CRAH external service sections shall comply with IP55 as a minimum.

Cooling controls shall accept 415 V, three phase, 50 Hz supply.

3. Emergency Generation

DG-01 and DG-02 shall provide 1250 kVA standby capacity at 415 V.

Generator enclosure protection shall be IP55 minimum.

Fuel autonomy shall be not less than 24 hours at rated load.