

VoltEdge Vendor Submittal — UPS Package

Submitted model: UPS-01

Proposed UPS-01: rated output capacity 400 kVA.

Nominal input voltage: 400 V, three phase, 50 Hz.

Configuration supplied as N modular system.

Standard enclosure protection: IP20.

Manufacturing lead time: 12 weeks after purchase order.

Submitted model: UPS-02

Proposed UPS-02: rated output capacity 500 kVA.

Nominal input voltage: 415 V, three phase, 50 Hz.

Configuration supplied as N+1 modular system.

Standard enclosure protection: IP31.

Manufacturing lead time: 8 weeks after purchase order.