Preventive Maintenance Program

Document	Revision	Effective	Owner
SOP-OPS-004	5	2025-02-20	Northgate Distribution, Facilities

1. Purpose

This procedure sets the preventive maintenance (PM) schedule for monitored equipment across all sites. Intervals in the equipment manuals are minimums. Where this SOP is stricter, follow this SOP.

2. Site Adjustments

Lakeland (LAK) and Stockton (STK) have high summer ambient temperatures and dust from nearby agriculture. Condenser coils at these sites foul faster, so CU-400 coil cleaning is monthly there instead of quarterly. Aurora (AUR) is at high altitude; AC-75 compressors there run hotter and get oil samples every 1,500 hours.

3. PM Schedule

Equipment	Task	Standard interval	Site exceptions
CU-400	Clean condenser coil	Quarterly	Monthly at LAK and STK
CU-400	Check charge and subcooling	Semi-annually	-
EV-220	Test defrost termination sensor	Quarterly	-
EV-220	Check drain heater	Quarterly	Before Nov 1 at JOL, AUR and ALN
AC-75	Vibration route	Monthly	Weekly when above 3.5 mm/s
AC-75	Oil sample	2,000 run hours	1,500 hours at AUR
CD-900	Belt tension and tracking	Weekly	-
CD-900	Roller inspection	Monthly	-
BC-48	Cable and connector inspection	Monthly	-

4. Condition-Based Triggers

Monitoring data can trigger PM early:

- Any AC-75 with vibration rising more than 1.0 mm/s in 7 days gets an unscheduled vibration analysis.
- Any CU-400 with head pressure averaging above 280 psig for 3 days gets a coil cleaning.
- Any CD-900 with 3 or more OL-1 warnings in a week gets a roller and belt inspection.

5. Records

Close each PM work order in the CMMS with readings taken. Missed PMs are reported in the monthly maintenance review.