CH402 Chemical Engineering Process Design

Class Notes L9

Heat Exchanger Design – You are expected to know this!

Problem 14-15 using CHEMCAD

“3-Step” Heat Exchanger Design Method

(use desktop computer unless laptops have updated price index)

Problem Statement 14-15

The overhead vapor from the C2 splitter in Figure 3-13 is partially condensed in E-601. The process conditions for the vapor entering the condenser are

Temperature, °C	-30.1
Pressure, kPa	1945*

Species Flow rates, kg/s	
CH_4	0.003
C_2H_6	0.0626
C_2H_4	64.53

* Value has been changed from the book value. The authors report 2944 kPa.

A shell-and-tube heat exchanger is to be used to condense 73.5 % of the overhead vapor. Use an appropriate software package (based on TEMA guidelines) to obtain the overall heat transfer coefficient and the area required for the condensation if the tubes have an outside diameter of 0.0127 m and an inside diameter of 0.0094 m. Assuming that the maximum length of the tubes is 3.05 m long, how many tubes will be required and what shell diameter is recommended? Propylene at -46 °C and 125 kPa serves as the coolant for the condensation process.

Additional Questions: (1) Identify the largest resistance to heat transfer in the exchanger and, (2) determine the total purchase cost of the exchanger in Feb. 2026.

Process Background - Conventional Ethylene Process – Fig. 3-7.

page 91



Figure 3-13. Product Separation Section



Figure 3-13. Product separation section.



On my computer, I have Common SI set as the default.



“Thermodynamic Suggestions” window launches automatically when you click OK.

Thermodynamic Suggestions







SRK is good!

Thermodynamic suggestions: Check defaults in both tabs and click OK.




CHEMCAD 8.1.0 - [Untitled*]
File
Home
Drawing
View
Thermophys
Component
Specificatio
Analysis
Sizing
Tools
CC-THERM
Style
Help
Flowsheet
Data Boxes
Explorer
Zoom to Fit
TP Box Visible
Mark Error with Color
Mark Cut Streams
Show Stream IDs
Show UnitOp IDs
Show Stream Names
Show UnitOp Names
Layers
Cascade
Tile Horizontally
Tile Vertically
Refresh
Show
Zoom
Flowsheet
Window
Draw flowchart and solve m/e balances.
Step 1 – Lesson 8, slide 3.
Overhead vapor
Coolant – tube side
Heat Exchanger #4
1
2
3
4
Pro tip 1: default fonts can be set in the "drawing" tab by clicking "font"
Font
Pro tip 2: connect streams in the order shown here. Your streams should be numbered the same. This helps troubleshooting.
Palette
All UnitOps : Grayscale
Heat Exchangers
Feed
Product
Fired Heater
Heat Exchanger
Multi-Stream Exchanger
Miscellaneous : Grayscale
Piping and Flow : Grayscale
Reactors : Grayscale
Separators : Grayscale
Solids handling : Grayscale
Untitled*
Steady State
124.0%

Set Feed Stream 1: Propylene

(Propylene at -46 °C and 125 kPa is available as a coolant.)

Place propylene coolant tubeside (Stream 1)

Tube-side coolant in a condenser is a good idea.

Given: Propylene at -46 °C and 125 kPa serves as the coolant for the condensation process.

The pressure was not specified in the book. Engineers "fill in the blanks."

This will be explained further in slides 11 and 20.



Two specs needed:
Set temperature and vapor fraction.

We don't know the propylene flow rate.
Set it to 1 kg/s.

CHEMCAD will solve for the actual flow rate later.

Complete Specs on Heat Exchanger and Coolant Flow Rate



Note 1: The largest "thermal reservoir" in the coolant is the latent heat of the phase transition. Any further warming of the coolant beyond the phase change will involve relatively small enthalpy changes.

Click OK, then Run

Run the Simulation and Confirm Results (1/3)



Confirm Results (2/3)



Given

Note: there is no P-drop

Note: there is no A or U

Double-click heat exchanger to confirm results

Confirm Results (3/3)



Numbers in gray fields were calculated by CHEMCAD

STOP HERE

Confirm results in slides 12 to 14 before proceeding

Step 1 (L8 Slide 3) is complete:

Determined the flow rates and heat transfer rates necessary to meet the given conditions.



Save your simulation at this point.

Make a copy of the first exchanger and paste it to make a second exchanger. This is REQUIRED.

This is a backup of your work to safeguard against mistakes.

Click “Sizing,” then “Shell-and-tube.”

This initiates steps 2-5 of the design process (L8 slide 5).




CHEMCAD 8.1.0 - [Lesson9_AY232_Trial1*]
File
Home
Drawing
View
Thermophysic
Component D
Specification
Analysis
Sizing
Tools
CC-THERM
Style
Help
UnitOp ID 2
Case 14-15 Design
Select
Type Shell and Tube
General
Enter Stream Information
Heat Curve Specification
Edit Heat Curve
Materials
Label
Tube
Nozzle
Shell
Clearance
Charts
Reports
1
CLICK THE CENTER OF THE GEAR WHEEL.
4
7
2
5
6
8
Lesson9_AY232_Trial1*
Lesson9_AY232_Trial1_1
Steady State
K:SRK H:SRK
Select Tube-side Inlet Stream
Please select the stream entering the exchanger tube side.
3
5
2
OK
Cancel
Hide
All Streams
Feed Streams
Product Streams
Cut Streams
Groups

TEMA Type AEL Exchanger. Take all defaults.



Heating-cooling curve can be seen by clicking “Heat Curve Specification.”



Bumping up the cold feed pressure to 125 kPa drops the first data point so I can identify the cold inlet in the heating-colling curve.


CHEMCAD 8.1.0 - [Lesson9_AY232_Trial1*]
File
Home
Drawing
View
Thermophysic
Component D
Specification
Analysis
Sizing
Tools
CC-THERM
Style
Help
UnitOp ID 2
Case 14-15 Design
Select
Type Shell and Tube
General
dropdown
Enter Stream Information
Heat Curve Specification
Edit Heat Curve
Materials
Label
Simulation Mode
Design Constraints
Reboiler Specifications
Tube
Shell
Baffle
Nozzle
Clearance
Miscellaneous
Geometry
Design
Run
Charts
Reports
Results
Palette
1
4
7
5
2
6
8
Lesson9_AY232_Trial1*
Lesson9_AY232_Trial1_1
Steady State
Design Constraints
Design Criteria
Allowable tube pressure drop 34.473801 kPa
Allowable shell pressure drop 34.473801 kPa
Allowable tube velocity 76.199997 m/sec
Allowable shell velocity 76.199997 m/sec
Prefer tube length/shell diameter ratio 12
Minimum excess %
Sizing nozzle
Tube, inlet
Tube, outlet
Shell, inlet
Shell, outlet
Limits of Design Variables
Lower Limits
Upper Limits
Tube Length 3 3.1 m
Shell Diameter 0.1524 6 m
Baffle Cut 15 45 Percent of diameter
Baffle Spacing 0.050799999 3.175 m
Optimize number of tube passes
2
3
4
5
Help
Cancel
OK


CHEMCAD 8.1.0 - [Lesson9_AY232_Trial1*]
File
Home
Drawing
View
Thermophysic
Component D
Specification
Analysis
Sizing
Tools
CC-THERM
Style
Help
UnitOp ID 2
Case 14-15 Design
Select
Type Shell and Tube
General
Enter Stream Information
Heat Curve Specification
Edit Heat Curve
Materials
Label
Simulation Mode
Tube
Nozzle
Shell
Clearance
Baffle
Miscellaneous
Geometry
Design
Run
Charts
Reports
Results
Tube
Access tube specifications
Tube Specifications
Number of tubes * 1396
Number of tube passes * 1
Tube outer diameter .0127 m
Tube wall thickness 0.00165 m
Tube length * m
Roughness factor 1.5748e-06 m
Tube pattern Rotated Triangular (60)
Tube pitch 0.023812501 m
Trufin tube code Plain tube
Turbulator No Turbulator
Tubesheet thickness 0.01905 m
Number of tubesheets 2
* Field may be recalculated when design calculation is run
Help
Cancel
OK
1
2
3
4
5
Heat Exchangers
Feed
Product
Fired Heater
Heat Exchanger
Multi-Stream Exchanger
Miscellaneous : Grayscale
Piping and Flow : Grayscale
Reactors : Grayscale
Separators : Grayscale
Solids handling : Grayscale
Lesson9_AY232_Trial1*
Lesson9_AY232_Trial1_1
Steady State
K:SRK H:SRK
128.0%


CHEMCAD NXT 1.2.0 - [Untitled*]
File
Home
Drawing
View
Thermophys
Component
Specificatio
Analysis
Sizing
Economics
Tools
CC-THERM
Style
Help
UnitOp ID 2
Case 14-15 Design
Select
Type Shell and Tube
General
Enter Stream Information
Heat Curve Specification
Edit Heat Curve
Materials
Label
Simulation Mode
Configuration
Tube
Shell
Baffle
Geometry
Design
Charts
Reports
dropdown
1
Design
Rating
Fouling Rating
4
7
2
5
6
8
you should see 44 iterations
23
Iteration 44
Steady State
K:SRK H:SRK
196.0%


CHEMCAD 8.1.0 - [Lesson9_AY232_Trial1*]
Sizing
Tools
CC-THERM
Tube
Nozzle
Shell
Clearance
Baffle
Miscellaneous
Geometry
Design
Charts
Reports
1
CC-THERM Reports
Overview
Summary Results
Shell-side Data
Tube-side Data
Baffle Data
Clearances
Overall Data
Tabulated Data
Heat Curve
Zone-by-zone A...
Vibration
Optimization
Stream Data
Reboiler Data
TEMA
TEMA Sheet
Input Data Report
2

Design Results – CHEMCAD NXT 1.2.0

TABULATED ANALYSIS

Overall Data:

Area Total	m2	2348.77	% Excess		6.13
Area Required	m2	2157.83	U Calc.	W/m2-K	566.94
Area Effective	m2	2290.05	U Service	W/m2-K	534.21
Area Per Shell	m2	2290.05	Heat Duty	J/sec	1.57E+07
Weight LMTD C	12.80	LMTD CORR Factor	1.0000	CORR LMTD C	12.80

Shell:

Shell O.D.	m	3.68	Orientation		H
Shell I.D.	m	3.66	Shell in Series		1
Bonnet I.D.	m	3.66	Shell in Parallel		1
Type		AEL	Max. Heat Flux Btu/ft2-hr		0.00
Imping. Plate		Impingement Plate	Sealing Strip		5

Tubes:

Number		19314	Tube Type		Bar
Length	m	3.05	Free Int. Fl Area	m2	0.00
Tube O.D.	m	0.013	Fin Efficiency		0.000
Tube I.D.	m	0.009	Tube Pattern		TRI60
Tube Wall Thk.	m	0.002	Tube Pitch	m	0.024
No. Tube Pass		1			
Inner Roughness	m	0.0000016			
Number of tubesheets		2	Tubesheet thickness, m		0.019

Resistances:

Shell-side Film	m2-K/W	0.00068
Shell-side Fouling	m2-K/W	0.00018
Tube Wall	m2-K/W	0.00004
Tube-side Fouling	m2-K/W	0.00018
Tube-side Film	m2-K/W	0.00047
Reference Factor (Total outside area/inside area based on tube ID)		1.351

Answers to first three questions are found here. How many tubes? Shell diameter? Largest resistance?

STOP HERE

Confirm results in slide 25 and save your simulation before proceeding

Steps 2-5 of L8 Slide 3 are now complete:

Type of exchanger, geometric details, overall U, thermal driving force, area, and P-drops.

Exchanger Simulation

Copying and pasting is an important step.

It preserves the design work down in exchanger 2 as a backup.



copy this and paste here

Setting the “Simulation Mode” to “1 Shell & tube simulation initiates step 6 of the design process (L8 slide 3).



Heat Exchanger Before Running





Click OK then run the simulation.

Heat Exchanger After Running



Click “Run All” in the Home tab


CHEMCAD NXT 1.2.0 - [14-15 Practice Trial4 - NXT*]
File
Home
Drawing
View
Thermophysical
Component Database
Specification
Analysis
Sizing
Economics
Tools
CC-THERM
Style
Help
Show Grid
Snap to Grid
Snap to Center
Change Grid Size
Stream Styles...
Font
Workspace
Text Box
Title Block
Stream Box
UnitOp Box
TP Box
Excel Range
Image
Insert
Arrange
Objects
ID 7
T -30.10 C
P 1945.81 kPa
ID 5
T -46.00 C
P 125.00 kPa
ID 11
T -30.10 C
P 1945.81 kPa
ID 9
T -46.00 C
P 125.00 kPa
7
5
11
9
2
3
6
8
10
12
ID 6
T -42.88 C
P 125.00 kPa
ID 8
T -30.11 C
P 1945.81 kPa
ID 10
T -40.45 C
P 121.68 kPa
ID 12
T -30.14 C
P 1944.17 kPa
Simulation Results
14-15 Practice Trial4 - NXT*
14-15 Practice Trial4 - NXT_1
Steady State
K:SRK H:SRK
144.0%


CHEMCAD NXT 1.2.0 - [14-15 Practice Trial4 - NXT*]
File
Home
Drawing
View
Thermophysical
Component Database
Specification
Analysis
Sizing
Economics
Tools
CC-THERM
Style
Help
Save Data Map
Save Data Map As
View/Edit
Execution Rules
New
Import...
Data Map
Select Costing
Edit Cost Index
Economics
Execute Parser
Units Converter
Simple Calculator
Visual Basic Editor
Reaction Rate Regression
CO2 Solid
Hydrates
TOC/COD...
Environmental Report...
Title Block Designer
UnitOp Designer
Flowsheet
1
2
3
4
Chemical Engineering Plant Cost Index
Year/Month Selection for the Cost Index
Year
2026
Source
Database
Month
February
make sure to set this to February 2026
Type
Cost Index
CE Index
830.50
Equipment
1045.80
Heat exchangers and tanks
815.70
Process machinery
1057.50
Pipes, valves, and fittings
1410.40
Process instruments
620.50
Pumps and compressors
1677.10
Electrical equipment
917.90
Structural supports and misc.
1142.00
Construction labor
390.30
Buildings
835.10
Engineering and supervision
313.20
Help
Cancel
OK
ID 11
T -30.10 C
P 1945.81 kPa
ID 9
T -46.00 C
P 125.00 kPa
ID 10
T -40.45 C
P 121.68 kPa
ID 12
T -30.14 C
P 1944.17 kPa
T -30.11 C
P 1945.81 kPa
14-15 Practice Trial4 - NXT*
Steady State
K:SRK H:SRK
196.0%


CHEMCAD NXT 1.2.0 - [14-15 Practice Trial4 - NXT*]
File
Home
Drawing
View
Thermophysical
Component Database
Specification
Analysis
Sizing
Economics
Tools
CC-THERM
Style
Help
Save Data Map
Save Data Map As
View/Edit
Execution Rules
New
Import...
Data Map
Select Costing
Edit Cost Index
Economics
Costing
Execute Parser
Units Converter
Simple Calculator
Visual Basic Editor
Reaction Rate Regression
General
CO2 Solid
Hydrates
TOC/COD...
Environmental Report...
Environmental
Title Block Designer
UnitOp Designer
Flowsheet
8
ID 8
T -30.11 C
P 1945.81 kPa
ID 11
T -30.10 C
P 1945.81 kPa
11
3
ID 9
T -46.00 C
P 125.00 kPa
9
10
ID 10
T -40.45 C
P 121.68 kPa
1
double-click
12
ID 12
T -30.14 C
P 1944.17 kPa
14-15 Practice Trial4 - NXT*
14-15 Practice Trial4 - NXT_1
HTXR.my
Steady State
K:SRK H:SRK
196.0%

Cost Results



Answer to last question is found here (total purchase cost in Feb 2026).

STOP HERE

Finished.

Submit CHEMCAD file, tabulated results report, and answers to the four (4) questions