STD-CV-0103 Control valves (invented)

Revision 0 Engineering Standard (invented for testing)

1 Scope

This invented standard covers control valves.

5.1 Capacity

The offered flow coefficient shall be at least the required flow coefficient.

6.2 Leakage

The seat leakage class shall be Class IV or tighter.

7.1 Noise

The noise level shall not exceed 85 dBA.

7.3 Stroke time

The valve stroke time shall not exceed 0.5 min.

9.3 Fire safety

A fire-safe certificate shall be stated for valves in hydrocarbon service.

9.6 Cryogenic service

A valve in cryogenic service shall have an extended bonnet.