STD-PUMP-0101 Centrifugal pumps (invented)

Revision 0 Engineering Standard (invented for testing)

1 Scope

This invented standard covers centrifugal pumps.

4.2 Design pressure

The design pressure shall be at least 12 barg.

5.1 Seals

The mechanical seal plan shall be stated on the datasheet.

6.3 Flow

The rated flow shall be at least the required flow.

Service	Minimum flow
General	100 m3/h

7.1 Head

The differential head shall be at least 40 m of liquid column.

9.4 Steam turbines

A steam turbine driver shall have a trip valve.