









Title-24 Energy Requirements

Wade Energy

1942 Linda Dr.
Pleasant Hill, CA 94523
(925) 203-5686
travis@wadeenergy.com



Building Component		Notes	Efficiency
Water Heater		Tankless Water Heater	0.95 UEF
Heating System		Ducted Heat Pump	9.1 HSPF2
Cooling System		Heat Pump Outdoor Condenser	12 EER2 19.6 SEER2
Ducting System		Ducts within unconditioned attic	R-8
Ceiling/Roof		Unvented Roof Attic	R-38 below roof deck
Walls		Exterior 2x6 Walls Underground Mass Walls	R-21 R-5 Continuous Exterior Rigid
Floors		Unheated Slab on Grade	N/A
Windows/Doors		Windows Solid Doors	U-Factor = 0.30 SHGC = 0.23 U-Factor = 0.50