









# Title-24 Energy Requirements

## Wade Energy

1942 Linda Dr.  
Pleasant Hill, CA 94523  
(925) 203-5686  
travis@wadeenergy.com



| Building Component |   | Notes  | Efficiency   |
|--------------------|---|--|--|
| Water Heater       |    | Heat Pump Water Heater, 40 gal                   | 3.83 UEF   |
| Heating System     |    | Ductless Multi-Split Heat Pump (3x indoor units) | 8.0 HSPF2  |
| Cooling System     |   | Ductless Multi-Split Heat Pump (1x outdoor unit) | 11.7 EER2<br>14 SEER2  |
| Ducting System     |  | None   | N/A  |
| Ceiling/Roof       |  | Roof attic                                       | R-30   |
| Walls              |  | New Walls 2x6                                    | R-21   |
| Floors             |  | Slab on Grade                                    | N/A  |
| Windows            |  | New Windows<br><br>New Glass Doors               | U-Factor = 0.30<br>SHGC = 0.23<br>U-Factor = 0.32<br>SHGC = 0.21 |