



- | ITEM | REMARKS |
|------|---|
| 1. | THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ELECTRICAL SERVICES SPECIFICATION AND ALL OTHER DRAWINGS LISTED ON THE DRAWING ISSUE SHEETS. |
| 2. | THE ELECTRICAL INSTALLATION SHALL FULLY COMPLY WITH THE LATEST REQUIREMENTS OF BS 7671 AND ALL ITS LATEST AMENDMENTS. |
| 3. | ALL CONDUCTORS SHALL BE COPPER. |
| 4. | ALL EARTH BARS SHALL BE HIND DRAWN COPPER, MOUNTED ON INSULATED SUPPORTS. |
| 5. | ALL INSTALLED CABLES SHALL BE LOW SMOKE AND ZERO HALOGEN AND SHALL BE BASIC APPROVED. |

Contract drawings are for design intent purposes only and shall not be used as working or installation drawings. Contractor to produce coordinated installation drawings. Installation to be co-ordinated on site with all other Trades. All information to be read in-conjunction with Preliminaries and Specification.



norse
group

CLIENT
LEEDS CITY COUNCIL
HOUSING GROWTH

PROJECT
NEW BUILD STANDARD M&E
SPECIFICATIONS

TITLE
ELECTRICAL SERVICES
TYPICAL INDICATIVE CONSUMER UNIT
LAYOUTS FOR FLATS AND HOUSES

SCALE		DISCIPLINE		PROJECT NUMBER	
N.T.S		Electrical Engineer		114026	
DRAWING NUMBER				REV CODE	
NPS-ZZ-XX-D-E-6000				C1	
STATUS CODE		PURPOSE OF ISSUE		APPROVED BY	
A3		Tender		De KM	