

Reference : DB-00-08P Food Room					Location : NB1 2 Ground Floor Electrical Riser off Circ Space 00-117						
160A Sw/Discon 18 Way					Serving : NB02 Ground Floor Food Room Power						
TP&N					Reference : F28						
					Cable Size : Refer To Cable Schedule (70mm² Multicore XLPE/SWA/LS0H)						
Way	Line	In	lb	Type Note 3	Load (Watts)			Serving	Cable csa (mm ²)	Cable Type Note 2	Install Method No. See Note 5
				P	L1	L2	L3				
	L1			B							
1	L2			B							
	L3			B							
	L1			B							
2		20		P1	26			Electrical Hob - Radial #EPO 2	4	T5	31, 5
		32		P1				32A SP&N Isolator for Range Cooker #EPO 2	6	T5	31, 5
	L1	32		P1				00-116 Food Room Bench DSSO Ring Circuit	4	T5	31, 5
3		20		P1				Electrical Oven - Radial #EPO 2	4	T5	31, 5
		32		P1				32A SP&N Isolator for Range Cooker #EPO 2	6	T5	31, 5
	L1	32		P1				Food Store Frigdes & DSSO Ring Circuit	4	T5	31, 5
4	L2	32		P1				32A SP&N Isolator for Range Cooker #EPO 4	6	T5	31, 5
		32		P1				Food Room Island Bench DSSO Ring Circuit	4	T5	31, 5
	L1	32		P1				Food Store Washing Machine & Dryer Ring Circuit	4	T5	31, 5
5	L2	32		P1				32A SP&N Isolator for Range Cooker #EPO 4	6	T5	31, 5
		32		P1	19			32A SP&N Isolator for Range Cooker #EPO 2	6	T5	31, 5
	L1	20		P1				Electrical Oven - Radial #EPO 4	4	T5	31, 5
6	L2	32		P1				32A SP&N Isolator for Range Cooker #EPO 4	6	T5	31, 5
		32		P1				32A SP&N Isolator for Range Cooker #EPO 2	6	T5	31, 5
	L1	20		P1				Electrical Hob - Radial #EPO 4	4	T5	31, 5
7	L2	32		P1				32A SP&N Isolator for Range Cooker #EPO 4	6	T5	31, 5
		32		P1				32A SP&N Isolator for Range Cooker #EPO 2	6	T5	31, 5
	L1	32		P1				Teachaers Wall Ring Circuits, cleaners & Fridge	4	T5	31, 5
8	L2	32		P1	11			32A SP&N Isolator for Range Cooker #EPO 4	6	T5	31, 5
		32		P1				32A SP&N Isolator for Range Cooker #EPO 2	6	T5	31, 5
	L1	20		P1				Radial 6no DSSO & 1no Cleaner Outlet	2.5	T5	31, 5
9	L2	32		P1				32A SP&N Isolator for Range Cooker #EPO 4	6	T5	31, 5
		20		P1				Radial 6no DSSO & 1no Cleaner Outlet	2.5	T5	31, 5
	L1	32		P1				32A SP&N Isolator for Range Cooker #EPO 3	6	T5	31, 5
10	L2	20		P1				Gas Shut off Solenoid Valve	2.5	T5	31, 5
		32		P1				32A SP&N Isolator for Range Cooker #EPO 1	6	T5	31, 5
	L1	32		P1				32A SP&N Isolator for Range Cooker #EPO 3	6	T5	31, 5
11	L2	32		P1				SPARE			
		32		P1				32A SP&N Isolator for Range Cooker #EPO 1	6	T5	31, 5
	L1	32		P1				32A SP&N Isolator for Range Cooker #EPO 3	6	T5	31, 5
12	L2	32		P1				SPARE			
		32		P1				32A SP&N Isolator for Range Cooker #EPO 1	6	T5	31, 5
Total Phase Loading								Watts 3	Protective Device		
								Amps	P1 - MCB Curve Type C		
									P2 - RCBO (Type A unless stated otherwise)		
									P3 - MCB / Fuse with separate 30 mA RCD		
									P4 - HRC		
									P5 - MCB Type User Defined		
									4 Loads noted for Ring Circuits [RC] are nominal		
									5 Installation method based on Table 4A2		
									6 Separate CPC to be same csa as Line Conductor		
									7 B Fitted blank		

Notes

1 Fitted with Integral Incoming Switch

2 Cable Types-Legend

T1 LS0H Single Core Cables in Conduit / Trunking

T2 XLPE / SWA / LS0H Cable

T3 MICC / LSF Cables

T4 XLPE / SWA / PVC Cable

T5 XLPE / LS0H Flat Twin & Earth Cable

T6 As T1 Plus 4mm² Separate CPC

4 Loads noted for Ring Circuits [RC] are nominal

5 Installation method based on Table 4A2

6 Separate CPC to be same csa as Line Conductor

7 B Fitted blank

Reference : DB-00-08P Food Room				Location : NB1 2 Ground Floor Electrical Riser off Circ Space 00-117							
160A Sw/Discon 18 Way				Serving : NB02 Ground Floor Food Room Power							
TP&N				Reference : F28							
				Cable Size : Refer To Cable Schedule (70mm2 Multicore XLPE/SWA/LS0H)							
				Type Note 3	Load (Watts)			Serving	Cable csa (mm²)	Cable Type Note 2	Install Method No. See Note 5
Way	Line	In	Ib	P	L1	L2	L3				
	L1	32		P1				32A SP&N Isolator for Range Cooker* EPO 3	6	T5	31, 5
13	L2	32		P1				SPARE			
	L3	32		P1				32A SP&N Isolator for Range Cooker* EPO 1	6	T5	31, 5
	L1	32		P1				32A SP&N Isolator for Range Cooker* EPO 1	6	T5	31, 5
14	L2	32		P1				32A SP&N Isolator for Range Cooker* EPO 3	6	T5	31, 5
	L3	32		P1				Teachaers Wall Ring Circuits, cleaners & Fridge	4	T5	31, 5
	L1	20		P1				Electrical Oven - Radial* EPO 3	4	T5	31, 5
15	L2	32		P1				SPARE			
	L3	32		P1				32A SP&N Isolator for Range Cooker* EPO 1	4	T5	31, 5
	L1	20		P1				Electrical Hob - Radial* EPO 3	4	T5	31, 5
16	L2	32		P1				SPARE			
	L3	20		P1				3no Heat maintenance tape spurs	2.5	T5	31, 5
	L1			B							
17	L2			B							
	L3			B							
	L1			B							
18	L2			B							
	L3			B							
Total Phase Loading								Watts Amps	3	Protective Device	
										P1 - MCB Curve Type C	
										P2 - RCBO (Type A unless stated otherwise)	
										P3 - MCB / Fuse with separate 30 mA RCD	
										P4 - HRC	
										P5 - MCB Type User Defined	
									4	Loads noted for Ring Circuits [RC] are nominal	
									5	Installation method based on Table 4A2	
									6	Separate CPC to be same csa as Line	
										Conductor	
									7	B Fitted blank	

Notes

1 Fitted with Integral Incoming Switch

2 Cable Types-Legend

T1 LS0H Single Core Cables in Conduit / Trunking

T2 XLPE / SWA / LS0H Cable

T3 MICC / LSF Cables

T4 XLPE / SWA / PVC Cable

T5 XLPE / LS0H Flat Twin & Earth Cable

T6 AS 11 Plus 4mm² Separate CPC

3 Protective Device

P1 - MCB Curve Type C

P2 - RCBO (Type A unless stated otherwise)

P3 - MCB / Fuse with separate 30 mA RCD

P4 - HRC

P5 - MCB Type User Defined

4 Loads noted for Ring Circuits [RC] are nominal

5 Installation method based on Table 4A2

6 Separate CPC to be same csa as Line

Conductor

7 B Fitted blank

Notes

- 1 Fitted with Integral Incoming Switch
- 2 Cable Types-Legend
 - T1 LS0H Single Core Cables in Conduit / Trunking
 - T2 XLPE / SWA / LS0H Cable
 - T3 MICC / LSF Cables
 - T4 XLPE / SWA / PVC Cable
 - T5 XLPE / LS0H Flat Twin & Earth Cable
 - T6 AS 11 Plus 4mm² Separate CPC
- 3 Protective Device
- 4 Loads noted for Ring Circuits [RC] are nominal
- 5 Installation method based on Table 4A2
- 6 Separate CPC to be same csa as Line
- 7 B Fitted blank

Reference : DB-00-11P				Location : NB02 Electrical Riser off 00-102 Corridor Circ Space.							
160 A - Sw/Discon				Serving : NB2 Ground Floor DT Power							
16 Way TP&N				Incoming Cable				Reference : F34			
								Cable Size : Refer To Cable Schedule (70mm2 Multicore XLPE/SWA/LS0H)			
				Type Note 3	Load (Watts)			Serving	Cable csa (mm²)	Cable Type Note 2	Install Method No. See Note 5
Way	Line	In	Ib	P	L1	L2	L3				
1	L1	16		P2				Lathe 16A Equipment Power #EPO	4	T5	31, 5
	L2										
	L3										
	L1	20		P2				DT Power DSSO Outlets	4	T5	31, 5
2	L2	16		P2				Scrollsaw & Extract 16A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
3	L2	20		P2				PillarDrill 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				PillarDrill 20A Equipment Power #EPO	4	T5	31, 5
	L1	16		P2				Lathe 16A Equipment Power #EPO	4	T5	31, 5
4	L2	20		P2				DT Power DSSO Outlets	4	T5	31, 5
	L3	20		P2				Polisher inc Extract 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
5	L2	20		P2				CNC Lathe 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				Teachers wall power DSSO Outlets	4	T5	31, 5
	L1	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
6	L2	16		P2				Scrollsaw & Extract 16A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				DT Power DSSO Outlets	4	T5	31, 5
	L1	20		P2				PillarDrill 20A Equipment Power #EPO	4	T5	31, 5
7	L2	20		P2				SPARE	-	-	-
	L3	20		P2				CNC Lathe 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				Polisher inc Extract 20A Equipment Power #EPO	4	T5	31, 5
8	L2	20		P2				Polisher inc Extract 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				Scrollsaw & Extract 16A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				00-152 DT Power Pillar Drill #EPO	4	T5	31, 5
9	L2	20		P2				PillarDrill 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				00-112 DT Power DSSO Outlets	4	T5	31, 5
	L1	20		P2				SPARE	-	-	-
10	L2	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				Polisher inc Extract 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				SPARE	-	-	-
11	L2	20		P2				Lathe 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				SPARE	-	-	-
12	L2	20		P2				CNC Lathe 20A SP&N Equip Power #EPO	4	T5	31, 5
	L3	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
Total Phase Loading								Watts 3	Protective Device		
								Amps	P1 - MCB Curve Type C		
Notes				P2 - RCBO (Type A unless stated otherwise)							
				P3 - MCB / Fuse with separate 30 mA RCD							
				P4 - HRC							
				P5 - MCB Type User Defined							
				4 Loads noted for Ring Circuits [RC] are nominal							
				5 Installation method based on Table 4A2							
				6 Separate CPC to be same csa as Line Conductor							
1 Fitted with Integral Incoming Switch				7 B Fitted blank							
2 Cable Types-Legend											
T1 LS0H Single Core Cables in Conduit / Trunking											
T2 XLPE / SWA / LS0H Cable											
T3 MICC / LSF Cables											
T4 XLPE / SWA / PVC Cable											
T5 XLPE / LS0H Flat Twin & Earth Cable											
T6 As T1 Plus 4mm² Separate CPC											

Reference : DB-00-11P				Location : NB02 Electrical Riser off 00-102 Corridor Circ Space.			
160 A - Sw/Discon				Serving : NB2 Ground Floor DT Power			
16 Way				Incoming Cable		Reference : F34	
TP&N						Cable Size : Refer To Cable Schedule (70mm2 Multicore XLPE/SWA/LS0H)	

Reference : DB-00-13 P					Location : NB02 Electrical Riser off Circ 00-102						
160 A Sw/Discon					Serving : NB2 Ground Floor DT & Engineering Power						
12 Way					Incoming Cable			Reference : F36			
TP&N					Refer To Cable Schedule (70mm2 Multicore						
								Cable Size : XLPE/SWA/LS0H)			
				Type Note 3	Load (Watts)			Serving	Cable csa (mm²)	Cable Type Note 2	Install Method No. See Note 5
Way	Line	In	lb	P	L1	L2	L3				
	L1	20		P2				SPARE	-	-	-
1	L2	20		P2				SPARE	-	-	-
	L3	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				Lahme 20A Equipment Power #EPO	4	T5	31, 5
2	L2	20		P2				Gas pressure proving unit	2.5	T5	31, 5
	L3	20		P2				Bandfacer 20A Equipment Power #EPO	4	T5	31, 5
	L1	16		P2				ScrollSaw Extract 16A Equipment Power #EPO	4	T5	31, 5
3	L2	20		P2				Teachers wall DSSO Outlets	4	T5	31, 5
	L3	20		P2				Pillardrill 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				CNC LAHME 20A Equipment Power #EPO	4	T5	31, 5
4	L2	20		P2				Lahme 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				Polisher (Inc Extract) 20A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				SPARE	-	-	-
5	L2	16		P2				Milling Machine 16A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				00-179 Teachers wall DSSO Outlets	4	T5	31, 5
	L1	20		P2				00-173 DT Studio textiles wall DSSO #EPO	4	T5	31, 5
6	L2	20		P2				Polisher (Inc Extract) 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				00-179 DT Workshop 2 General DSSO Outlets #EPO	4	T5	31, 5
	L1	20		P2				DT Studio textiles 2 DSSO Outlets #EPO	4	T5	31, 5
7	L2	20		P2				Pillar Drill 20A Equipment Power #EPO	4	T5	31, 5
	L3	16		P2				Grinder 16A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				DT Studio Textiles 2 Teachers wall DSSO	4	T5	31, 5
8	L2	20		P2				00-176 Engineering Workshop 2 General DSSO #EPO	4	T5	31, 5
	L3	16		P2				ScrollSaw + Extract 16A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				DT Prep Room 1 General DSSO Outlets #EPO	4	T5	31, 5
9	L2	20		P2				SPARE	-	-	-
	L3	16		P2				Brazing Hearhm 16A Equipment Power #EPO	4	T5	31, 5
	L1	20		P2				00-173 Teachers wall DSSO Outlets	4	T5	31, 5
10	L2	20		P2				SPARE	-	-	-
	L3	16		P2				Crucible Furnace 16A Equipment Power #EPO	4	T5	31, 5
	L1	-		B				-	-	-	-
11	L2	20		P2				CNC LAHME 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P2				CNC LAHME 20A Equipment Power #EPO	4	T5	31, 5
12	L1	16		P2				Table Saw + Extract TPN 16A Equipment Pwr #EPO	4	T5	31, 5
Total Phase Loading								Watts 3	Protective Device		
								Amps	P1 - MCB Curve Type C		
Notes					P2 - RCBO (Type A unless stated otherwise)						
1 Fitted with Integral Incoming Switch					P3 - MCB / Fuse with separate 30 mA RCD						
2 Cable Types-Legend					P4 - HRC						
T1 LS0H Single Core Cables in Conduit / Trunking					P5 - MCB Type User Defined						
T2 XLPE / SWA / LS0H Cable					4 Loads noted for Ring Circuits [RC] are nominal						
T3 MICC / LSF Cables					5 Installation method based on Table 4A2						
T4 XLPE / SWA / PVC Cable					6 Separate CPC to be same csa as Line						
T5 XLPE / LS0H Flat Twin & Earth Cable					Conductor						
T6 As T1 Plus 4mm² Separate CPC					7 B Fitted blank						

Reference : DB-00-13 P					Location : NB02 Electrical Riser off Circ 00-102				
160 A Sw/Discon 12 Way TP&N					Serving : NB2 Ground Floor DT & Engineering Power				
					Reference : F36 Refer To Cable Schedule (70mm ² Multicore XLPE/SWA/LS0H)				
					Cable Size :				

Way	Line	In	lb	Type	Load (Watts)			Serving	Cable csa (mm ²)	Cable Type Note 2	Install Method No. See Note 5
				Note 3	P	L1	L2				
	L1			B							
13	L2			B							
	L3			B							
	L1			B							
14	L2			B							
	L3			B							
Total Phase Loading								Watts	3	Protective Device	
								Amps		P1 - MCB Curve Type C	

Notes 1 Fitted with Integral Incoming Switch 2 Cable Types-Legend T1 LS0H Single Core Cables in Conduit / Trunking T2 XLPE / SWA / LS0H Cable T3 MICC / LSF Cables T4 XLPE / SWA / PVC Cable T5 XLPE / LS0H Flat Twin & Earth Cable T6 As T1 Plus 4mm ² Separate CPC	P2 - RCBO (Type A unless stated otherwise) P3 - MCB / Fuse with separate 30 mA RCD P4 - HRC P5 - MCB Type User Defined 4 Loads noted for Ring Circuits [RC] are nominal 5 Installation method based on Table 4A2 6 Separate CPC to be same csa as Line Conductor 7 B Fitted blank
--	--

Reference : DB-00-23P				Location : NB02 Electrical Riser off 00-102 Corridor Circ Space.							
160 A - Sw/Disc 12 Way TP&N				Serving : NB2 Ground Floor Engineering Workshop Power							
				Incoming Cable				Reference : F98			
								Cable Size : Refer To Cable Schedule (70mm2 Multicore XLPE/SWA/LS0H)			
				Type Note 3	Load (Watts)			Serving	Cable csa (mm²)	Cable Type Note 2	Install Method No. See Note 5
Way	Line	In	Lb	P	L1	L2	L3				
1	L1	20		P1				00-163 Engineering Workshop DSSO Outlets #EPO	4	T5	31, 5
	L2	20		P1				Polisher inc Extract 20A Equipment Power #EPO	4	T5	31, 5
	L3	20		P1				SPARE	-	-	-
2	L1	16		P1				Grinder 16A Equipment Power #EPO	4	T5	31, 5
	L2	16		P1				Milling Machine 16A Equipment Power #EPO	4	T5	31, 5
	L3	16		P1				Grinder 16A Equipment Power #EPO	4	T5	31, 5
3	L1	16		P1				Brazing HEARHM 16A Equipment Power #EPO	4	T5	31, 5
	L2	20		P1				Pillar Drill 20A Equipment Power #EPO	4	T5	31, 5
	L3	16		P1				ScrollSaw + Extract 16A Equip Power #EPO	4	T5	31, 5
4	L1	16		P1				Crucible Furnace 16A Equipment Power #EPO	4	T5	31, 5
	L2	20		P1				Teachers wall dsso power	4	T5	31, 5
	L3	20		P1				CNC LAHME 20A Equipment Power #EPO	4	T5	31, 5
5	L1	20		P1				CNC LAHME 20A Equipment Power #EPO	4	T5	31, 5
	L2	20		P1				Lahme 20A Equipment Power #EPO	4	T5	31, 5
	L3	16		P1				Brazing HEARHM 16A Equipment Power #EPO	4	T5	31, 5
6	L1	16		P1				ScrollSaw + Extract 16A Equip Power #EPO	4	T5	31, 5
	L2	20		P1				Gas pressure proving power	4	T5	31, 5
	L3	16		P1				Crucible Furnace 16A Equipment Power #EPO	4	T5	31, 5
7	L1	20		P1				Polisher 20A (Inc Extract) SP&N #EPO	4	T5	31, 5
	L2	16		P1				SPARE			
	L3	16		P1				SPARE			
8	L1	16		P1				Milling Machine 16A Equipment Power #EPO	4	T5	31, 5
	L2	20		P1				SPARE			
	L3	20		P1				SPARE			
9	L1	20		P1				Pillar Drill 20A Equipment Power #EPO	4	T5	31, 5
	L2	20		P1				00-155 Engineering Workshop DSSO Outlets #EPO	4	T5	31, 5
	L3			B							
10	L1	20		P1				Lahme 20A Equipment Power #EPO	4	T5	31, 5
	L2			B							
	L3			B							
11	L1	20		P1				00-163 - Teachers wall DSSO Power	4	T5	31, 5
	L2			B							
	L3			B							
12	L1	20		P1				Gas pressure proving Power	4	T5	31, 5
	L2			B							
	L3			B							
Total Phase Loading								Watts 3	Protective Device		
								Amps	P1 - MCB Curve Type C		
Notes				P2 - RCBO (Type A unless stated otherwise)							
1 Fitted with Integral Incoming Switch				P3 - MCB / Fuse with separate 30 mA RCD							
2 Cable Types-Legend				P4 - HRC							
T1 LS0H Single Core Cables in Conduit / Trunking				P5 - MCB Type User Defined							
T2 XLPE / SWA / LS0H Cable				4 Loads noted for Ring Circuits [RC] are nominal							
T3 MICC / LSF Cables				5 Installation method based on Table 4A2							
T4 XLPE / SWA / PVC Cable				6 Separate CPC to be same csa as Line							
T5 XLPE / LS0H Flat Twin & Earth Cable				Conductor							
T6 As T1 Plus 4mm ² Separate CPC				7 B Fitted blank							

Reference : DB-02-37				Location : 02-073 Circulation Space 1 Elec Riser							
Science Lab				Serving : Science Lab Classrooms							
125 A Sw/Discon											
8 Way				Incoming Cable		Reference : F11					
TP&N				Cable Size : Refer To Cable Schedule (50mm2 Multicore XLPE/SWA/LS0H)							
				Type Note 3	Load (Watts)			Serving	Cable csa (mm²)	Cable Type Note 2	Install Method No. See Note 5
Way	Line	In	lb	P	L1	L2	L3				
	L1	20		P2				02-056 Science Lab 7 Radial Circuit BM contactor cct1	4	T5	31, 5
1	L2	20		P2				02-077 Science Lab 2 Specialist Radial Circuit Teachers Wall	4	T5	31, 5
	L3	20		P2				02-055 Science Lab 2 Radial Circuit contactor cct 2	4	T5	31, 5
	L1	20		P2				SPARE	-	-	-
2	L2	20		P2				02-078 Science Lab 8 Radial Circuit Teachers Wall	4	T5	31, 5
	L3	20		P2				02-055 Science Lab 2 Radial Circuit Teachers Wall	4	T5	31, 5
	L1	20		P2				02-056 Science Lab 7 Radial Circuit Teachers Wall	4	T5	31, 5
3	L2	20		P2				SPARE	-	-	-
	L3	20		P2				02-057 Science Lab 10 Radial Circuit contactor cct 3	4	T5	31, 5
	L1	-		B				-	-	-	-
4	L2	20		P2				02-053 Science Lab 5 Radial Circuit Teachers Wall	4	T5	31, 5
	L3	20		P2				02-057 Science Lab 10 Radial Circuit Teachers Wall	4	T5	31, 5
	L1	-		B				-	-	-	-
5	L2	20		P2				02-077 Science Lab Specialist 2 Radial Circuit BM Contactor cct 4	4	T5	31, 5
	L3	20		P2				02-052 Science Lab 3 Radial Circuit Teachers Wall	4	T5	31, 5
	L1	-		B				-	-	-	-
6	L2	20		P2				02-078 Science Lab 8 Radial Circuit BM Contactor cct 5	4	T5	31, 5
	L3	20		P2				02-052 Science Lab 3 Radial Circuit contactor cct 6	4	T5	31, 5
	L1	-		B				-	-	-	-
7	L2	20		P2				02-053 Science Lab 5 Radial Circuit BM contactor cct 7	4	T5	31, 5
	L3	-		B				-	-	-	-
	L1			B							
8	L2			B							
	L3			B							
Total Phase Loading								Watts 3	Protective Device		
								Amps	P1 - MCB Curve Type C		
									P2 - RCBO (Type A unless stated otherwise)		
									P3 - MCB / Fuse with separate 30 mA RCD		
									P4 - HRC		
									P5 - MCB Type User Defined		
									4 Loads noted for Ring Circuits [RC] are nominal		
									5 Installation method based on Table 4A2		
									6 Separate CPC to be same csa as Line		
									Conductor		
									7 B Fitted blank		
Notes											
1 Fitted with Integral Incoming Switch											
2 Cable Types-Legend											
T1 LS0H Single Core Cables in Conduit / Trunking											
T2 XLPE / SWA / LS0H Cable											
T3 MICC / LSF Cables											
T4 XLPE / SWA / PVC Cable											
T5 XLPE / LS0H Flat Twin & Earth Cable											
T6 As T1 Plus 4mm² Separate CPC											

All highlighted circuits are separate contactor control

Reference : DB-02-41				Location : 02-060 Circulation Space 1 Elec Riser							
Science Lab				Serving : Science Lab Classrooms							
160A Sw/Discon				Incoming Cable							
8 Way				Reference : F16							
TP&N				Cable Size : Refer To Cable Schedule (70mm2 Multicore XLPE/SWA/LS0H)							
				Type Note 3	Load (Watts)			Serving	Cable csa (mm²)	Cable Type Note 2	Install Method No. See Note 5
Way	Line	In	lb	P	L1	L2	L3				
	L1	20		P2				SPARE	-	-	-
1	L2	20		P2				SPARE	-	-	-
	L3	20		P2				SPARE	-	-	-
	L1	-		B				-	-	-	-
2	L2	-		B				-	-	-	-
	L3	-		B				-	-	-	-
	L1	20		P2				02-064 Science Lab 1 BM Radial Circuit contactor cct 8	4	T5	31, 5
3	L2	20		P2				02-062 Science Lab 6 BM Radial Circuit contactor cct 9	4	T5	31, 5
	L3	20		P2				02-070 Science Lab 4 BM Radial Circuit contactor cct 10	4	T5	31, 5
	L1	-		B				-	-	-	-
4	L2	20		P2				02-062 Science Lab 6 Teachers Wall	4	T5	31, 5
	L3	20		P2				02-066 Science Lab specialist 1 BM Radial Circuit contactor cct 11	4	T5	31, 5
	L1	20		P2				02-064 Science Lab 1 Teachers Wall	4	T5	31, 5
5	L2	20		P2				02-072 Science Lab 9 BM Radial Circuit contactor cct 12	4	T5	31, 5
	L3	20		P2				02-066 Science Lab specialist 1 Teachers Wall	4	T5	31, 5
	L1	-		B				-	-	-	-
6	L2	-		B				-	-	-	-
	L3	20		P2				02-070 Science Lab 4 Teachers Wall	4	T5	31, 5
	L1			B				-	-	-	-
7	L2	20		P2				02-072 Science Lab 9 Teachers Wall	4	T5	31, 5
	L3	20		P2				02-058 Science Prep Room Central 1 Radial 01 contactor cct 13	4	T5	31, 5
	L1	20		P2				SPARE	-	-	-
8	L2	-		B				-	-	-	-
	L3	20		P2				02-058 Science Prep Room Central 1 Radial 02	4	T5	31, 5
Total Phase Loading								Watts 3	Protective Device		
								Amps	P1 - MCB Curve Type C		
									P2 - RCBO (Type A unless stated otherwise)		
									P3 - MCB / Fuse with separate 30 mA RCD		
									P4 - HRC		
									P5 - MCB Type User Defined		
									4 Loads noted for Ring Circuits [RC] are nominal		
									5 Installation method based on Table 4A2		
									6 Separate CPC to be same csa as Line		
									Conductor		
									7 B Fitted blank		
Notes											
1 Fitted with Integral Incoming Switch											
2 Cable Types-Legend											
T1 LS0H Single Core Cables in Conduit / Trunking											
T2 XLPE / SWA / LS0H Cable											
T3 MICC / LSF Cables											
T4 XLPE / SWA / PVC Cable											
T5 XLPE / LS0H Flat Twin & Earth Cable											
T6 As T1 Plus 4mm² Separate CPC											

All highlighted circuits are separate contactor control