



Anoopam Mission Crematorium

DISTRIBUTION BOARD SCHEDULES

DOCUMENT NO: 25057-RC-XX-XX-SH-E-00001

ISSUE DATE: 24.04.26

REVISION: C02

The Old Barns
85 Camden Street
Birmingham
B1 3DD
T: 0121 233 0474

Board Reference:			DB-01						
Location:			GROUND FLOOR PLANT ROOM						
Size, Type and Rating:			8+8 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
L-1/L1	10	C	30	NO	2	1.5	1.5	RAD	EXTERNAL LIGHTING
L-1/L2	10	C	30	NO	1	1.5	1.0	RAD	CREMATORY MEZZ LEVEL LIGHTING
L-1/L3	10	C	30	NO	5	1.5	1.5	RAD	PLANT ROOM LIGHTING
L-2/L1	10	C	30	NO	1	1.5	1.0	RAD	CREMATORY LIGHTING
L-2/L2	10	C	30	NO	1	1.5	1.0	RAD	CREMATORY LIGHTING
L-2/L3	10	C	30	NO	1	1.5	1.0	RAD	CREMATORY LIGHTING
L-3/L1	10	C	30	NO	1	1.5	1.0	RAD	COMMITAL ROOM 2
L-3/L2	10	C	30	NO	1	1.5	1.0	RAD	COMMITAL ROOM 3
L-3/L3	10	C	30	NO	1	1.5	1.0	RAD	COMMITAL ROOM 1
L-4/L1	-	-	-	-	-	-	-	-	SPARE
L-4/L2	-	-	-	-	-	-	-	-	SPARE
L-4/L3	-	-	-	-	-	-	-	-	SPARE
L-5/L1	-	-	-	-	-	-	-	-	SPARE
L-5/L2	-	-	-	-	-	-	-	-	SPARE
L-5/L3	-	-	-	-	-	-	-	-	SPARE
L-6/L1	-	-	-	-	-	-	-	-	SPARE
L-6/L2	-	-	-	-	-	-	-	-	SPARE
L-6/L3	-	-	-	-	-	-	-	-	SPARE
L-7/L1	-	-	-	-	-	-	-	-	SPARE
L-7/L2	-	-	-	-	-	-	-	-	SPARE
L-7/L3	-	-	-	-	-	-	-	-	SPARE
L-8/L1	-	-	-	-	-	-	-	-	SPARE
L-8/L2	-	-	-	-	-	-	-	-	SPARE
L-8/L3	-	-	-	-	-	-	-	-	SPARE
METERING SPLIT									

Board Reference:			DB-01						
Location:			GROUND FLOOR PLANT ROOM						
Size, Type and Rating:			8+8 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
P-1/L1	16	C 1	30	NO	1	2.5	1.5	RAD	COMMITAL ROOMS – VRF SYSTEMS
P-1/L2	20	C 1	30	NO	1	2.5	1.5	RAD	CREMATORY CLEANERS SOCKETS
P-1/L3	32	C 1	30	NO	5	4.0	4.0	RING	PLANT ROOM
P-2/L1	16	C 2	30	NO	1	2.5	1.5	RAD	COMMITAL ROOMS – COND PUMPS
P-2/L2	16	C 1	-	NO	1	2.5	1.5	RAD	ASH TRANSFER CABINET
P-2/L3	16	C 3	30	NO	1	2.5	1.5	RAD	PLANT ROOM – VRF BC BOX
P-3/L1	16	C 2	-	NO	1	2.5	1.5	RAD	HIGH SPEED CREMULATOR
P-3/L2	32	C 4	30	NO	1	4.0	4.0	RING	MEZZANINE LEVEL
P-3/L3	16	C 5	30	NO	5	2.5	2.5	RAD	PLANT ROOM – MIKROFILL UNIT
P-4/L1									
P-4/L2	20	C	-	NO	2	2.5	SWA	RAD	ROOF – VRF EXTERNAL CONDENSOR
P-4/L3									
P-5/L1	32	C 2	30	NO	1	4.0	4.0	RING	CREMATORY SOCKETS
P-5/L2	16	C 6	30	NO	1	2.5	1.5	RAD	AV TOUCH PLATE
P-5/L3	20	C 2	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-6/L1	-	-	-	-	-	-	-	-	SPARE
P-6/L2	-	-	-	-	-	-	-	-	SPARE
P-6/L3	-	-	-	-	-	-	-	-	SPARE
P-7/L1	-	-	-	-	-	-	-	-	SPARE
P-7/L2	-	-	-	-	-	-	-	-	SPARE
P-7/L3	-	-	-	-	-	-	-	-	SPARE
P-8/L1	TO BE CONFIRMED BY MANUFACTURER							TYPE 2 SPD	
P-8/L2									
P-8/L3									

CABLE TYPE CODES:

1 – LS0H Multi Flat; **2** – Cu XLPE/SWA/LS0H Armoured; **3** – Cu XLPE/LS0H Soft Skin Fire Rated PH120; **4** – Cu XLPE/SWA/LS0H Armoured Fire Rated F120; **5** – LS0H CU Singles

Board Reference:			DB-02						
Location:			GROUND FLOOR MAIN STORE ROOM						
Size, Type and Rating:			8+14 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
L-1/L1	10	C	30	NO	1	1.5	1.0	RAD	RECEPTION, COLLECTION, DIS. WC LTG
L-1/L2	10	C	30	NO	1	1.5	1.0	RAD	STORE, AV RM, ASHES & CELEBRANT RMS
L-1/L3	10	C	30	NO	1	1.5	1.0	RAD	CIRC, CELEBRANT, WC'S AND SHOWER
L-2/L1	10	C	30	NO	1	1.5	1.0	RAD	OFFICE, MEETING RM & KITCHEN LTG
L-2/L2	10	C	30	NO	1	2.5	1.5	RAD	BOH CORRIDOR LIGHTING
L-2/L3	10	C	30	NO	1	2.5	1.5	RAD	BOH CORRIDOR LIGHTING
L-3/L1	10	C	30	NO	1	2.5	1.5	RAD	BOH CORRIDOR LIGHTING
L-3/L2	10	C	30	NO	1	2.5	1.5	RAD	MAIN CEREMONIAL HALL
L-3/L3	10	C	30	NO	1	2.5	1.5	RAD	MAIN CEREMONIAL HALL
L-4/L1	10	C	30	NO	1	2.5	1.5	RAD	MAIN CEREMONIAL HALL
L-4/L2	10	C	30	NO	1	2.5	1.5	RAD	MAIN CEREMONIAL HALL
L-4/L3	10	C	30	NO	1	2.5	1.5	RAD	MAIN CEREMONIAL HALL
L-5/L1	10	C	30	NO	1	2.5	1.5	RAD	MAIN CEREMONIAL HALL
L-5/L2	10	C	30	NO	2	1.5	1.5	RAD	EXTERNAL LIGHTING 14
L-5/L3	-	-	-	-	-	-	-	-	SPARE
L-6/L1	-	-	-	-	-	-	-	-	SPARE
L-6/L2	-	-	-	-	-	-	-	-	SPARE
L-6/L3	-	-	-	-	-	-	-	-	SPARE
L-7/L1	-	-	-	-	-	-	-	-	SPARE
L-7/L2	-	-	-	-	-	-	-	-	SPARE
L-7/L3	-	-	-	-	-	-	-	-	SPARE
L-8/L1	-	-	-	-	-	-	-	-	SPARE
L-8/L2	-	-	-	-	-	-	-	-	SPARE
L-8/L3	-	-	-	-	-	-	-	-	SPARE
METERING SPLIT									

Board Reference:			DB-02						
Location:			GROUND FLOOR MAIN STORE ROOM						
Size, Type and Rating:			8+14 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
P-1/L1	32	1 C	30	NO	1	4.0	1.5	RING	RECEPTION & COLLECTION
P-1/L2	32	2 C	30	NO	1	4.0	1.5	RING	OFFICE
P-1/L3	32	3 C	30	NO	1	4.0	1.5	RING	MEETING ROOM INCLUDING FLOOR BOX
P-2/L1	32	4 C	30	NO	1	4.0	1.5	RING	KITCHEN
P-2/L2	32	5 C	30	NO	1	4.0	1.5	RING	CELEBRANT ROOM 2
P-2/L3	32	6 C	30	NO	1	4.0	1.5	RING	CELEBRANT ROOM 1
P-3/L1	32	7 C	30	NO	1	4.0	1.5	RING	STORE & ASHES ROOM
P-3/L2	32	8 C	30	NO	1	4.0	1.5	RING	MAIN CEREMONIAL HALL
P-3/L3	32	9 C	30	NO	1	4.0	1.5	RING	MAIN CEREMONIAL HALL
P-4/L1	16	1 C	30	NO	1	2.5	1.5	RAD	BOH CORRIDOR DOOR HOLD BACKS
P-4/L2	16	2 C	30	NO	1	2.5	1.5	RAD	VRF SYSTEMS
P-4/L3	20	1 C	30	NO	1	2.5	1.5	RAD	ACCESS CONTROL – DOOR CONTROLLERS
P-5/L1	16	3 C	30	NO	1	2.5	1.5	RAD	DIS WC – HAND DRYER
P-5/L2	16	4 C	30	NO	1	2.5	1.5	RAD	UFH – MANIFOLD No. 7
P-5/L3	16	5 C	30	NO	1	2.5	1.5	RAD	STORE – LIGHTING CONTROL PANEL
P-6/L1	16	6 C	30	NO	1	2.5	1.5	RAD	RECEPTION – AUTOMATIC DOOR
P-6/L2	20	2 C	30	NO	1	2.5	1.5	RAD	ACCESS CONTROL – DOOR CONTROLLERS
P-6/L3	16	7 C	30	NO	1	2.5	1.5	RAD	STORE – ACCESS CONTROL PANEL
P-7/L1	20	3 C	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-7/L2	16	8 C	30	NO	1	2.5	1.5	RAD	STORE – INTRUDER ALARM PANEL
P-7/L3	20	4 C	30	NO	1	2.5	1.5	RAD	WC R1 & R2 – HAND DRYERS
P-8/L1	32	10 C	30	NO	1	4.0	1.5	RING	MAIN CEREMONIAL HALL – LECTERN FB
P-8/L2	20	5 C	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-8/L3	20	6 C	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-9/L1	32	11 C	30	NO	1	4.0	1.5	RING	CLEANERS SOCKETS

Board Reference:			DB-02						
Location:			GROUND FLOOR MAIN STORE ROOM						
Size, Type and Rating:			8+14 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm²)	CPC (mm²/SWA)	Circuit Configuration	Duty
P-9/L2	32	I ₂ C	30	NO	1	4.0	1.5	RING	MAIN CEREMONIAL HALL – LECTERN FB
P-9/L3	16	I C	30	NO	1	2.5	1.5	RAD	MAIN HALL – INDUCTION LOOP
P-10/L1	32	I ₃ C	30	NO	1	4.0	1.5	RING	CLEANERS SOCKETS
P-10/L2	-	-	-	-	-	-	-	-	SPARE
P-10/L3	20	I C	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-11/L1	-	-	-	-	-	-	-	-	SPARE
P-11/L2	-	-	-	-	-	-	-	-	SPARE
P-11/L3	-	-	-	-	-	-	-	-	SPARE
P-12/L1	-	-	-	-	-	-	-	-	SPARE
P-12/L2	-	-	-	-	-	-	-	-	SPARE
P-12/L3	-	-	-	-	-	-	-	-	SPARE
P-13/L1	-	-	-	-	-	-	-	-	SPARE
P-13/L2	-	-	-	-	-	-	-	-	SPARE
P-13/L3	-	-	-	-	-	-	-	-	SPARE
P-14/L1	TO BE CONFIRMED BY MANUFACTURER							TYPE 2 SPD	
P-14/L2									
P-14/L3									

CABLE TYPE CODES:

1 – LS0H Multi Flat; 2 – Cu XLPE/SWA/LS0H Armoured; 3 – Cu XLPE/LS0H Soft Skin Fire Rated PH120; 4 – Cu XLPE/SWA/LS0H Armoured Fire Rated F120; 5 – LS0H CU Singles

Board Reference:			DB-03						
Location:			GROUND FLOOR WAITING ROOM FOYER No.2 – ELECTRICAL CUPBOARD						
Size, Type and Rating:			8+14 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
L-1/L1	10	C	30	NO	1	1.5	1.0	RAD	PROCESSION CORRIDOR 2
L-1/L2	10	C	30	NO	1	1.5	1.0	RAD	PROCESSION CORRIDOR 1
L-1/L3	10	C	30	NO	1	2.5	1.5	RAD	PRIVATE CEREMONIAL SPACE 2
L-2/L1	10	C	30	NO	1	2.5	1.5	RAD	PRIVATE CEREMONIAL SPACE 1
L-2/L2	10	C	30	NO	1	1.5	1.0	RAD	SHRINE
L-2/L3	10	C	30	NO	1	1.5	1.0	RAD	WAITING ROOM FOYER 2
L-3/L1	10	C	30	NO	1	1.5	1.0	RAD	WAITING ROOM FOYER 2
L-3/L2	10	C	30	NO	1	1.5	1.0	RAD	WAITING ROOM FOYER 1
L-3/L3	10	C	30	NO	1	1.5	1.0	RAD	WAITING ROOM FOYER 1
L-4/L1	10	C	30	NO	1	1.5	1.0	RAD	MALE WC'S AND CIRCULATION
L-4/L2	10	C	30	NO	1	1.5	1.0	RAD	FEMALE WC'S & DISABLED WC
L-4/L3	10	C	30	NO	2	1.5	1.5	RAD	EXTERNAL LIGHTING
L-5/L1	10	C	30	NO	2	1.5	1.5	RAD	EXTERNAL LIGHTING
L-5/L2	-	-	-	-	-	-	-	-	SPARE
L-5/L3	-	-	-	-	-	-	-	-	SPARE
L-6/L1	-	-	-	-	-	-	-	-	SPARE
L-6/L2	-	-	-	-	-	-	-	-	SPARE
L-6/L3	-	-	-	-	-	-	-	-	SPARE
L-7/L1	-	-	-	-	-	-	-	-	SPARE
L-7/L2	-	-	-	-	-	-	-	-	SPARE
L-7/L3	-	-	-	-	-	-	-	-	SPARE
L-8/L1	-	-	-	-	-	-	-	-	SPARE
L-8/L2	-	-	-	-	-	-	-	-	SPARE
L-8/L3	-	-	-	-	-	-	-	-	SPARE
METERING SPLIT									

Board Reference:			DB-03						
Location:			GROUND FLOOR WAITING ROOM FOYER No.2 – ELECTRICAL CUPBOARD						
Size, Type and Rating:			8+14 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
P-1/L1	32	C 1	30	NO	1	4.0	1.5	RING	WAITING ROOM FOYER 2
P-1/L2	32	C 2	30	NO	1	4.0	1.5	RING	WAITING ROOM FOYER 1
P-1/L3	32	C 3	30	NO	1	4.0	1.5	RING	AV BOOTH
P-2/L1	32	C 4	30	NO	1	4.0	1.5	RING	SHRINE
P-2/L2	16	C 1	30	NO	1	2.5	1.5	RAD	AV SYSTEM TOUCH PLATE – PC1
P-2/L3	16	C 2	30	NO	1	2.5	1.5	RAD	INTRUDER ALARM EXTENDER
P-3/L1	20	C 1	30	NO	1	2.5	1.5	RAD	MALE WC'S – HAND DRYERS
P-3/L2	20	C 2	30	NO	1	2.5	1.5	RAD	FEMALE WC'S – HAND DRYERS
P-3/L3	20	C 3	30	NO	1	2.5	1.5	RAD	DISABLED WC'S – HAND DRYERS
P-4/L1	16	C 3	30	NO	1	2.5	1.5	RAD	UFH – MANIFOLD No. 1
P-4/L2	16	C 4	30	NO	1	2.5	1.5	RAD	UFH – MANIFOLD No. 2 & 3
P-4/L3	16	C 5	30	NO	1	2.5	1.5	RAD	UFH – MANIFOLD No. 4 & 5
P-5/L1	16	C 6	30	NO	1	2.5	1.5	RAD	UFH – MANIFOLD No. 6
P-5/L2	16	C 7	30	NO	1	2.5	1.5	RAD	MAIN HALL – ASPIRATION SYSTEM
P-5/L3	16	C 8	30	NO	1	2.5	1.5	RAD	MAIN HALL – ASPIRATION SYSTEM
P-6/L1	32	C 5	30	NO	1	4.0	1.5	RING	MAIN CEREMONIAL HALL
P-6/L2	32	C 6	30	NO	1	4.0	1.5	RING	MAIN CEREMONIAL HALL
P-6/L3	20	C 4	30	NO	1	2.5	1.5	RAD	STORE 2 - SOCKET & WASH - EXTRACT FAN
P-7/L1	20	C 5	30	NO	1	2.5	1.5	RAD	STORE 1 - SOCKET & WASH - EXTRACT FAN
P-7/L2	16	C 9	30	NO	4	2.5	2.5	RAD	FIRE ALARM REPEATER PANEL
P-7/L3	32	C 7	30	NO	1	4.0	1.5	RING	AV BOOTH
P-8/L1	20	C 6	30	NO	1	2.5	1.5	RAD	AV RACK – COMMANDO SOCKETS
P-8/L2	16	C 10	30	NO	1	2.5	1.5	RAD	AV SYSTEM TOUCH PLATE – PC2
P-8/L3	20	C 7	30	NO	1	2.5	1.5	RAD	AV RACK – COMMANDO SOCKETS
P-9/L1	16	C 11	30	NO	1	2.5	1.5	RAD	WASHROOM 2 – HAND DRYER

Board Reference:			DB-03						
Location:			GROUND FLOOR WAITING ROOM FOYER No.2 – ELECTRICAL CUPBOARD						
Size, Type and Rating:			8+14 WAY TP&N SPLIT METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
P-9/L2	16	C 12	30	NO	1	2.5	1.5	RAD	WASHROOM 1 – HAND DRYER
P-9/L3	20	C 8	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-10/L1	20	C 9	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-10/L2	20	C 6	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-10/L3	20	C 11	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-11/L1	20	C 12	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-11/L2	-	-	-	-	-	-	-	-	SPARE
P-11/L3	20	C 13	30	NO	1	2.5	1.5	RAD	CLEANERS SOCKETS
P-12/L1	-	-	-	-	-	-	-	-	SPARE
P-12/L2	-	-	-	-	-	-	-	-	SPARE
P-12/L3	-	-	-	-	-	-	-	-	SPARE
P-13/L1	-	-	-	-	-	-	-	-	SPARE
P-13/L2	-	-	-	-	-	-	-	-	SPARE
P-13/L3	-	-	-	-	-	-	-	-	SPARE
P-14/L1	TO BE CONFIRMED BY MANUFACTURER							TYPE 2 SPD	
P-14/L2									
P-14/L3									

CABLE TYPE CODES:

1 – LS0H Multi Flat; **2** – Cu XLPE/SWA/LS0H Armoured; **3** – Cu XLPE/LS0H Soft Skin Fire Rated PH120; **4** – Cu XLPE/SWA/LS0H Armoured Fire Rated F120; **5** – LS0H CU Singles

Board Reference:			DB-AV						
Location:			GROUND FLOOR AV ROOM						
Size, Type and Rating:			12 WAY SP&N SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
CCT 1	32 ₁	C	30	NO	1	4.0	1.5	RING	AV ROOM
CCT 2	32 ₂	C	30	NO	1	4.0	1.5	RING	AV ROOM
CCT 3	16	C	30	NO	1	2.5	1.5	RAD	AMPLIFIER
CCT 4	32 ₃	C	30	NO	1	4.0	1.5	RAD	DATA CABINET – COMMANDO SOCKETS
CCT 5	10	C	30	NO	1	2.5	1.5	RAD	VRF WALL UNIT – AV ROOM
CCT 6	32 ₄	C	30	NO	1	4.0	1.5	RAD	DATA CABINET – COMMANDO SOCKETS
CCT 7	32 ₅	C	30	NO	1	4.0	1.5	RAD	DATA CABINET – COMMANDO SOCKETS
CCT 8	-	-	-	-	-	-	-	-	SPARE
CCT 9	-	-	-	-	-	-	-	-	SPARE
CCT 10	-	-	-	-	-	-	-	-	SPARE
CCT 11	-	-	-	-	-	-	-	-	SPARE
CCT 12	TO BE CONFIRMED BY MANUFACTURER								TYPE 2 SPD

CABLE TYPE CODES:

1 –LS0H Multi Flat; **2** – Cu XLPE/SWA/LS0H Armoured; **3** – Cu XLPE/LS0H Soft Skin Fire Rated PH120; **4** – Cu XLPE/SWA/LS0H Armoured Fire Rated F120; **5** – LS0H CU Singles

Board Reference:			DB-MECH						
Location:			GROUND FLOOR PLANT ROOM						
Size, Type and Rating:			18 WAY TP&N 250A RATED METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm²)	CPC (mm²/SWA)	Circuit Configuration	Duty
1/L1	-	-	-	-	-	-	-	-	SPARE
1/L2	32	C ₁	-	NO	2	10.0	10.0	RAD	AHU 01 – CONDENSOR - ROOF
1/L3	32	C ₂	-	NO	2	6.0	6.0	RAD	AHU 03a – CONDENSOR - ROOF
2/L1	32	C ₃	-	NO	2	6.0	6.0	RAD	AHU 04a – CONDENSOR - ROOF
2/L2	32	C ₄	-	NO	2	10.0	10.0	RAD	AHU 02 – CONDENSOR - ROOF
2/L3	32	C ₅	-	NO	2	6.0	6.0	RAD	AHU 03b – CONDENSOR - ROOF
3/L1	32	C ₆	-	NO	2	6.0	6.0	RAD	AHU 04b – CONDENSOR - ROOF
3/L2	32	C ₁	30	NO	5	10.0	6.0	RAD	PLANT ROOM – BOOSTER SET
3/L3	16	C ₁	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 1
4/L1	16	C ₁	-	NO	2	6.0	SWA	RAD	AHU 01 - ROOF
4/L2									
4/L3									
5/L1	16	C ₂	-	NO	2	6.0	SWA	RAD	AHU 02 - ROOF
5/L2									
5/L3									
6/L1	16	C ₃	-	NO	2	2.5	SWA	RAD	AHU 03 - MEZZANINE
6/L2									
6/L3									
7/L1	16	C ₄	-	NO	2	2.5	SWA	RAD	AHU 04 - MEZZANINE
7/L2									
7/L3									
8/L1	-	-	-	-	-	-	-	-	SPARE
8/L2	16	C ₁	-	NO	2	2.5	SWA	RAD	AHU 05 - ROOF
8/L3	16	C ₂	-	NO	2	2.5	SWA	RAD	AHU 05 - ROOF

Board Reference:			DB-MECH						
Location:			GROUND FLOOR PLANT ROOM						
Size, Type and Rating:			18 WAY TP&N 250A RATED METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
9/L1	-	-	-	-	-	-	-	-	SPARE
9/L2	-	-	-	-	-	-	-	-	SPARE
9/L3	-	-	-	-	-	-	-	-	SPARE
10/L1	16	C 2	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 5
10/L2	16	C 3	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 3
10/L3	16	C 4	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 2
11/L1	16	C 5	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 6
11/L2	16	C 6	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 4a
11/L3	-	-	-	-	-	-	-	-	SPARE
12/L1	16	C 7	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 7
12/L2	16	C 8	30	NO	5	2.5	2.5	RAD	PLANT ROOM – PUMPSET 4b
12/L3	-	-	-	-	-	-	-	-	SPARE
13/L1	63	C	30	NO	5	16.0	16.0	RAD	BMS PANEL
13/L2									
13/L3									
14/L1	-	-	-	-	-	-	-	-	SPARE
14/L2	-	-	-	-	-	-	-	-	SPARE
14/L3	-	-	-	-	-	-	-	-	SPARE
15/L1	-	-	-	-	-	-	-	-	SPARE
15/L2	-	-	-	-	-	-	-	-	SPARE
15/L3	-	-	-	-	-	-	-	-	SPARE
16/L1	-	-	-	-	-	-	-	-	SPARE
16/L2	-	-	-	-	-	-	-	-	SPARE
16/L3	-	-	-	-	-	-	-	-	SPARE
17/L1	-	-	-	-	-	-	-	-	SPARE

Board Reference:			DB-MECH						
Location:			GROUND FLOOR PLANT ROOM						
Size, Type and Rating:			18 WAY TP&N 250A RATED METERED SCHNEIDER ACTI 9 DISTRIBUTION BOARD						
CIRCUIT INFORMATION									
Way No.	MCB/RCBO Rating (A)	Trip Curve	RCD/RCBO Rating (mA)	Arc Fault Detection	Cable Type	Phase & Neutral (mm ²)	CPC (mm ² /SWA)	Circuit Configuration	Duty
17/L2	-	-	-	-	-	-	-	-	SPARE
17/L3	-	-	-	-	-	-	-	-	SPARE
18/L1	TO BE CONFIRMED BY MANUFACTURER								TYPE 2 SPD
18/L2									
18/L3									

CABLE TYPE CODES:

1 –LS0H Multi Flat; **2** – Cu XLPE/SWA/LS0H Armoured; **3** – Cu XLPE/LS0H Soft Skin Fire Rated PH120; **4** – Cu XLPE/SWA/LS0H Armoured Fire Rated F120; **5** – LS0H CU Singles