

EMERGENCY LIGHTS INSPECTION CHECKLIST

Frequency: Weekly (Every Saturday)

Floor/Unit: _____

Inspection Date: _____

Location	Start Time	Stop Time	Evaluation		Recommendation
			Pass	Fail	

Inspection Criteria:

"Push-button" test should be conducted by pressing the "test" button on the unit by holding it for 1 minute

If the device does not light, or the lamps are dim, or if it fails to light at full brilliance for 1 minute, the unit should be replaced.

Inspector's Name and Signature: _____

Noted by: _____

Confirmed by: _____