SMARTCAMPUS

Technical annex version 2

Nikos Georgiou - University of Athens

Baseline: 12 consecutive months before the pilot intervention.

Normalization: annual electricity use per square metre of floor area.

Collection: Sofia checks monthly meter totals and building floor areas.

Quality control: flag missing readings and confirm outliers with partners.

Update: addresses the reviewer request for period and normalization.