

TRADEPASS ACADEMY

309A COMPANION SERIES · VOLUME 6

Bonus Practice Questions

100 brand-new multiple-choice questions covering all 33 chapters of the Construction Electrician 309A curriculum, none repeated from the study guide, each with a full explanation.

- 100 original questions, verified against the book for zero repeats
- Organized by chapter, matching your study guide exactly
- Complete answer key with a plain-language explanation for every question
- Realistic exam-style wording and distractors
- Use as a fresh diagnostic after finishing the book's own practice tests

Companion resource to: Red Seal Construction Electrician 309A Exam Prep, 2026–2027 Edition

© 2026 TradePass Academy. For personal study use by the book owner. Not for redistribution.

TradePass Academy is an independent publisher and is not affiliated with the CCDA or the Red Seal Program.

Contents

In Microsoft Word, right-click this table and choose "Update Field" to refresh page numbers before exporting to PDF.

How to use this bonus set

These 100 questions are new material written specifically for this companion volume. They are not drawn from, and do not repeat, any question found in your Red Seal Construction Electrician 309A study guide, including its ten built-in practice tests. Use this set as a fresh, independent check after you have completed the book's own material.

The questions are organized to match your book's chapter structure, so you can work a chapter's bonus questions immediately after finishing that chapter, or complete the full 100-question set in one sitting as a final diagnostic before your exam date.

HOW TO SCORE YOURSELF

Answer every question before checking the key. Aim for roughly one minute per question if timing yourself, matching the pace expected on the real Red Seal exam. A score below 80% on any chapter's questions is a strong signal to revisit that chapter before moving on.

A NOTE ON CODE-DEPENDENT ANSWERS

A small number of questions reference specific Canadian Electrical Code section numbers or values for study convenience. The code is amended on a regular cycle and provinces adopt editions on their own schedule; always confirm current section numbers and values against the edition of the code in force for your examination.

Questions 1–100

Chapter 1: Introduction to the Trade, the Standard and Exam Strategy

1. The Red Seal Construction Electrician exam is built primarily from:
 - A. The most popular textbook on the trade
 - B. The Red Seal Occupational Standard for the trade
 - C. Each employer's internal training manual
 - D. The national building code alone
2. A Red Seal endorsement on a certificate of qualification means:
 - A. The holder can only work in the province of issue
 - B. The holder is recognized to work in that trade across Canada
 - C. The holder has completed an apprenticeship but not certification
 - D. The holder is exempt from provincial licensing

Chapter 2: Workplace Safety and the Control of Hazardous Energy

3. Under the hierarchy of controls, which measure is considered most effective?
 - A. Personal protective equipment
 - B. Administrative controls
 - C. Elimination of the hazard
 - D. Engineering controls
4. The correct sequence when applying lockout to a circuit is:
 - A. Lock, tag, isolate, test
 - B. Isolate, lock and tag, then test for zero energy
 - C. Test, isolate, lock and tag
 - D. Tag, test, isolate, lock
5. WHMIS 2015 primarily changed Canadian workplace chemical safety by:
 - A. Removing the need for safety data sheets
 - B. Aligning Canadian labels and SDS with the Globally Harmonized System
 - C. Making WHMIS training optional for certified trades
 - D. Replacing pictograms with text-only warnings
6. The purpose of the 'test before touch' step after lockout is to:
 - A. Confirm the lock itself is not damaged
 - B. Prove the circuit is actually de-energized, since a lock alone doesn't guarantee it
 - C. Satisfy a paperwork requirement only
 - D. Check that PPE is rated correctly

Chapter 3: Tools, Equipment, Access and Rigging

7. An insulated hand tool must be inspected before each use primarily to check for:
 - A. The manufacturer's warranty date
 - B. Damage or contamination to the insulating coating
 - C. Whether it matches the job's colour code

- D. Whether it has been calibrated that week
- 8. The key difference between fall restraint and fall arrest is that:
 - A. Restraint is only for ladders
 - B. Restraint prevents reaching the fall hazard; arrest stops a fall already underway
 - C. Arrest is used only indoors
 - D. They are two names for the same system

Chapter 4: Reading Drawings, Specifications and Organizing Work

- 9. A single-line diagram on an electrical drawing set primarily shows:
 - A. The physical floor layout of the building
 - B. The logical electrical connections and protection devices in schematic form
 - C. The finish schedule for each room
 - D. The HVAC ductwork routing
- 10. Electrical work typically falls under which MasterFormat division?
 - A. Division 03
 - B. Division 15
 - C. Division 22
 - D. Division 26

Chapter 5: Support Structures and Fastening Systems

- 11. The primary factor that determines a fastener's real-world holding capacity is:
 - A. The colour of the fastener
 - B. The base material it is installed into
 - C. The brand of the drill used to install it
 - D. The time of year it was installed
- 12. Seismic restraint on electrical equipment is primarily intended to:
 - A. Improve energy efficiency
 - B. Prevent equipment movement or falling during an earthquake
 - C. Reduce installation cost
 - D. Meet fire-rating requirements

Chapter 6: Commissioning and Decommissioning Electrical Systems

- 13. An insulation-resistance test is performed using a:
 - A. Clamp-on ammeter
 - B. Megohmmeter
 - C. Multimeter set to AC volts
 - D. Wattmeter
- 14. Functional testing during commissioning is distinct from an insulation test because it confirms:
 - A. The wiring colour coding is correct
 - B. The system operates correctly once energized, including sequencing and protection response
 - C. The building has received its occupancy permit

- D. The conductor sizes match the drawings

Chapter 7: Communication, Mentoring and Essential Skills

15. Clear jobsite communication is treated as a safety issue primarily because:

- A. It affects project cost tracking
- B. Misunderstood instructions near hazards can directly cause injury
- C. It is required for union membership
- D. It improves customer satisfaction scores

Chapter 8: Electrical Fundamentals, Ohm's Law, Power and DC Circuits

16. A series circuit contains a burned-out lamp among three identical lamps. The voltage measured across the burned-out lamp will be:

- A. Zero
- B. One-third of the source voltage
- C. The full source voltage
- D. Cannot be determined

17. Two 60-ohm resistors are connected in parallel. Their combined resistance is:

- A. 120 Ω
- B. 60 Ω
- C. 30 Ω
- D. 15 Ω

18. A circuit draws 8 A at 120 V. The power consumed is:

- A. 15 W
- B. 96 W
- C. 960 W
- D. 1500 W

19. A voltmeter must be connected to a component:

- A. In series, to read the full circuit current
- B. In parallel, since it has very high internal resistance
- C. In series, since it has very low internal resistance
- D. It can be connected either way with no difference

20. As more resistors are added in parallel to a circuit, total resistance:

- A. Increases
- B. Stays the same
- C. Decreases, always below the smallest branch
- D. Becomes infinite

21. A loose connection in an otherwise normal circuit tends to run hot because of:

- A. Reduced total circuit current
- B. I^2R heating concentrated at the point of added resistance
- C. A drop in system voltage
- D. Reversed current flow

Chapter 9: AC Theory, Single-Phase, Power Factor and Vector Reasoning

- 22.** The standard utility frequency in Canada is:
- A. 50 Hz
 - B. 60 Hz
 - C. 100 Hz
 - D. 400 Hz
- 23.** A voltage reads 208 V RMS on a meter. Its approximate peak value is:
- A. 147 V
 - B. 208 V
 - C. 294 V
 - D. 360 V
- 24.** As frequency increases, capacitive reactance:
- A. Increases proportionally
 - B. Stays constant
 - C. Decreases
 - D. Becomes infinite
- 25.** A load operates at 0.75 lagging power factor. This indicates the load is:
- A. Purely resistive
 - B. Predominantly capacitive
 - C. Predominantly inductive
 - D. Operating at unity
- 26.** Power-factor-correction capacitors are added to a system primarily to:
- A. Increase the true power delivered
 - B. Offset lagging (inductive) reactance and improve system efficiency
 - C. Convert AC to DC
 - D. Reduce system voltage
- 27.** In a purely inductive AC circuit, current:
- A. Leads voltage by 90 degrees
 - B. Lags voltage by 90 degrees
 - C. Is exactly in phase with voltage
 - D. Has no defined phase relationship

Chapter 10: Three-Phase Systems, Wye, Delta and Line-versus-Phase

- 28.** In a wye-connected system with a 120 V phase voltage, the line voltage is approximately:
- A. 120 V
 - B. 173 V
 - C. 208 V
 - D. 240 V
- 29.** A delta connection differs from a wye connection in that:
- A. Delta has a usable neutral point; wye does not

- B. Wye has a usable neutral point; delta does not
 - C. Both always have a neutral
 - D. Neither can be grounded
- 30.** To reverse the direction of rotation of a three-phase induction motor, you should:
- A. Reverse the neutral connection
 - B. Interchange any two of the three line conductors
 - C. Lower the supply frequency
 - D. Increase the supply voltage
- 31.** A balanced three-phase wye load, under ideal balanced conditions, has a neutral current that is:
- A. Equal to the phase current
 - B. Equal to the line current
 - C. Near zero
 - D. Always exactly double the phase current
- 32.** The $\sqrt{3}$ factor appears in three-phase formulas because:
- A. Of an arbitrary code requirement
 - B. It accounts for the 120-degree phase displacement between the three voltages
 - C. It compensates for conductor resistance
 - D. It only applies to delta systems

Chapter 11: Consumer and Supply Services and Metering

- 33.** A standard single-phase, three-wire residential service provides:
- A. Only 120 V
 - B. Only 240 V
 - C. Both 120 V and 240 V from the same service
 - D. Three-phase 208 V
- 34.** The neutral-to-ground bonding connection for a system is established:
- A. At every panelboard in the building
 - B. Once, at the service
 - C. At the utility transformer only
 - D. Nowhere; it is not required
- 35.** A utility revenue meter is typically installed:
- A. Downstream of the main disconnect only
 - B. Ahead of (upstream of) the main service disconnect
 - C. Only on three-phase services
 - D. Inside the panelboard itself

Chapter 12: Service and Feeder Load Calculations

- 36.** A continuous load, under the general 80% rule, must not exceed what percentage of the overcurrent device rating (absent a 100%-rated assembly)?
- A. 100%
 - B. 90%
 - C. 80%

- D. 70%
- 37.** The 'larger of' rule for heating and air conditioning loads in a calculation exists because:
- A. Heating always draws more current than cooling
 - B. The two loads rarely, if ever, operate simultaneously
 - C. Air conditioning is exempt from calculations
 - D. Both loads must always be added together
- 38.** Demand factors are applied in load calculations primarily to:
- A. Increase the calculated service size for safety margin
 - B. Reflect realistic simultaneous usage rather than full connected load
 - C. Simplify the arithmetic only
 - D. Comply with fire code, not electrical code
- 39.** A feeder, as distinct from a branch circuit, is best described as:
- A. The conductor set from a distribution point to a panelboard, not directly to the final load
 - B. Any conductor smaller than #10 AWG
 - C. A conductor used only outdoors
 - D. The conductor from a receptacle to an appliance
- 40.** Correctly classifying a load as continuous versus non-continuous matters chiefly because it determines:
- A. The wire colour required
 - B. Whether the 80% derating applies to sizing
 - C. Whether the load needs a disconnect
 - D. The panel's bus bar rating alone

Chapter 13: Overcurrent, Ground-Fault, Arc-Fault and Surge Protection

- 41.** The interrupting rating of an overcurrent protective device refers to:
- A. Its continuous current rating
 - B. The maximum fault current it can safely interrupt
 - C. Its physical size
 - D. How many times it can be reset
- 42.** A Class A GFCI is designed to open the circuit at a ground-fault current of approximately:
- A. 1 to 2 mA
 - B. 4 to 6 mA
 - C. 30 to 50 mA
 - D. 100 to 200 mA
- 43.** Arc-fault circuit interrupters are primarily designed to protect against:
- A. Overvoltage from lightning
 - B. Shock hazards from ground faults
 - C. Fire hazards from arcing conditions
 - D. Overloaded neutral conductors
- 44.** A key difference between a fuse and a circuit breaker is that a fuse:
- A. Can be reset after operating

- B. Is a single-use device that must be replaced after operating
 - C. Only works on DC circuits
 - D. Cannot provide short-circuit protection
- 45.** A surge protective device is intended to protect equipment from:
- A. Sustained overload currents
 - B. Transient overvoltages such as lightning or switching surges
 - C. Ground faults
 - D. Under-voltage conditions
- 46.** An overcurrent device's ampere rating, in general practice, should be selected to:
- A. Always exceed the conductor's ampacity for safety margin
 - B. Not exceed the conductor's ampacity, except where specific code exceptions apply
 - C. Match the load's nameplate current exactly regardless of conductor size
 - D. Be independent of the conductor size entirely

Chapter 14: Power Distribution Equipment

- 47.** The primary function of a panelboard is to:
- A. Generate emergency power
 - B. Receive feeder power and distribute it to protected branch circuits
 - C. Step transformer voltage up or down
 - D. Measure utility energy consumption
- 48.** A transfer switch in a standby generator system exists primarily to:
- A. Increase generator output voltage
 - B. Prevent the utility and generator sources from being connected simultaneously
 - C. Provide surge protection
 - D. Meter generator fuel consumption
- 49.** Working space requirements in front of electrical equipment exist to:
- A. Improve the equipment's appearance
 - B. Provide safe, unobstructed access for operation and service
 - C. Reduce arc-flash incident energy automatically
 - D. Meet aesthetic building code requirements

Chapter 15: Power Quality and Standby Systems

- 50.** Harmonic currents in a three-phase system can cause unexpectedly high current on the neutral because:
- A. The neutral is always undersized by code
 - B. Certain harmonic orders do not cancel at the neutral like balanced fundamental currents do
 - C. Harmonics only exist in single-phase systems
 - D. The neutral carries no current by design
- 51.** The key functional difference between a UPS and a standby generator is that a UPS provides:
- A. Longer duration backup power than a generator
 - B. Near-instant, short-duration backup to bridge the gap until other power is available
 - C. No real backup capability

- D. Power only for lighting circuits

Chapter 16: Bonding, Grounding and Lightning Protection

- 52.** The fundamental purpose of bonding, as distinct from grounding, is to:
- A. Connect the system to the earth for voltage reference
 - B. Provide a low-impedance path so fault current can operate the overcurrent device
 - C. Reduce the building's total electrical load
 - D. Improve power factor
- 53.** Neutral-to-bond connections in a properly wired system should occur:
- A. At every panelboard for redundancy
 - B. Only once, typically at the service
 - C. Only at the furthest point from the service
 - D. Nowhere; they must always remain isolated
- 54.** A ground-fault current in a typical building electrical system primarily returns to its source through:
- A. The soil itself, which has low impedance
 - B. A low-impedance bonded metallic path
 - C. The building's structural concrete only
 - D. There is no return path required

Chapter 17: Power Generation and Conversion

- 55.** An AC generator produces alternating voltage through the principle of:
- A. Chemical reaction
 - B. Electromagnetic induction from relative motion between field and conductor
 - C. Direct current commutation
 - D. Capacitive discharge
- 56.** Rectification refers to the conversion of:
- A. DC to AC
 - B. AC to DC
 - C. One AC frequency to another
 - D. One DC voltage to another DC voltage

Chapter 18: Renewable Energy and Energy Storage

- 57.** A photovoltaic solar cell generates electricity by:
- A. Electromagnetic induction
 - B. The photovoltaic effect, converting sunlight directly to DC
 - C. Burning a fuel source
 - D. Chemical reaction similar to a battery
- 58.** The hazard unique to solar photovoltaic arrays, compared to most other electrical equipment, is that:
- A. They only operate at night
 - B. They remain energized whenever exposed to light and cannot simply be switched off at the source
 - C. They generate no DC voltage

- D. They require no disconnecting means at all

Chapter 19: High-Voltage Systems

59. Under the Canadian Electrical Code, voltages exceeding approximately what threshold are generally classified as high voltage?

- A. 120 V
- B. 347 V
- C. 750 V
- D. 5000 V

60. Approach to energized high-voltage equipment typically requires:

- A. No special PPE beyond standard low-voltage gear
- B. Larger defined approach boundaries and often insulated tools such as hot sticks
- C. Only a visual inspection from outside the room
- D. The same procedures used for low-voltage equipment

Chapter 20: Transformers

61. A transformer's turns ratio directly determines the ratio between its:

- A. Primary and secondary current only
- B. Primary and secondary voltage
- C. Core losses and copper losses
- D. Interrupting rating and fault current

62. Transformers are rated in kVA rather than kW primarily because:

- A. kVA is easier to calculate
- B. Winding heating depends on current, which relates to kVA regardless of load power factor
- C. kW cannot be measured on transformers
- D. It is an arbitrary industry convention with no technical basis

63. An autotransformer differs from a standard two-winding transformer in that it:

- A. Provides full electrical isolation
- B. Uses a single shared winding and provides no electrical isolation
- C. Cannot step voltage down, only up
- D. Only functions on DC systems

64. Opening the secondary circuit of a current transformer while its primary is energized is dangerous because:

- A. It causes the primary to short circuit
- B. It has no effect; CTs are safe to open at any time
- C. The CT attempts to maintain ampere-turns balance and can develop very high secondary voltage
- D. It reduces the accuracy of downstream metering only

Chapter 21: Raceways, Conductors, Cables and Enclosures

65. The termination-temperature rule means that a conductor's usable ampacity may be limited by:

- A. Its insulation colour
- B. The lower temperature rating of its terminations, even if insulation is rated higher

- C. The manufacturer's warranty period
 - D. The conduit material only
- 66.** The general maximum conduit fill for three or more conductors is:
- A. 25%
 - B. 31%
 - C. 40%
 - D. 53%
- 67.** In a box fill calculation, a duplex receptacle typically counts as:
- A. One conductor volume allowance
 - B. Two conductor volume allowances
 - C. Zero, devices are not counted
 - D. Four conductor volume allowances
- 68.** Ampacity derating for conductor count in a raceway is required because:
- A. More conductors reduce voltage automatically
 - B. Heat from adjacent current-carrying conductors accumulates, reducing each conductor's safe capacity
 - C. It is purely a cost-control measure
 - D. Conduit fill and ampacity derating are unrelated concepts
- 69.** The key structural difference between a raceway and a cable is that:
- A. A raceway is a factory-assembled bundle of conductors; a cable is an empty channel
 - B. A cable is a factory-assembled unit with its own covering; a raceway is an enclosed channel conductors are pulled into
 - C. They are identical terms for the same product
 - D. Cables cannot be used indoors

Chapter 22: Branch Circuitry, Luminaires and Lighting Controls

- 70.** A branch circuit is best defined as the wiring between:
- A. The utility transformer and the service
 - B. The final overcurrent device and the connected outlets or equipment
 - C. Two panelboards in the same building
 - D. The meter and the main disconnect
- 71.** Dwelling receptacles are generally required to be tamper-resistant primarily to:
- A. Improve energy efficiency
 - B. Reduce the risk of injury from foreign objects being inserted, particularly by children
 - C. Increase the receptacle's current rating
 - D. Simplify installation
- 72.** A dimmer must be matched to its load type because:
- A. All dimmers work identically regardless of load
 - B. Mismatched dimming technology can cause flickering, humming, or premature failure
 - C. Dimmers only function with incandescent lamps
 - D. Load type has no bearing on dimmer compatibility

Chapter 23: HVAC Electrical Connections and Controls

73. On an HVAC nameplate, MOCP stands for and refers to:

- A. Minimum Operating Current Point; the lowest current the unit will draw
- B. Maximum Overcurrent Protection; the largest protective device size permitted
- C. Motor Overload Cutoff Point; a thermal protection setting only
- D. Maximum Output Current Peak; the surge current on startup

74. An HVAC unit's disconnecting means must generally be located within sight of the equipment or otherwise lockable because:

- A. It improves airflow around the unit
- B. It ensures a technician servicing the unit can be certain power cannot be re-energized during work
- C. It is required only for units over 5 tons
- D. It has no safety purpose, only a convenience purpose

Chapter 24: Electric Heating Systems and Controls

75. Sizing an electric heating circuit generally applies the continuous-load rule because heating loads typically:

- A. Operate for only a few minutes at a time
- B. Operate continuously for three hours or more
- C. Never actually draw their full rated current
- D. Are exempt from all sizing rules

76. A thermostat in an electric heating circuit functions to:

- A. Provide overcurrent protection
- B. Automatically cycle or modulate the heater based on sensed temperature
- C. Step down the supply voltage
- D. Replace the need for a disconnecting means

Chapter 25: Exit, Emergency and Life-Safety Lighting

77. Self-contained emergency lighting (unit equipment) must be electrically connected:

- A. Downstream of the local lighting switch so it can be turned off with the room lights
- B. Ahead of (unswitched by) any local lighting switch
- C. Only to a dedicated 600 V circuit
- D. It does not require a dedicated circuit connection

Chapter 26: Cathodic Protection Systems

78. An impressed-current cathodic protection system, compared to a sacrificial anode system, is distinguished by:

- A. Using no external power source at all
- B. Using an external power source (rectifier) to drive the protective current
- C. Only working on above-ground structures
- D. Requiring no electrician involvement

Chapter 27: Motor Starters and Control Devices

79. The key functional difference between a motor's power circuit and control circuit is that the control circuit:

- A. Carries the full motor running current
- B. Carries low-current signals that determine when the power circuit switches
- C. Requires no overcurrent protection at all
- D. Is only used on three-phase motors

80. Three-wire motor control, using a seal-in contact, is described as providing low-voltage protection because:

- A. It reduces the voltage supplied to the motor
- B. The circuit drops out on a power loss and will not automatically restart when power returns
- C. It only operates at voltages below 120 V
- D. It eliminates the need for overload protection

81. In standard motor control wiring practice, stop devices are wired:

- A. Normally open, in parallel
- B. Normally closed, in series
- C. Normally closed, in parallel
- D. Normally open, in series

82. An overload relay in a motor starter is specifically intended to protect against:

- A. Short-circuit currents
- B. Sustained overcurrent conditions on the motor itself
- C. Voltage surges from lightning
- D. Ground faults on the supply feeder

Chapter 28: AC and DC Drives

83. A variable-frequency drive controls motor speed primarily by:

- A. Switching motor poles mechanically
- B. Varying the frequency and voltage supplied to the motor
- C. Adding external resistance to the motor windings
- D. Changing the motor's physical gear ratio

84. A common installation concern introduced by variable-frequency drives is:

- A. Reduced motor torque at all speeds
- B. Electrical noise and harmonics on the supply system
- C. Complete elimination of motor current draw
- D. Inability to control motor direction

Chapter 29: Electric Motors

85. Slip in an induction motor is best described as:

- A. The motor's power factor
- B. The difference between synchronous speed and actual rotor speed, as a percentage
- C. The motor's starting current multiplier
- D. The ratio of horsepower to full-load current

- 86.** Three-phase induction motors are inherently self-starting because:
- A. They contain a starting capacitor by design
 - B. Their three-phase supply naturally creates a rotating magnetic field
 - C. They always start at reduced voltage
 - D. They use brushes to initiate rotation
- 87.** Single-phasing of a running three-phase motor is dangerous because it causes the motor to:
- A. Immediately stop with no damage
 - B. Draw excessive current on the remaining phases and overheat
 - C. Reverse its direction of rotation
 - D. Automatically disconnect itself safely
- 88.** Before performing an insulation-resistance test on a motor, the motor must be:
- A. Running at full speed
 - B. De-energized and isolated
 - C. Connected to a variable-frequency drive
 - D. Loaded to full nameplate current

Chapter 30: Automated and Programmable Control Systems

- 89.** The PLC scan cycle refers to the repeating process of:
- A. Physically scanning for wiring faults
 - B. Reading inputs, executing the control program, and updating outputs
 - C. Downloading new firmware automatically
 - D. Testing insulation resistance
- 90.** Critical safety stop functions in a PLC-controlled system are often still hard-wired, independent of the PLC program, because:
- A. Hard-wiring is always cheaper than programming
 - B. A hard-wired circuit provides a fail-safe path that functions even if the PLC or its program fails
 - C. PLCs cannot process stop signals at all
 - D. It is purely a historical convention with no safety basis

Chapter 31: Fire Alarm and Security Systems

- 91.** The key difference between a conventional and an addressable fire alarm system is that an addressable system:
- A. Cannot detect smoke, only heat
 - B. Identifies the exact individual device that triggered an alarm, not just a zone
 - C. Requires no control panel
 - D. Is only used in residential buildings
- 92.** An end-of-line resistor in a fire alarm circuit is used to:
- A. Reduce voltage at the final device only
 - B. Provide supervision, allowing detection of an open-circuit wiring fault
 - C. Boost the signal strength on long runs
 - D. Prevent false alarms from smoke detectors
- 93.** Class A fire alarm wiring differs from Class B in that Class A:

- A. Uses lower voltage throughout
- B. Loops back to the panel, so a single break does not disable devices beyond it
- C. Cannot be supervised for faults
- D. Is prohibited in commercial buildings

Chapter 32: Voice, Data and Communication Systems

- 94.** The main advantage of fibre-optic cable over copper for data transmission is that fibre:
- A. Is always cheaper to install
 - B. Offers greater bandwidth and distance, and is immune to electromagnetic interference
 - C. Can carry standard 120 V power directly
 - D. Requires no special termination equipment
- 95.** Power over Ethernet (PoE) allows a device such as an IP camera to:
- A. Receive both data and low-voltage DC power over the same cable
 - B. Operate without any network connection
 - C. Bypass the need for a fire alarm connection
 - D. Function only on fibre-optic cabling

Chapter 33: Building Automation and Integrated Control

- 96.** Communication protocols such as BACnet in a building automation system primarily serve to:
- A. Provide overcurrent protection for control wiring
 - B. Allow equipment from different manufacturers to communicate within the system
 - C. Replace the need for a fire alarm system
 - D. Eliminate the need for any wiring at all
- 97.** In a building automation system, lighting control is typically:
- A. Isolated entirely from other building systems
 - B. Integrated and coordinated with occupancy, daylight, and scheduling as part of the overall system
 - C. Only controllable through manual wall switches
 - D. Prohibited from being automated by code

Exam Toolkit: Cross-Reference and Terminology

- 98.** The Canadian Electrical Code section that generally governs grounding and bonding requirements is:
- A. Section 4
 - B. Section 6
 - C. Section 10
 - D. Section 28
- 99.** On a trade exam, when two answer options both appear technically plausible, the most reliable next step is to:
- A. Choose the longer-sounding option
 - B. Re-read the stem for a qualifying word that distinguishes the correct answer
 - C. Always choose option C by convention
 - D. Skip the question entirely and leave it blank

- 100.** Insulation resistance measured with a megohmmeter is typically expressed in units of:

- A. Milliamperes
- B. Kilovolts
- C. Megohms
- D. Microfarads

Answer Key & Explanations

Chapter 1: Introduction to the Trade, the Standard and Exam Strategy

ANSWER 1

Correct answer: B. The Red Seal Occupational Standard for the trade

Why: The Occupational Standard defines every task block and sub-task the exam draws from; it is the actual blueprint, and study material should map to it.

ANSWER 2

Correct answer: B. The holder is recognized to work in that trade across Canada

Why: The Red Seal is the interprovincial standard, allowing certified tradespeople to have their qualification recognized across Canada without rewriting a provincial exam.

Chapter 2: Workplace Safety and the Control of Hazardous Energy

ANSWER 3

Correct answer: C. Elimination of the hazard

Why: Elimination removes the hazard entirely and sits at the top of the hierarchy; PPE is the last and least reliable layer of protection.

ANSWER 4

Correct answer: B. Isolate, lock and tag, then test for zero energy

Why: Energy sources are isolated first, then locked and tagged, and only then tested to confirm zero energy — testing always comes last, never first.

ANSWER 5

Correct answer: B. Aligning Canadian labels and SDS with the Globally Harmonized System

Why: WHMIS 2015 harmonized Canada's system with the GHS, standardizing pictograms, label elements and the 16-section safety data sheet format used internationally.

ANSWER 6

Correct answer: B. Prove the circuit is actually de-energized, since a lock alone doesn't guarantee it

Why: A lock prevents re-energization but does not verify the circuit is dead; only a meter test, done correctly (test-verify-test), confirms zero energy.

Chapter 3: Tools, Equipment, Access and Rigging

ANSWER 7

Correct answer: B. Damage or contamination to the insulating coating

Why: The insulation rating only protects the user if the coating is intact; nicks, cuts or contamination can create a conductive path despite the tool's rated category.

ANSWER 8

Correct answer: B. Restraint prevents reaching the fall hazard; arrest stops a fall already underway

Why: Restraint systems physically prevent a worker from reaching a point where a fall could occur, while arrest systems are designed to safely stop a fall in progress.

Chapter 4: Reading Drawings, Specifications and Organizing Work

ANSWER 9

Correct answer: B. The logical electrical connections and protection devices in schematic form

Why: Single-line diagrams simplify a three-phase system into one line per circuit, showing how equipment, protection and distribution connect logically rather than physically.

ANSWER 10

Correct answer: D. Division 26

Why: MasterFormat Division 26 is designated for electrical work, giving a consistent location for electrical specifications across virtually all Canadian construction projects.

Chapter 5: Support Structures and Fastening Systems

ANSWER 11

Correct answer: B. The base material it is installed into

Why: The same fastener performs very differently in solid concrete versus hollow block or wood; base material is the dominant factor in actual holding capacity.

ANSWER 12

Correct answer: B. Prevent equipment movement or falling during an earthquake

Why: Seismic bracing keeps heavy or critical equipment from shifting or falling during seismic activity, protecting both the equipment and anyone or anything below it.

Chapter 6: Commissioning and Decommissioning Electrical Systems

ANSWER 13

Correct answer: B. Megohmmeter

Why: A megohmmeter (megger) applies a high test voltage to measure insulation resistance, which a standard multimeter or clamp meter cannot do.

ANSWER 14

Correct answer: B. The system operates correctly once energized, including sequencing and protection response

Why: Functional testing verifies operational behaviour under live conditions, which is a separate confirmation from insulation integrity or wiring correctness alone.

Chapter 7: Communication, Mentoring and Essential Skills

ANSWER 15

Correct answer: B. Misunderstood instructions near hazards can directly cause injury

Why: On an active jobsite, unclear or misunderstood communication near energized equipment, heights, or heavy loads can lead directly to an incident, making clarity a genuine safety control.

Chapter 8: Electrical Fundamentals, Ohm's Law, Power and DC Circuits

ANSWER 16

Correct answer: C. The full source voltage

Why: With no current flowing, there is no voltage drop across the two working lamps, so the entire source voltage appears across the open lamp.

ANSWER 17

Correct answer: C. 30 Ω

Why: For equal resistors in parallel, $R_T = R / n = 60 / 2 = 30 \Omega$.

ANSWER 18

Correct answer: C. 960 W

Why: $P = E \times I = 120 \times 8 = 960 \text{ W}$.

ANSWER 19

Correct answer: B. In parallel, since it has very high internal resistance

Why: A voltmeter's high internal resistance means it must be connected in parallel; placed in series it would block virtually all current flow.

ANSWER 20

Correct answer: C. Decreases, always below the smallest branch

Why: Adding parallel paths always provides more routes for current, so total resistance drops below the value of the smallest individual branch.

ANSWER 21

Correct answer: B. I^2R heating concentrated at the point of added resistance

Why: Even a small added resistance at a poor connection generates real heat through I^2R losses concentrated at that single point, which is why loose lugs are a common source of overheating.

Chapter 9: AC Theory, Single-Phase, Power Factor and Vector Reasoning

ANSWER 22

Correct answer: B. 60 Hz

Why: Canada, like the rest of North America, standardizes on 60 Hz utility frequency.

ANSWER 23

Correct answer: C. 294 V

Why: Peak = RMS x 1.414 = 208 x 1.414 is approximately 294 V.

ANSWER 24

Correct answer: C. Decreases

Why: $X_C = 1/(2\pi f C)$; as frequency rises, capacitive reactance falls, the opposite behaviour of inductive reactance.

ANSWER 25

Correct answer: C. Predominantly inductive

Why: A lagging power factor (current lagging voltage) is characteristic of inductive loads such as motors and transformers.

ANSWER 26

Correct answer: B. Offset lagging (inductive) reactance and improve system efficiency

Why: Capacitors supply leading reactive power that offsets the lagging reactive power from inductive loads, raising the power factor toward unity without changing true power delivered.

ANSWER 27

Correct answer: B. Lags voltage by 90 degrees

Why: By the ELI mnemonic, in an inductor voltage (E) leads current (I), meaning current lags voltage by 90 degrees.

Chapter 10: Three-Phase Systems, Wye, Delta and Line-versus-Phase

ANSWER 28

Correct answer: C. 208 V

Why: $E_L = E_{\text{phase}} \times \sqrt{3} = 120 \times 1.732$ is approximately 208 V, the familiar 120/208 V system.

ANSWER 29

Correct answer: B. Wye has a usable neutral point; delta does not

Why: A wye connection joins all three windings at a common point that can be brought out and grounded as a neutral; a closed delta loop has no such point.

ANSWER 30

Correct answer: B. Interchange any two of the three line conductors

Why: Swapping any two line conductors reverses the phase sequence feeding the motor, which reverses the direction of the rotating magnetic field and the motor's rotation.

ANSWER 31

Correct answer: C. Near zero

Why: In a perfectly balanced three-phase system, the vector sum of the three equal, 120-degree-displaced phase currents cancels almost entirely at the neutral.

ANSWER 32

Correct answer: B. It accounts for the 120-degree phase displacement between the three voltages

Why: The $\sqrt{3}$ factor mathematically arises from the 120-degree separation between the three phase voltages and is fundamental to relating line and phase quantities in any three-phase system.

Chapter 11: Consumer and Supply Services and Metering

ANSWER 33

Correct answer: C. Both 120 V and 240 V from the same service

Why: With two hot conductors and a neutral, 120 V is available line-to-neutral and 240 V is available line-to-line, from the same three-wire service.

ANSWER 34

Correct answer: B. Once, at the service

Why: The main bonding connection between the system neutral and ground occurs once at the service; downstream panels keep the neutral and bonding systems separated.

ANSWER 35

Correct answer: B. Ahead of (upstream of) the main service disconnect

Why: The meter must measure all energy delivered to the building, so it is positioned upstream of the disconnecting means to capture the complete load.

Chapter 12: Service and Feeder Load Calculations

ANSWER 36

Correct answer: C. 80%

Why: Continuous loads (running 3 hours or more) are limited to 80% of the device rating unless the equipment is specifically listed for 100% continuous duty.

ANSWER 37

Correct answer: B. The two loads rarely, if ever, operate simultaneously

Why: Since heating (winter) and cooling (summer) are not typically used at the same time, the code allows using only the larger of the two connected loads rather than summing both.

ANSWER 38

Correct answer: B. Reflect realistic simultaneous usage rather than full connected load

Why: Demand factors recognize that not all connected loads operate at full capacity simultaneously, producing a realistic and appropriately sized service rather than an oversized one.

ANSWER 39

Correct answer: A. The conductor set from a distribution point to a panelboard, not directly to the final load

Why: A feeder supplies a distribution point, such as a panelboard, rather than terminating directly at the utilization equipment as a branch circuit does.

ANSWER 40

Correct answer: B. Whether the 80% derating applies to sizing

Why: Continuous loads require the 80% continuous-load derating for conductor and overcurrent device sizing; misclassifying a load changes the required equipment size.

Chapter 13: Overcurrent, Ground-Fault, Arc-Fault and Surge Protection

ANSWER 41

Correct answer: B. The maximum fault current it can safely interrupt

Why: Interrupting rating is the maximum fault current the device can safely clear; it must meet or exceed available fault current at that point in the system.

ANSWER 42

Correct answer: B. 4 to 6 mA

Why: Class A GFCIs are calibrated to trip around 4 to 6 mA, a threshold low enough to protect people from a dangerous shock.

ANSWER 43

Correct answer: C. Fire hazards from arcing conditions

Why: AFCI technology detects the electrical signature of arcing, a fire hazard, which is fundamentally different from the shock-hazard imbalance a GFCI detects.

ANSWER 44

Correct answer: B. Is a single-use device that must be replaced after operating

Why: A fuse operates by melting an internal element, a one-time event, while a breaker trips mechanically and can be reset and reused.

ANSWER 45

Correct answer: B. Transient overvoltages such as lightning or switching surges

Why: Surge protection addresses brief, high-magnitude voltage transients, a different hazard than sustained overcurrent, which fuses and breakers address.

ANSWER 46

Correct answer: B. Not exceed the conductor's ampacity, except where specific code exceptions apply

Why: Overcurrent protection is generally sized to not exceed the ampacity of the conductor it protects, safeguarding the conductor itself from overheating.

Chapter 14: Power Distribution Equipment

ANSWER 47

Correct answer: B. Receive feeder power and distribute it to protected branch circuits

Why: A panelboard takes an incoming feeder or service and splits it into multiple branch circuits, each with its own overcurrent protection.

ANSWER 48

Correct answer: B. Prevent the utility and generator sources from being connected simultaneously

Why: A transfer switch ensures only one power source, utility or generator, feeds the load at any time, preventing dangerous backfeed onto utility lines.

ANSWER 49

Correct answer: B. Provide safe, unobstructed access for operation and service

Why: Clear working space ensures a worker has room to safely operate or service equipment without being forced into a hazardous position near energized parts.

Chapter 15: Power Quality and Standby Systems

ANSWER 50

Correct answer: B. Certain harmonic orders do not cancel at the neutral like balanced fundamental currents do

Why: Triplen harmonics (the third and its multiples) can add together rather than cancel at the neutral, unlike balanced fundamental-frequency currents, leading to higher-than-expected neutral current.

ANSWER 51

Correct answer: B. Near-instant, short-duration backup to bridge the gap until other power is available

Why: A UPS uses stored energy (typically batteries) to provide immediate backup with no interruption, while a generator takes time to start and is intended for longer-duration backup.

Chapter 16: Bonding, Grounding and Lightning Protection

ANSWER 52

Correct answer: B. Provide a low-impedance path so fault current can operate the overcurrent device

Why: Bonding ties non-current-carrying metal parts together to carry fault current back to the source with low impedance, allowing the protective device to trip quickly; this is a different function than earth grounding.

ANSWER 53

Correct answer: B. Only once, typically at the service

Why: Single-point bonding at the service prevents unintended parallel neutral current paths on bonding conductors and metal parts, which would occur if the connection were duplicated downstream.

ANSWER 54

Correct answer: B. A low-impedance bonded metallic path

Why: Soil has comparatively high impedance; effective fault clearing relies on a deliberately low-impedance bonded metallic path, not current traveling through the earth.

Chapter 17: Power Generation and Conversion

ANSWER 55

Correct answer: B. Electromagnetic induction from relative motion between field and conductor

Why: AC generation relies on electromagnetic induction: relative motion between a magnetic field and a conductor induces an alternating voltage in the winding.

ANSWER 56

Correct answer: B. AC to DC

Why: Rectification is specifically the process of converting alternating current to direct current, typically using diode-based rectifier circuits.

Chapter 18: Renewable Energy and Energy Storage

ANSWER 57

Correct answer: B. The photovoltaic effect, converting sunlight directly to DC

Why: Solar cells use the photovoltaic effect in semiconductor material to convert light energy directly into DC electrical current, with no moving parts or induction involved.

ANSWER 58

Correct answer: B. They remain energized whenever exposed to light and cannot simply be switched off at the source

Why: Unlike equipment that can be de-energized at its source, a PV array produces voltage any time it is illuminated, which is why rapid-shutdown requirements exist for emergency responders.

Chapter 19: High-Voltage Systems

ANSWER 59

Correct answer: C. 750 V

Why: The code generally treats voltages above 750 V as high voltage, which brings additional installation, clearance and safety requirements into effect.

ANSWER 60

Correct answer: B. Larger defined approach boundaries and often insulated tools such as hot sticks

Why: High-voltage work carries significantly greater arc-flash and shock hazard, requiring larger safe-approach boundaries and specialized insulated tools beyond standard low-voltage practice.

Chapter 20: Transformers

ANSWER 61

Correct answer: B. Primary and secondary voltage

Why: $EP/ES = NP/NS$: the turns ratio directly sets the voltage relationship between primary and secondary windings.

ANSWER 62

Correct answer: B. Winding heating depends on current, which relates to kVA regardless of load power factor

Why: Since winding heating is a function of current rather than true power, rating in kVA protects the windings appropriately regardless of the connected load's power factor.

ANSWER 63

Correct answer: B. Uses a single shared winding and provides no electrical isolation

Why: An autotransformer shares a single winding between primary and secondary via a tap, making it smaller and cheaper but offering no isolation between input and output.

ANSWER 64

Correct answer: C. The CT attempts to maintain ampere-turns balance and can develop very high secondary voltage

Why: With no load path on the secondary, a CT under load attempts to sustain its ampere-turns relationship, resulting in a dangerously high open-circuit secondary voltage.

Chapter 21: Raceways, Conductors, Cables and Enclosures

ANSWER 65

Correct answer: B. The lower temperature rating of its terminations, even if insulation is rated higher

Why: Even where insulation is rated for a higher temperature, terminations (often rated 60 or 75 °C) can be the limiting factor, and ampacity sizing must respect that lower rating.

ANSWER 66

Correct answer: C. 40%

Why: For three or more conductors in a raceway, the standard maximum fill is 40% of the raceway's cross-sectional area.

ANSWER 67

Correct answer: B. Two conductor volume allowances

Why: A device such as a receptacle or switch is counted as two conductor volume allowances, based on the largest conductor connected to it.

ANSWER 68

Correct answer: B. Heat from adjacent current-carrying conductors accumulates, reducing each conductor's safe capacity

Why: When multiple current-carrying conductors share a raceway, their combined heating effect reduces the safe current-carrying capacity of each individual conductor, requiring derating.

ANSWER 69

Correct answer: B. A cable is a factory-assembled unit with its own covering; a raceway is an enclosed channel conductors are pulled into

Why: A cable arrives from the factory as a complete assembly with conductors and covering; a raceway is an empty enclosed pathway into which conductors are separately pulled.

Chapter 22: Branch Circuitry, Luminaires and Lighting Controls

ANSWER 70

Correct answer: B. The final overcurrent device and the connected outlets or equipment

Why: A branch circuit specifically refers to the conductors running from the final protective device to the outlets or equipment it serves, distinct from feeders or service conductors.

ANSWER 71

Correct answer: B. Reduce the risk of injury from foreign objects being inserted, particularly by children

Why: Tamper-resistant receptacles use internal shutters that block insertion unless both prongs of a plug are engaged simultaneously, specifically to protect against child injury.

ANSWER 72

Correct answer: B. Mismatched dimming technology can cause flickering, humming, or premature failure

Why: LED, incandescent, and other lighting technologies respond differently to different dimming methods, and using an incompatible dimmer and load pairing can cause visible or audible problems and shorten equipment life.

Chapter 23: HVAC Electrical Connections and Controls

ANSWER 73

Correct answer: B. Maximum Overcurrent Protection; the largest protective device size permitted

Why: MOCP is Maximum Overcurrent Protection, indicating the largest size of protective device that may be used on that circuit, as specified by the equipment manufacturer.

ANSWER 74

Correct answer: B. It ensures a technician servicing the unit can be certain power cannot be re-energized during work

Why: Visibility or lockability of the disconnect prevents someone else from re-energizing the circuit while a technician is servicing the equipment, a core lockout safety principle.

Chapter 24: Electric Heating Systems and Controls

ANSWER 75

Correct answer: B. Operate continuously for three hours or more

Why: Electric heating is a classic continuous load, commonly running for extended periods, which triggers the requirement to size the circuit at 125% of the load current.

ANSWER 76

Correct answer: B. Automatically cycle or modulate the heater based on sensed temperature

Why: A thermostat senses temperature and controls the heater's operation to maintain a setpoint; it is a control device, not a protective device.

Chapter 25: Exit, Emergency and Life-Safety Lighting

ANSWER 77

Correct answer: B. Ahead of (unswitched by) any local lighting switch

Why: Emergency lighting must activate automatically during a power failure regardless of the position of local switches, so it connects ahead of, and is not controlled by, the local switch.

Chapter 26: Cathodic Protection Systems

ANSWER 78

Correct answer: B. Using an external power source (rectifier) to drive the protective current

Why: Impressed-current systems use a rectifier and external power source to drive protective current, unlike sacrificial anode systems which rely on the natural galvanic action of a more reactive metal.

Chapter 27: Motor Starters and Control Devices

ANSWER 79

Correct answer: B. Carries low-current signals that determine when the power circuit switches

Why: The control circuit handles switching logic at low current, separate from the power circuit, which carries the actual current driving the motor.

ANSWER 80

Correct answer: B. The circuit drops out on a power loss and will not automatically restart when power returns

Why: With three-wire control, a power interruption drops the seal-in contact, so the motor requires the start button to be pressed again rather than restarting automatically, protecting against unexpected startup.

ANSWER 81

Correct answer: B. Normally closed, in series

Why: Stop devices are normally closed and wired in series so that opening any single stop device will de-energize the entire control circuit.

ANSWER 82

Correct answer: B. Sustained overcurrent conditions on the motor itself

Why: Overload relays are sized and set to protect the motor from sustained overcurrent (overload) conditions, a distinct function from the branch circuit's short-circuit protective device.

Chapter 28: AC and DC Drives

ANSWER 83

Correct answer: B. Varying the frequency and voltage supplied to the motor

Why: A VFD electronically varies both frequency and voltage supplied to the motor, allowing continuous speed control rather than fixed-frequency operation.

ANSWER 84

Correct answer: B. Electrical noise and harmonics on the supply system

Why: The switching behaviour of VFDs can introduce electrical noise and harmonic distortion onto the supply, requiring consideration in the overall system design.

Chapter 29: Electric Motors

ANSWER 85

Correct answer: B. The difference between synchronous speed and actual rotor speed, as a percentage

Why: Slip represents how much the rotor lags behind the synchronous (magnetic field) speed, and this lag is fundamentally what allows the induction motor to produce torque.

ANSWER 86

Correct answer: B. Their three-phase supply naturally creates a rotating magnetic field

Why: The three-phase supply itself produces a naturally rotating magnetic field in the stator, which is enough to start rotor rotation without any additional starting mechanism, unlike single-phase motors.

ANSWER 87

Correct answer: B. Draw excessive current on the remaining phases and overheat

Why: When one phase is lost, the motor attempts to continue operating using the remaining phases, drawing significantly higher current on them and risking overheating and winding damage.

ANSWER 88

Correct answer: B. De-energized and isolated

Why: The megohmmeter applies its own test voltage to check insulation integrity, requiring the motor to be de-energized and isolated for both accurate results and safety.

Chapter 30: Automated and Programmable Control Systems

ANSWER 89

Correct answer: B. Reading inputs, executing the control program, and updating outputs

Why: The scan cycle is the PLC's continuous operating loop: read all inputs, process the program logic, then update outputs, repeating at high speed.

ANSWER 90

Correct answer: B. A hard-wired circuit provides a fail-safe path that functions even if the PLC or its program fails

Why: A hard-wired safety circuit operates independently of the PLC's software, ensuring critical safety stops remain functional even in the event of a program fault or PLC failure.

Chapter 31: Fire Alarm and Security Systems

ANSWER 91

Correct answer: B. Identifies the exact individual device that triggered an alarm, not just a zone

Why: Addressable systems assign a unique identifier to each device, allowing the panel to pinpoint exactly which detector or station triggered an alarm, unlike conventional systems which only identify the zone.

ANSWER 92

Correct answer: B. Provide supervision, allowing detection of an open-circuit wiring fault

Why: The end-of-line resistor allows the fire alarm panel to continuously monitor the circuit's integrity, detecting an open circuit or wiring fault even when the system is in a normal, non-alarm state.

ANSWER 93

Correct answer: B. Loops back to the panel, so a single break does not disable devices beyond it

Why: Class A wiring returns to the panel from both ends of the circuit, so a single break still leaves all devices reachable; Class B wiring is not looped, so a single break can disable everything past that point.

Chapter 32: Voice, Data and Communication Systems

ANSWER 94

Correct answer: B. Offers greater bandwidth and distance, and is immune to electromagnetic interference

Why: Fibre-optic cable transmits data as light rather than electrical signals, giving it much higher bandwidth and distance capability while being immune to electromagnetic interference that affects copper.

ANSWER 95

Correct answer: A. Receive both data and low-voltage DC power over the same cable

Why: PoE technology delivers both data communication and low-voltage DC power over the same structured cable, eliminating the need for a separate power circuit to the device.

Chapter 33: Building Automation and Integrated Control

ANSWER 96

Correct answer: B. Allow equipment from different manufacturers to communicate within the system

Why: Standardized protocols like BACnet and Modbus allow otherwise incompatible equipment from different manufacturers to exchange data and coordinate within a single building automation system.

ANSWER 97

Correct answer: B. Integrated and coordinated with occupancy, daylight, and scheduling as part of the overall system

Why: Within a BAS, lighting is generally treated as one coordinated subsystem, integrated with sensors and scheduling rather than operating in isolation from the rest of the building's automated controls.

Exam Toolkit: Cross-Reference and Terminology

ANSWER 98

Correct answer: C. Section 10

Why: Section 10 of the CEC is specifically dedicated to grounding and bonding requirements, distinct from conductors (Section 4), services (Section 6), or motors (Section 28).

ANSWER 99

Correct answer: B. Re-read the stem for a qualifying word that distinguishes the correct answer

Why: Qualifying words like 'minimum,' 'first,' or 'most appropriate' in the question stem are usually the deciding factor between two plausible-sounding options; skipping guarantees a zero, which is never the better choice.

ANSWER 100

Correct answer: C. Megohms

Why: A megohmmeter measures insulation resistance in megohms (millions of Ω), reflecting the very high resistance expected of intact insulation.

LAST WORD

A strong score on this bonus set, on top of the book's own ten practice tests, means you have now been tested on the material from more angles than the real exam will ever ask. That is exactly the position you want to be in on exam morning.