

Fuerteventura-Lanzarote power system: two-node topology

FV-LZ SYSTEM · 2025 CLOSE

Demand	1,592 GWh
Instantaneous peak	272.3 MW
Conventional (cat. A)	364 MW
Wind	105.6 MW
Solar PV	61.2 MW
Renewable share	17.1%
Renewable curtailment	15.67%
Conventional split: 159 MW FV + 205 MW LZ	

CRITICAL N-1 CONTINGENCY

Loss of the 132 kV link electrically separates the two nodes.

LEGEND

-  Thermal station
-  Wind generation
-  Solar PV generation
-  132 kV inter-island link
-  66 kV inter-island link
-  132 kV island backbones
-  66 kV island grid · Lanzarote

Grid: schematic layout.
Renewables: technology presence, not exact siting.

